

**ENERGY SAVINGS OPPORTUNITY SURVEY
FORT BELVOIR, ALEXANDRIA, VIRGINIA**

**A/E CONTRACT NO.
DACA 31-89-C-0198**

**FINAL SUBMITTAL
VOLUME IV**

Calculations

Prepared for

**DEPARTMENT OF THE ARMY
BALTIMORE DISTRICT CORPS OF ENGINEERS
BALTIMORE, MARYLAND**

DTIC QUALITY INSPECTED 2

19971017 180

By

**ENGINEERING APPLICATIONS CONSULTANTS
9004-B CROWNWOOD COURT
BURKE, VIRGINIA 22015-1630**

August 1991

DISTRIBUTION STATEMENT A

**Approved for public release
Distribution Unlimited**




DEPARTMENT OF THE ARMY
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS
P.O. BOX 9005
CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO
ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.
Distribution A. Approved for public release.


Marie Wakefield,
Librarian Engineering

VOLUME IV
CALCULATIONS

Building 505A

Building 1359

Buildings 1-60 (General Officers' Quarters)

Buildings 401-432 (Rossell Village)

Buildings 900-944 (Dogue Creek Village)


Buildings 2600-2787 (Woodlawn Village)

BUILDING 505A

ELECTRICAL PEAK DEMAND

FORT BELVOIR

Peak Day Of July 11, 1989



ESTIMATED ELECTRICAL BILLING DEMAND WHEN USING A GENERATOR

TIME OF DAY GENERATOR ON	KW DEMAND SAVED	GENERATOR HOURS/DAY	ESTIMATED TOTAL BILLING KW DEMAND
1100-1615	1076	5.3	24,230
1110-1600	884	4.8	24,422
1130-1540	614	4.2	24,692
1140-1535	500	3.9	24,806
1150-1500	422	3.2	24,884
1310-1445	346	1.6	24,960
1315-1430	270	1.3	25,036
1330-1420	154	0.8	25,152

FORT BELVOIR KW DEMAND
SUMMER OF 1989

PEAK DAY OF JULY 11, 1989
30 MINUTE DEMANDS

TIME	KW DEMAND
----	-----
0030	16,666
0100	16,358
0130	16,012
0200	15,706
0230	15,514
0300	15,360
0330	15,168
0400	15,092
0430	14,976
0500	15,014
0530	15,322
0600	15,706
0630	16,090
0700	17,510
0730	18,816
0800	20,006
0830	21,082
0900	22,042
0930	22,772
1000	23,462
1030	23,846
1100	24,230
1130	24,692
1200	24,960
1230	24,806
1300	24,922
1330	25,152
1400	25,306 * Peak
1430	25,036
1500	24,884
1530	24,844
1600	24,422
1630	23,654
1700	22,886
1730	22,042
1800	21,696
1830	21,428
1900	21,082
1930	20,928
2000	20,620
2030	20,428
2100	20,276
2130	20,084
2200	19,276
2230	18,508
2300	17,894
2330	17,396
2400	16,896


FORT BELVOIR KW DEMAND
SUMMER OF 1989

PEAK DAY OF JULY 11, 1989
HOURLY DEMANDS

TIME ----	KW DEMAND -----
0100	16,358
0200	15,706
0300	15,360
0400	15,092
0500	15,014
0600	15,706
0700	17,510
0800	20,006
0900	22,042
1000	23,462
1100	24,230
1200	24,960
1300	24,922
1400	25,306 * Peak
1500	24,884
1600	24,422
1700	22,886
1800	21,696
1900	21,082
2000	20,620
2100	20,276
2200	19,276
2300	17,894
2400	16,896


Electrical Peak Demand

Fort belvoir




Electrical Peak Demand

Fort Belvoir



Incremental Peak Demand

Fort Belvoir



ELECTRICAL PEAK DEMANDS
FORT BELVOIR

	1989 -----	1990 -----
HIGHEST BILLING PEAK KW DEMAND:	25,306 KW (July)	28,735 KW (July)
HIGHEST BILLING TOTAL MONTHLY KWH:	11,168,000 KWH (July)	14,868,000 KWH (July)
HOURS USE OF MAXIMUM DEMAND:	441.3 HOURS	517.4 HOURS

ELECTRICAL PEAK DEMANDS
SUBSTATION 505 A

TOTAL CALCULATED PEAK DEMAND FOR SUBSTATION 505 A: 3219 KW

ESTIMATED KW LOAD AVAILABLE AT SUBSTATION 505 A

CIR NO.	KWH (July) 1989	KWH (July) 1990	ESTIMATED 1989 PEAK LOAD (KW)	ESTIMATED 1990 PEAK LOAD (KW)	ESTIMATED AVERAGE PEAK LOAD (1989 & 1990)
-----	-----	-----	-----	-----	-----
CIR. 3	161,400	158,880	366	307	336
CIR. 5	209,400	200,400	474	387	431
CIR. 6	401,600	376,000	910	727	818
CIR. 7	262,400	284,800	595	550	573
CIR. 8	184,000	193,000	417	373	395

Note: The presented circuits are the circuits where metering data is available

SUBSTATION 505 A

EXPECTED COINCIDENTAL KW DEMAND AVAILABLE AT SUBSTATION 505 A

CIR NO.	ESTIMATED AVERAGE PEAK LOAD (KW)	ESTIMATED AVAILABLE COINCIDENTAL KW (Diversified)	GENERAL AREA SERVED
CIR. 3	336	269	0-90 Area
CIR. 5	431	345	200 Area
CIR. 6	818	655	400 Area
CIR. 7	573	458	0-90 Area
CIR. 8	395	316	500 Area

GENERATOR SERVING SINGLE CIRCUITS

PEAK KW	CIRCUIT NUMBER	GENERATOR SIZE (KW)	TIME OF DAY GENERATOR ON	GENERATOR HOURS/DAY	KWH GENERATED PER MONTH
366	3	600	1310-1430	1.4	9,018
474	5	750	1305-1450	1.8	15,016
910	6	1500	1120-1545	4.4	70,470
595	7	1000	1135-1530	3.9	40,841
417	8	750	1310-1445	1.6	11,743

GENERATOR SERVING MULTIPLE CIRCUITS

PEAK KW	CIRCUIT NUMBER	GENERATOR SIZE (KW)	TIME OF DAY GENERATOR ON	GENERATOR HOURS/DAY	KWH GENERATED PER MONTH
803	3+8	1100	1130-1535	4.1	57,944
840	3+5	1200	1125-1540	4.3	63,571
911	8+5	1250	1120-1545	4.4	70,548
1011	3+7	1500	1115-1550	4.6	81,851
1082	8+7	1500	1110-1555	4.7	89,503
1119	5+7	1500	1105-1600	4.8	94,533

Note: Generators larger than 1500 kw have not been evaluated

NATURAL GAS GENERATORS FOR PEAK DEMAND REDUCTION - SUBSTATION 505 A
FORT BELVOIR

JULY DEMAND

SUB. 505 A CIRCUIT NUMBER	ESTIMATED PEAK LOAD	TOTAL FT BELVOIR MAXIMUM POSSIBLE DEMAND REDUCTION	NATURAL GAS GENERATOR NOMINAL SIZE
-----	-----	-----	-----
3	366 KW	269 KW	630 KW
5	474 KW	345 KW	780 KW
6	910 KW	655 KW	1720 KW
7	595 KW	458 KW	1055 KW
8	417 KW	316 KW	630 KW

HOURS OF GENERATION

CIRCUIT NUMBER	START TIME	END TIME	HOURS/DAY	HOURS/MONTH	TOTAL HOURS PER SUMMER
-----	-----	-----	-----	-----	-----
3	1310	1435	1.4	31	123
5	1300	1450	1.8	40	158
6	1120	1545	4.4	97	387
7	1140	1535	3.9	86	343
8	1310	1445	1.6	35	141

KWH GENERATED

CIRCUIT NUMBER	KWH PER MONTH	TOTAL KWH PER SUMMER	TOTAL MBTU SAVED	DEMAND SAVED	GENERATOR SIZE (KW)
-----	-----	-----	-----	-----	-----
3	9,018	36,073	123.1	269	630
5	15,016	60,065	205.0	345	780
6	70,470	281,882	962.1	655	1720
7	40,841	163,363	557.6	458	1055
8	11,743	46,971	160.3	316	630

ENERGY SAVINGS

DEMAND SAVINGS

TOTAL

CIRCUIT NUMBER	KWH \$ SAVED PER MONTH	KWH \$ SAVED PER SEASON	DEMAND SAVED/MONTH SUMMER	DEMAND SAVED/MONTH WINTER	TOTAL ANNUAL DEMAND SAVED	ANNUAL SAVINGS
-----	-----	-----	-----	-----	-----	-----
3	\$195	\$779	\$2,900	\$2,610	\$32,478	\$33,257
5	\$324	\$1,297	\$3,719	\$3,347	\$41,654	\$42,951
6	\$1,522	\$6,089	\$7,061	\$6,355	\$79,082	\$85,171
7	\$882	\$3,529	\$4,937	\$4,444	\$55,297	\$58,826
8	\$254	\$1,015	\$3,406	\$3,066	\$38,153	\$39,167

NATURAL GAS GENERATORS FOR PEAK DEMAND REDUCTION - SUBSTATION 505 A

GENERATING COSTS PER MONTH

CIRCUIT NUMBER	GENERATOR SIZE	GENERATOR CCF/HR	GENERATOR HOURS	ELECTRIC KWH REDUCE	THERMS USED	MBTU GEN./MO.	GENERATING COSTS/MO
3	630	74	31	9,018	1,324	136.5	\$1,364
5	780	83	40	15,016	1,997	205.9	\$2,057
6	1720	195	97	70,470	9,987	1029.6	\$10,286
7	1055	121	86	40,841	5,855	603.7	\$6,031
8	630	74	35	11,743	1,724	177.8	\$1,776

CAPITAL RECOVERY COSTS

CIRCUIT NUMBER	TOTAL SUMMER HOURS	GENERATOR ESTIMATED LIFE	GENERATOR SIZE	TOTAL COST	CAPITAL RECOVERY FACTOR	CAPITAL RECOVERY COSTS/YR
3	123	25	630	\$350,814	0.08776	\$30,787
5	158	25	780	\$477,302	0.08776	\$41,888
6	387	25	1720	\$1,044,131	0.08776	\$91,633
7	343	25	1055	\$735,118	0.08776	\$64,514
8	141	25	630	\$350,814	0.08776	\$30,787

TOTAL ANNUAL GENERATOR COSTS

CIRCUIT NUMBER	GENERATING COSTS	OPERATING COSTS	MAINTEN. COSTS	CAPITAL COSTS	TOTAL ANNUAL GENERATOR COSTS
3	\$5,455	\$4,558	\$361	\$30,787	\$41,162
5	\$8,229	\$5,861	\$601	\$41,888	\$56,579
6	\$41,145	\$14,326	\$2,819	\$91,633	\$149,923
7	\$24,123	\$12,698	\$1,634	\$64,514	\$102,969
8	\$7,103	\$5,210	\$470	\$30,787	\$43,570

NET ESTIMATED SAVINGS

CIRCUIT NUMBER	GENERATOR SIZE (KW)	TOTAL ANNUAL SAVINGS	TOTAL ANNUAL COSTS	TOTAL NET ANNUAL SAVINGS
3	630	\$33,257	\$41,162	(\$7,905)
5	780	\$42,951	\$56,579	(\$13,627)
6	1720	\$85,171	\$149,923	(\$64,753)
7	1055	\$58,826	\$102,969	(\$44,143)
8	630	\$39,167	\$43,570	(\$4,403)*

Note: * Selected generator based on larger net annual savings

COST ESTIMATES FOR NATURAL GAS GENERATORS - SUBSTATION 505 A

	GENERATOR SIZES (KW)			
	630	780	1055	1720
COST OF GENERATOR	\$195,000	\$276,000	\$445,000	\$605,000
TRANSFER SWITCHES	\$63,000	\$78,000	\$105,500	\$172,000
WIRING & CONTROLS	\$6,300	\$7,800	\$10,550	\$17,200
CONCRETE PAD	\$945	\$1,170	\$1,583	\$2,580
GAS LINE (250 ft)	\$2,500	\$2,500	\$2,500	\$2,500
DIGGING, CLEANING, MISC.	\$945	\$1,170	\$1,583	\$2,580
SUB-TOTAL MATERIAL:	\$268,690	\$366,640	\$566,715	\$801,860
TAXES (4.5%):	\$12,091	\$16,499	\$25,502	\$36,084
SUB-TOTAL MATERIAL:	\$280,781	\$383,139	\$592,217	\$837,944
OVERHEAD (10%):	\$28,078	\$38,314	\$59,222	\$83,794
SUB-TOTAL MATERIAL:	\$308,859	\$421,453	\$651,439	\$921,738
PROFIT (10%):	\$30,886	\$42,145	\$65,144	\$92,174
TOTAL MATERIAL:	\$339,745	\$463,598	\$716,583	\$1,013,912
SUB-TOTAL LABOR:	\$7,560	\$9,360	\$12,660	\$20,640
LABOR MARKUP (21%):	\$1,588	\$1,966	\$2,659	\$4,334
SUB-TOTAL LABOR:	\$9,148	\$11,326	\$15,319	\$24,974
OVERHEAD (10%):	\$915	\$1,133	\$1,532	\$2,497
SUB-TOTAL LABOR:	\$10,062	\$12,458	\$16,850	\$27,472
PROFIT (10%):	\$1,006	\$1,246	\$1,685	\$2,747
TOTAL LABOR:	\$11,069	\$13,704	\$18,536	\$30,219
TOTAL MATERIAL & LABOR:	\$350,814	\$477,302	\$735,118	\$1,044,131

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : GAS GENERATOR ON-PK.

06-06-91

Prepared By : E A C

60901891.00

E20-II Advanced Economic Analysis Program

Page 1 of 2

LCCID - based (version 1, level 35).

 STUDY IDENTIFICATION BLOCK

 Project Title : FORT BELVOIR E.S.O.S
 Installation Name : SUBSTATION 505-A
 Project Number : DACA-31-89-C-0198
 Fiscal Year : 1991
 Name of Analyst : EAC

 KEY STUDY DATES

 ECIP Economic Life : 25 (years)

 INVESTMENT COST SUMMARY

 Construction cost \$ 350814
 SIOH costs \$ 19295
 Design costs \$ 21049
 Energy credit calc \$ 352042
 Salvage value cost -\$ 0
 Total investment cost \$ 352042

 ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	160	973	11.37	11063
DIST	7.43	0	0	17.06	0
RESID	9.97	0	0	16.85	0
NAT G	5.33	-711	-3791	17.52	-66413
COAL	0.00	0	0	13.34	0
TOTAL		-551	-2818		\$ -55350

 NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Maintenance	-470	11.65	-5476
Operating	-5210	11.65	-60696
Demand savings	38153	11.65	444482
Total discounted savings(+) / costs(-)			\$ 378310

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : GAS GENERATOR ON-PK.

06-06-91

Prepared By : E A C

60901891.00

E20-II Advanced Economic Analysis Program

Page 2 of 2

LCCID - based (version 1, level 35).

NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	------------------------	------	--------------------	-----------------------

No cost items.

Total discounted savings(+) / costs(-)			\$	0
--	--	--	----	---

DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings			\$	378310
---------------------------	--	--	----	--------

Non-energy one-time savings			\$	0
-----------------------------	--	--	----	---

Total non-energy savings			\$	378310
--------------------------	--	--	----	--------

PROJECT QUALIFICATION TESTS

Project non-energy qualification test.

Energy savings calc			\$	-18265
---------------------	--	--	----	--------

Non-energy savings-to-investment ratio				-0.21
--	--	--	--	-------

(SIR < 1) Project does not qualify.

First year Dollar savings			\$	29655
---------------------------	--	--	----	-------

Total net discounted savings			\$	322961
------------------------------	--	--	----	--------

Discounted savings ratio				0.92
--------------------------	--	--	--	------

(SIR < 1) Project does not qualify.

Simple payback period (years)				11.87
-------------------------------	--	--	--	-------

DIESEL GENERATORS FOR PEAK DEMAND REDUCTION - SUBSTATION 505 A

GENERATING COSTS PER MONTH

CIRCUIT NUMBER	GENERATOR SIZE	GPH	MONTHLY HOURS	KWH	GALLONS	MBTU GEN./MO.	GENERATING COSTS/MO
3	600	31	31	9,018	955	132.4	\$983
5	750	36	40	15,016	1,426	197.7	\$1,468
6	1500	67	97	70,470	6,486	899.6	\$6,680
7	1000	50	86	40,841	4,290	595.0	\$4,419
8	750	36	35	11,743	1,267	175.8	\$1,305

CAPITAL RECOVERY COSTS

CIRCUIT NUMBER	TOTAL SUMMER HOURS	GENERATOR ESTIMATED LIFE	GENERATOR SIZE	TOTAL COST	CAPITAL RECOVERY FACTOR	CAPITAL RECOVERY COSTS/YR
3	123	25	600	\$210,072	0.08776	\$18,436
5	158	25	750	\$262,590	0.08776	\$23,045
6	387	18	1500	\$525,179	0.10122	\$53,159
7	343	20	1000	\$350,120	0.09624	\$33,696
8	141	25	750	\$262,590	0.08776	\$23,045

TOTAL GENERATOR COSTS

CIRCUIT NUMBER	GENERATING COSTS	OPERATING COSTS	MAINTEN. COSTS	CAPITAL COSTS	TOTAL ANNUAL GENERATOR COSTS
3	\$3,934	\$4,558	\$451	\$18,436	\$27,379
5	\$5,873	\$5,861	\$751	\$23,045	\$35,530
6	\$26,721	\$14,326	\$3,524	\$53,159	\$97,729
7	\$17,675	\$12,698	\$2,042	\$33,696	\$66,111
8	\$5,221	\$5,210	\$587	\$23,045	\$34,062

NET ESTIMATED SAVINGS

CIRCUIT NUMBER	GENERATOR SIZE (KW)	TOTAL ANNUAL SAVINGS	TOTAL ANNUAL COSTS	TOTAL NET ANNUAL SAVINGS
3	600	\$33,257	\$27,379	\$5,878
5	750	\$42,951	\$35,530	\$7,421 *
6	1500	\$85,171	\$97,729	(\$12,559)
7	1000	\$58,826	\$66,111	(\$7,285)
8	750	\$39,167	\$34,062	\$5,105

Note: * Selected generator based on larger net annual savings

COSTS ESTIMATES FOR DIESEL GENERATORS - SUBSTATION 505 A

	GENERATOR SIZES (KW)						
	500	600	750	1000	1100	1250	1500
COST OF GENERATOR	\$75,000	\$90,000	\$112,500	\$150,000	\$165,000	\$187,500	\$225,000
TRANSFER SWITCHES	\$50,000	\$60,000	\$75,000	\$100,000	\$110,000	\$125,000	\$150,000
WIRING & CONTROLS	\$5,000	\$6,000	\$7,500	\$10,000	\$11,000	\$12,500	\$15,000
CONCRETE PAD	\$750	\$900	\$1,125	\$1,500	\$1,650	\$1,875	\$2,250
DIGGING, CLEANING, MISC.	\$750	\$900	\$1,125	\$1,500	\$1,650	\$1,875	\$2,250
SUB-TOTAL MATERIAL:	\$131,500	\$157,800	\$197,250	\$263,000	\$289,300	\$328,750	\$394,500
TAXES (4.5%):	\$5,918	\$7,101	\$8,876	\$11,835	\$13,019	\$14,794	\$17,753
SUB-TOTAL MATERIAL:	\$137,418	\$164,901	\$206,126	\$274,835	\$302,319	\$343,544	\$412,253
OVERHEAD (10%):	\$13,742	\$16,490	\$20,613	\$27,484	\$30,232	\$34,354	\$41,225
SUB-TOTAL MATERIAL:	\$151,159	\$181,391	\$226,739	\$302,319	\$332,550	\$377,898	\$453,478
PROFIT (10%):	\$15,116	\$18,139	\$22,674	\$30,232	\$33,255	\$37,790	\$45,348
TOTAL MATERIAL:	\$166,275	\$199,530	\$249,413	\$332,550	\$365,805	\$415,688	\$498,826
SUB-TOTAL LABOR:	\$6,000	\$7,200	\$9,000	\$12,000	\$13,200	\$15,000	\$18,000
LABOR MARKUP (21%):	\$1,260	\$1,512	\$1,890	\$2,520	\$2,772	\$3,150	\$3,780
SUB-TOTAL LABOR:	\$7,260	\$8,712	\$10,890	\$14,520	\$15,972	\$18,150	\$21,780
OVERHEAD (10%):	\$726	\$871	\$1,089	\$1,452	\$1,597	\$1,815	\$2,178
SUB-TOTAL LABOR:	\$7,986	\$9,583	\$11,979	\$15,972	\$17,569	\$19,965	\$23,958
PROFIT (10%):	\$799	\$958	\$1,198	\$1,597	\$1,757	\$1,997	\$2,396
TOTAL LABOR:	\$8,785	\$10,542	\$13,177	\$17,569	\$19,326	\$21,962	\$26,354
TOTAL MATERIAL & LABOR:	\$175,060	\$210,072	\$262,590	\$350,120	\$385,132	\$437,649	\$525,179

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : DIESEL GEN. ON-PEAK

06-07-91

Prepared By : E A C

60901891.00

E20-II Advanced Economic Analysis Program

Page 1 of 2

LCCID - based (version 1, level 35).

STUDY IDENTIFICATION BLOCK

Project Title	:	FORT BELVOIR E.S.O.S
Installation Name	:	SUBSTATION 505-A
Project Number	:	DACA-31-89-C-0198
Fiscal Year	:	1991
Name of Analyst	:	EAC

KEY STUDY DATES

ECIP Economic Life	:	25 (years)
--------------------	---	------------

INVESTMENT COST SUMMARY

Construction cost	\$	262590
SIOH costs	\$	14442
Design costs	\$	15755
Energy credit calc	\$	263508
Salvage value cost	-\$	0
Total investment cost	\$	263508

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	205	1244	11.37	14148
DIST	7.43	-791	-5878	17.06	-100277
RESID	9.97	0	0	16.85	0
NAT G	5.33	0	0	17.52	0
COAL	0.00	0	0	13.34	0
TOTAL		-586	-4634		\$ -86128

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Maintenance	-751	11.65	-8749
Operating	-5861	11.65	-68281
Demand savings	41654	11.65	485269
Total discounted savings(+) / costs(-)			\$ 408239

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : DIESEL GEN. ON-PEAK

06-07-91

Prepared By : E A C

60901891.00

E20-II Advanced Economic Analysis Program

Page 2 of 2

LCCID - based (version 1, level 35).

 NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings

No cost items.				

Total discounted savings(+) / costs(-)			\$	0
--	--	--	----	---

 DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings			\$	408239
Non-energy one-time savings			\$	0

Total non-energy savings			\$	408239

 PROJECT QUALIFICATION TESTS

Project non-energy qualification test.				
Energy savings calc			\$	-28422
Non-energy savings-to-investment ratio				-0.43
(SIR < 1) Project does not qualify.				
First year Dollar savings			\$	30408
Total net discounted savings			\$	322111
Discounted savings ratio				1.22
Simple payback period (years)				8.67

SUBSTATION 505 A

NATURAL GAS GENERATOR FOR STANDBY GENERATION

ENERGY GENERATED

SEASON	GENERATOR SIZE (KW)	KW REDUCED	MAXIMUM GEN. HOURS	ESTIMATED GEN. HOURS	MAXIMUM KWH GENERATED	ESTIMATED KWH GENERATED	TOTAL MBTU
Summer	630	345	100	60	34500	20700	70.6
Winter	630	150	100	60	15000	9000	30.7
TOTALS:						29700	101.4

ENERGY REQUIRED TO GENERATE

SEASON	GENERATOR SIZE (KW)	FULL LOAD CCF/HOUR	PART. LOAD CCF/HOUR	GENERATOR MAX. HOURS	GENERATOR EST. HOURS	NATURAL GAS THERMS	TOTAL MBTU
Summer	630	74	41	100	60	2431	250.7
Winter	630	74	74	100	60	4440	457.8
TOTALS:						6871	708.4

ANNUAL OPERATION AND MAINTENANCE COSTS

SEASON	ESTIMATED HOURS	EXPECTED LIFE	TOTAL KWH	OPERATING COSTS	MAINTENANCE COSTS	TOTAL O&M COSTS
Summer	60	25	20700	\$2,220	\$207	\$2,427
Winter	60	25	9000	\$2,220	\$90	\$2,310
TOTALS:				\$4,440	\$297	\$4,737

ELECTRIC SAVINGS WITH MSSG RATE

SEASON	TOTAL KWH	TOTAL KW	TOTAL MBTU	KWH \$ SAVINGS	DEMAND PAYMENTS	TOTAL SAVINGS
Summer	20700	345	70.6	\$429	\$12,420	\$12,849
Winter	9000	150	30.7	\$186	\$5,400	\$5,586
TOTALS:				\$615	\$17,820	\$18,435

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : GAS GEN. STANDBY

06-07-91

Prepared By : E A C

60901891.00

E20-II Advanced Economic Analysis Program

Page 1 of 2

CCID - based (version 1, level 35).

STUDY IDENTIFICATION BLOCK

Project Title	:	FORT BELVOIR E.S.O.S
Installation Name	:	SUBSTATION 505-A
Project Number	:	DACA-31-89-C-0198
Fiscal Year	:	1991
Name of Analyst	:	EAC

KEY STUDY DATES

ECIP Economic Life	:	25 (years)
--------------------	---	------------

INVESTMENT COST SUMMARY

Construction cost	\$	350814
SIOH costs	\$	19295
Design costs	\$	21049
Energy credit calc	\$	352042
Salvage value cost	-\$	0
Total investment cost	\$	352042

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
Fuel					
ELEC	6.07	101	615	11.37	6998
DIST	7.43	0	0	17.06	0
RESID	9.97	0	0	16.85	0
NAT G	5.33	-708	-3776	17.52	-66152
COAL	0.00	0	0	13.34	0
TOTAL		-607	-3160		\$ -59153

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Maintenance	-297	11.65	-3460
Operating	-4440	11.65	-51726
Demand credits	17820	11.65	207603
Total discounted savings(+) / costs(-)			\$ 152417

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : GAS GEN. STANDBY

06-07-91

Prepared By : E A C

60901891.00

E20-II Advanced Economic Analysis Program

Page 2 of 2

CCID - based (version 1, level 35).

NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	------------------------	------	--------------------	-----------------------

No cost items.

Total discounted savings(+) / costs(-)			\$	0
--	--	--	----	---

DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings			\$	152417
---------------------------	--	--	----	--------

Non-energy one-time savings			\$	0
-----------------------------	--	--	----	---

Total non-energy savings			\$	152417
--------------------------	--	--	----	--------

PROJECT QUALIFICATION TESTS

Project non-energy qualification test.

Energy savings calc			\$	-19521
---------------------	--	--	----	--------

Non-energy savings-to-investment ratio				-0.22
--	--	--	--	-------

(SIR < 1) Project does not qualify.

First year Dollar savings			\$	9923
---------------------------	--	--	----	------

Total net discounted savings			\$	93264
------------------------------	--	--	----	-------

Discounted savings ratio				0.26
--------------------------	--	--	--	------

(SIR < 1) Project does not qualify.

Simple payback period (years)				35.48
-------------------------------	--	--	--	-------

SUBSTATION 505 A

DIESEL GENERATOR FOR STANDBY GENERATION

ENERGY GENERATED

SEASON	GENERATOR SIZE (KW)	KW REDUCED	MAXIMUM HOURS	MAXIMUM KWH GENERATED	ESTIMATED KWH GENERATED	TOTAL MBTU
Summer	750	345	100	34500	20700	70.6
Winter	750	150	100	15000	9000	30.7
TOTALS:					29700	101.4

ENERGY REQUIRED TO GENERATE

SEASON	GENERATOR SIZE (KW)	FUEL GPH	GENERATOR MAX. HOURS	GENERATOR EST. HOURS	DIESEL GALLONS	TOTAL MBTU
Summer	750	30	100	60	1800	249.7
Winter	750	16	100	60	960	133.2
TOTALS:					2760	382.8

ANNUAL OPERATION AND MAINTENANCE COSTS

SEASON	ESTIMATED HOURS	EXPECTED LIFE	TOTAL KWH	OPERATING COSTS	MAINTENANCE COSTS	TOTAL O & M COSTS
Summer	60	25	20700	\$2,220	\$259	\$2,479
Winter	60	25	9000	\$2,220	\$113	\$2,333
TOTALS:				\$4,440	\$371	\$4,811

ELECTRIC SAVINGS WITH MSSG RATE

SEASON	TOTAL KWH	TOTAL KW	TOTAL MBTU	KWH \$ SAVINGS	DEMAND PAYMENTS	TOTAL SAVINGS
Summer	20700	345	70.6	\$429	\$12,420	\$12,849
Winter	9000	150	30.7	\$186	\$5,400	\$5,586
TOTALS:				\$615	\$17,820	\$18,435

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : DIESEL GEN. STANDBY

06-07-91

Prepared By : E A C

60901891.00

E20-II Advanced Economic Analysis Program

Page 1 of 2

LCCID - based (version 1, level 35).

STUDY IDENTIFICATION BLOCK

Project Title	:	FORT BELVOIR E.S.O.S
Installation Name	:	SUBSTATION 505-A
Project Number	:	DACA-31-89-C-0198
Fiscal Year	:	1991
Name of Analyst	:	EAC

KEY STUDY DATES

ECIP Economic Life	:	25 (years)
--------------------	---	------------

INVESTMENT COST SUMMARY

Construction cost	\$	262590
SIOH costs	\$	14442
Design costs	\$	15755
Energy credit calc	\$	263508
Salvage value cost	-\$	0
Total investment cost	\$	263508

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
Fuel					
ELEC	6.07	101	615	11.37	6998
DIST	7.43	-383	-2844	17.06	-48522
RESID	9.97	0	0	16.85	0
NAT G	5.33	0	0	17.52	0
COAL	0.00	0	0	13.34	0
TOTAL		-281	-2229		\$ -41524

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Maintenance	-615	11.65	-7165
Operating	-4440	11.65	-51726
Demand credits	17820	11.65	207603
Total discounted savings(+) / costs(-)			\$ 148712

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : DIESEL GEN. STANDBY

06-07-91

Prepared By : E A C

60901891.00

E20-II Advanced Economic Analysis Program

Page 2 of 2

LCCID - based (version 1, level 35).

 NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	------------------------	------	--------------------	-----------------------

 No cost items.

Total discounted savings(+) / costs(-)			\$	0
--	--	--	----	---

 DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings			\$	148712
---------------------------	--	--	----	--------

Non-energy one-time savings			\$	0
-----------------------------	--	--	----	---

Total non-energy savings			\$	148712
--------------------------	--	--	----	--------

 PROJECT QUALIFICATION TESTS

 Project non-energy qualification test.

Energy savings calc			\$	-13703
---------------------	--	--	----	--------

Non-energy savings-to-investment ratio				-0.21
--	--	--	--	-------

(SIR < 1) Project does not qualify.

First year Dollar savings			\$	10536
---------------------------	--	--	----	-------

Total net discounted savings			\$	107188
------------------------------	--	--	----	--------

Discounted savings ratio				0.41
--------------------------	--	--	--	------

(SIR < 1) Project does not qualify.

Simple payback period (years)				25.01
-------------------------------	--	--	--	-------

BUILDING 1359

BUILDING 1359

TABLE OF CONTENTS

Input Data	1359-1
Output Data	1359-85
ECIP Analysis	
ECO #1	1359-89
ECO \$2	1359-95
ECO #3	1359-101
ECO #4	1359-107
ECO #5	1359-113
ECO #6	1359-120
ECO #7	1359-127
ECO #8	1359-133

DESIGN PARAMETERS, SHGs

Location : FT. BELVOIR, VIRGINIA

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

DESIGN WEATHER PARAMETERS

City Name.....: FT. BELVOIR
 Location.....: VIRGINIA
 Latitude.....: 38.4 deg
 Elevation.....: 69.0 ft
 Summer Design Dry Bulb Temp.....: 90.0 F
 Summer Design Wet Bulb Temp.....: 75.0 F
 Daily Temperature Range.....: 23.0 F
 Winter Design Dry Bulb Temp.....: 12.0 F
 Atmospheric Clearness Number.....: 1.00

TABLE 1. MAXIMUM SOLAR HEAT GAINS - AVERAGE DAYS
(BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	24.2	61.1	97.3	110.1	97.3	61.1	24.2	24.2	80.0
Feb	31.8	74.8	105.7	113.8	105.7	74.8	31.8	31.8	107.2
Mar	40.8	87.0	106.9	108.0	106.9	87.0	40.8	40.8	136.8
Apr	60.0	97.4	104.4	97.2	104.4	97.4	60.0	49.3	164.3
May	74.9	103.0	98.4	84.0	98.4	103.0	74.9	54.9	181.8
Jun	85.1	109.3	97.5	79.2	97.5	109.3	85.1	57.9	195.2
Jul	80.6	106.7	98.1	81.4	98.1	106.7	80.6	56.4	189.3
Aug	69.1	104.1	105.7	94.4	105.7	104.1	69.1	52.2	177.6
Sep	52.3	99.3	114.8	111.6	114.8	99.3	52.3	45.4	158.1
Oct	36.4	88.3	117.7	122.9	117.7	88.3	36.4	36.4	128.2
Nov	26.7	66.5	101.8	113.3	101.8	66.5	26.7	26.7	89.4
Dec	21.4	53.0	87.6	100.9	87.6	53.0	21.4	21.4	68.4

TABLE 2. MAXIMUM SOLAR HEAT GAINS - DESIGN DAYS
(BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	20.4	158.9	243.9	253.8	243.9	158.9	20.4	20.4	142.0
Feb	53.0	189.1	246.5	237.5	246.5	189.1	53.0	24.7	187.7
Mar	95.9	219.8	234.5	200.7	234.5	219.8	95.9	29.4	229.0
Apr	141.6	224.4	200.1	146.7	200.1	224.4	141.6	34.1	256.0
May	166.1	220.1	170.7	104.6	170.7	220.1	166.1	37.4	268.0
Jun	173.2	215.4	156.7	87.8	156.7	215.4	173.2	47.4	269.7
Jul	163.7	215.7	166.5	101.4	166.5	215.7	163.7	38.3	264.7
Aug	136.4	216.6	193.1	141.7	193.1	216.6	136.4	35.8	251.3
Sep	90.3	207.2	224.7	194.9	224.7	207.2	90.3	30.6	221.4
Oct	52.0	182.7	238.2	230.6	238.2	182.7	52.0	25.5	184.4
Nov	20.7	156.1	239.8	249.9	239.8	156.1	20.7	20.7	141.3
Dec	18.5	141.9	236.4	254.2	236.4	141.9	18.5	18.5	122.2

1359-1A

MASTER SCHEDULE SUMMARY

Page 1

Prepared By : E A C

04-27-91

Barrier Hourly Analysis Program

6100190202

MASTER SCHEDULE 1. OCCUPANCY (GENERAL) Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	0	0	0	0	0	0	80	100	100	100	100	100
Saturday	0	0	0	0	0	0	0	5	25	30	30	30
Sunday	0	0	0	0	0	0	0	5	25	30	30	30
DESIGN	0	0	0	0	0	10	80	100	100	100	100	100

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	100	100	100	100	80	50	50	10	5	5	0	0
Saturday	30	30	30	30	25	5	0	0	0	0	0	0
Sunday	30	30	30	30	25	5	0	0	0	0	0	0
DESIGN	100	100	100	100	100	100	100	20	10	0	0	0

MASTER SCHEDULE 2. LIGHTING Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	5	5	5	5	5	10	80	90	100	100	100	100
Saturday	5	5	5	5	5	5	5	20	80	80	80	90
Sunday	5	5	5	5	5	5	5	20	80	80	80	90
DESIGN	10	10	10	10	10	20	50	100	100	100	100	100

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	100	100	100	100	90	70	70	70	70	70	70	10
Saturday	90	90	90	90	50	40	5	5	5	5	5	5
Sunday	90	90	90	90	50	40	5	5	5	5	5	5
DESIGN	100	100	100	100	100	100	100	50	20	10	10	10

MASTER SCHEDULE 3. EQUIPMENT Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	5	5	5	5	5	5	20	50	100	100	100	100
Saturday	5	5	5	5	5	5	10	10	15	20	20	20
Sunday	5	5	5	5	5	5	5	10	10	10	10	20
DESIGN	10	10	10	10	10	20	40	100	100	100	100	100

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	100	100	100	100	80	50	20	10	5	5	5	5
Saturday	20	20	20	10	10	10	10	10	5	5	5	5
Sunday	20	15	15	10	10	10	10	5	5	5	5	5
DESIGN	100	100	100	100	100	100	100	40	20	10	10	10

MASTER SCHEDULE SUMMARY

Page 2

Prepared By : E A C

04-27-91

Carrier Hourly Analysis Program

6100190202

MASTER SCHEDULE 4. DOMESTIC HOT WATER Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	0	0	0	0	0	5	10	10	20	20	20	80
Saturday	0	0	0	0	0	2	2	2	5	5	5	5
Sunday	0	0	0	0	0	0	0	2	2	2	2	2
DESIGN	0	0	0	0	0	5	5	20	20	20	20	80

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	80	20	20	20	10	10	5	5	5	2	0	0
Saturday	5	5	5	2	2	2	2	2	0	0	0	0
Sunday	2	2	2	2	2	2	0	0	0	0	0	0
DESIGN	80	20	20	20	10	10	5	5	2	2	0	0

MASTER SCHEDULE 5. OCCUPANCY (TOWER) Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	0	0	0	0	0	0	100	100	100	100	100	100
Saturday	0	0	0	0	0	0	0	33	100	100	100	100
Sunday	0	0	0	0	0	0	0	33	100	100	100	100
DESIGN	0	0	0	0	0	10	100	100	100	100	100	100

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	100	100	100	100	100	100	100	100	100	100	100	33
Saturday	100	100	100	100	66	0	0	0	0	0	0	0
Sunday	100	100	100	100	66	0	0	0	0	0	0	0
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

MASTER SCHEDULE 6. EQUIPMENT (CONSTANT) Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	10	10	10	10	10	10	80	100	100	100	100	100
Saturday	10	10	10	10	10	10	10	10	80	100	100	100
Sunday	10	10	10	10	10	10	10	10	80	100	100	100
DESIGN	10	10	10	10	10	20	80	100	100	100	100	100

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	100	100	100	100	80	80	80	80	80	80	80	10
Saturday	100	100	100	100	80	80	50	10	10	10	10	10
Sunday	100	100	100	100	80	80	50	10	10	10	10	10
DESIGN	100	100	100	100	100	100	100	100	100	100	100	10

MASTER SCHEDULE SUMMARY

Page 3

Prepared By : E A C

04-27-91

Carrier Hourly Analysis Program

6100190202

MASTER SCHEDULE 7. PIPE & EQ. RADIATION Hourly Percentages


Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	100	100	100	100	100	100	100	100	100	100	100	100
Saturday	100	100	100	100	100	100	100	100	100	100	100	100
Sunday	100	100	100	100	100	100	100	100	100	100	100	100
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	100	100	100	100	100	100	100	100	100	100	100	100
Saturday	100	100	100	100	100	100	100	100	100	100	100	100
Sunday	100	100	100	100	100	100	100	100	100	100	100	100
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100


MASTER SCHEDULE 8. OCCUPANCY (RADAR RM.) Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	0	0	0	0	0	0	0	33	100	100	100	100
Saturday	0	0	0	0	0	0	0	33	66	66	66	66
Sunday	0	0	0	0	0	0	0	0	0	0	0	0
DESIGN	0	0	0	0	0	33	100	100	100	100	100	100


Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	66	100	100	100	100	66	33	0	0	0	0	0
Saturday	33	66	66	66	66	33	0	0	0	0	0	0
Sunday	0	0	0	0	0	0	0	0	0	0	0	0
DESIGN	100	100	100	100	100	100	100	100	100	100	100	33





THIRD FLOOR PLAN




SECOND FLOOR PLAN




GROUND FLOOR PLAN




SEVENTH FLOOR PLAN



SIXTH FLOOR PLAN



FIFTH FLOOR PLAN



FOURTH FLOOR PLAN

BUILDING 1359 KEY PLAN

ENGINEERING ANALYSIS

Sheet 1 of 1

By: REF

Calculations for Infiltration

Building

Project: ESOS, Fort BELVOIR, BLDG 1359 Date: DEC. 1990

Contract No: DACA-31-89-C-0189 EAC Project No.: 89034.0

Calculations based on ASHRAE 1989 Page F 2.3.14.

Building Leakage Area

	Effective Leakage Area, in ²	Building Component Parameter	Building Leakage Area D _L , in ²
	L	D_L	L
SKIN CRACK	.5/LF	80 FT	40.00
Sill foundation	0.19/ft. of perimeter	84 ft.	15.96
Joints, ceiling/wall	0.12/ft. of wall	84 ft.	10.10
Windows	0.063/ft ² . of window	135 ft ² .	8.50
Doors	0.215/ft ² . of doors	78 ft ² .	16.77
Wall - Window frames	0.15/ft ² . of window	135 ft ² .	20.25
- Door frames	0.072/ft ² . of door	78 ft ² .	5.62
Elec. outlet/switch	0.16/fixture	20 ft ² .EA.	3.20
Recessed lights	1.6/fixture	6 ft ² .EA.	9.60
Pipe penetration	1.55/in ² . of pipe	4 ft ² .EA.	6.20
Exhaust fans	6.0/fan	2 ft ² .EA.	12.00
Duct penetration	2.2/SF	16.5 SF	36.30
FCU openings	60 x 1/3(SF/unit) x 2.2/SF		<u>1</u>
			185 in ² .

Infiltration $Q(\text{cfm}) = L \times (A \Delta t + B \nabla^2)^{1/2}$

(ASHRAE 1989, P. 23.17, EQ.33)

Winter

Summer

$$\begin{aligned} Q(\text{cfm}) &= \\ &= L(0.01313 \times 51 + 0.0157 \times 14^2)^{1/2} \\ &= L \times 2.2 \\ &= 185 \times 2.2 = 407 \text{ CFM} \end{aligned}$$

$$\begin{aligned} \text{Rate} &= \frac{407}{2940} \\ &= 0.139 \text{ CFM/SF} \end{aligned}$$

$$\begin{aligned} &= L(0.0313 \times 15 + 0.0157 \times 10^2)^{1/2} \\ &= L \times 1.45 \\ &= 185 \times 1.45 = 270 \text{ CFM} \end{aligned}$$

$$\begin{aligned} \text{Rate} &= \frac{270}{2940} \\ &= 0.092 \text{ CFM/SF} \end{aligned}$$

COMPLEX SPACE DESCRIPTION

Space Name : GROUND FL. - EQUIP. RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = GROUND FL. - EQUIP. RM.

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	0.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	138.0	0.0	33.7
W	0.0	0.0	0.0
NW	0.0	0.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->						
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : GROUND FL. - EQUIP. RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

<----- Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	8.3	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	:	Floor Area	=	275 sqft	Building Wt. =	M	lb/sqft
PEOPLE	:	sqft/person	=	0.0	Total People =		0
	:	Schedule No.	=	1	Activity Level =		2
LIGHTING	:	W/sqft	=	1.31	Total Watts =		360
	:	Schedule No.	=	2	Wattage Mult. =		1.00
	:	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	4.00	Total Watts =			1,100
	Schedule No.	=	6				
MISC. SENSIBLE:	Load	=	6,700 BTU/hr	Schedule No. =			4
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No. =			1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	130.0	0.400	0.0 F	0.0 F
Ceilings	70.0	0.420	0.0 F	30.0 F
Floors	0.0	0.100	90.0 F	50.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	41 CFM	Area	: 275.0 sqft
Heating	: 0.28 CFM/sqft =	77 CFM	Perimeter	: 34.0 ft
Typical	: 0.28 CFM/sqft =	77 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : GROUND FL. - STORAGE RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = GROUND FL. - STORAGE RM.

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	70.0	0.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	70.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	0.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : GROUND FL. - STORAGE RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

Exposure	<----- Glass Areas (sqft) ----->					
	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	:	Floor Area	=	50 sqft	Building Wt. =	M lb/sqft
PEOPLE	:	sqft/person	=	0.0	Total People =	0
	:	Schedule No.	=	1	Activity Level =	2
LIGHTING	:	W/sqft	=	1.20	Total Watts =	60
	:	Schedule No.	=	2	Wattage Mult. =	1.00
	:	Fixture Type	=	3 Free-hanging		
OTHER ELECTRIC:	:	W/sqft	=	0.00	Total Watts =	0
	:	Schedule No.	=	3		
MISC. SENSIBLE:	:	Load	=	0 BTU/hr	Schedule No. =	4
MISC. LATENT	:	Load	=	0 BTU/hr	Schedule No. =	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)	Unconditioned Space Temp.			
	Area (sqft)	U-Value (BTU/hr/sqft/F)	Cooling (deg F or %)	Heating (deg F or %)
Walls	0.0	0.400	110.0 %	10.0 F
Ceilings	0.0	0.420	15.0 F	10.0 F
Floors	0.0	0.100	90.0 F	50.0 F

INFILTRATION		GROUND ELEMENT			
Cooling	: 0.14 CFM/sqft =	7 CFM	Area	:	50.0 sqft
Heating	: 0.10 CFM/sqft =	5 CFM	Perimeter	:	14.0 ft
Typical	: 0.14 CFM/sqft =	7 CFM	Depth	:	0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : GROUND FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = GROUND FL. - STAIR

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	96.0	0.0	21.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	0.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : GROUND FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

Exposure	Glass Areas (sqft)					
	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	95 sqft	Building Wt.	=	M lb/sqft
PEOPLE	: sqft/person	=	0.0	Total People	=	0
	Schedule No.	=	1	Activity Level	=	2
LIGHTING	: W/sqft	=	1.26	Total Watts	=	120
	Schedule No.	=	2	Wattage Mult.	=	1.00
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	0.00	Total Watts	=	0
	Schedule No.	=	3			
MISC. SENSIBLE:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	70.0	0.420	10.0 F	10.0 F
Ceilings	0.0	0.420	15.0 F	10.0 F
Floors	0.0	0.100	90.0 F	50.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	14 CFM	Area	: 95.0 sqft
Heating	: 0.28 CFM/sqft =	27 CFM	Perimeter	: 28.0 ft
Typical	: 0.28 CFM/sqft =	27 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 2ND FL. - OFFICE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 2ND FL. - OFFICE

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	0.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	138.0	0.0	0.0
W	0.0	0.0	0.0
NW	130.0	0.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 2ND FL. - OFFICE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

Exposure	<----- Glass Areas (sqft) ----->					
	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	12.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	275 sqft	Building Wt. =	M lb/sqft
PEOPLE	: sqft/person	=	137.5	Total People =	2
	Schedule No.	=	1	Activity Level =	2
LIGHTING	: W/sqft	=	1.19	Total Watts =	326
	Schedule No.	=	2	Wattage Mult. =	1.00
	Fixture Type	=	3 Free-hanging		
OTHER ELECTRIC:	W/sqft	=	1.20	Total Watts =	330
	Schedule No.	=	3		
MISC. SENSIBLE:	Load	=	3,000 BTU/hr	Schedule No. =	7
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No. =	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)	Unconditioned Space Temp.			
	Area	U-Value	Cooling	Heating
	(sqft)	(BTU/hr/sqft/F)	(deg F or %)	(deg F or %)
Walls	130.0	0.400	90.0 %	30.0 F
Ceilings	0.0	0.420	15.0 F	10.0 F
Floors	275.0	0.270	90.0 %	30.0 F

INFILTRATION		GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	41 CFM	Area : 0.0 sqft
Heating	: 0.20 CFM/sqft =	55 CFM	Perimeter : 0.0 ft
Typical	: 0.20 CFM/sqft =	55 CFM	Depth : 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 2ND FL. - LATRINE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 2ND FL. - LATRINE

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	64.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	70.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 2ND FL. - LATRINE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

Exposure	<----- Glass Areas (sqft) ----->					
	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	6.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	:	Floor Area	=	50 sqft	Building Wt. =	M	lb/sqft
PEOPLE	:	sqft/person	=	0.0	Total People	=	0
	:	Schedule No.	=	1	Activity Level	=	2
LIGHTING	:	W/sqft	=	1.20	Total Watts	=	60
	:	Schedule No.	=	2	Wattage Mult.	=	1.00
	:	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	:	W/sqft	=	0.00	Total Watts	=	0
	:	Schedule No.	=	3			
MISC. SENSIBLE:	:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	:	Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	0.0	0.400	110.0 %	10.0 F
Ceilings	0.0	0.270	15.0 F	10.0 F
Floors	50.0	0.270	0.0 F	40.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	:	0.15 CFM/sqft =	8 CFM	Area : 0.0 sqft
Heating	:	0.20 CFM/sqft =	10 CFM	Perimeter : 0.0 ft
Typical	:	0.20 CFM/sqft =	10 CFM	Depth : 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 2ND FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 2ND FL. - STAIR

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	118.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	0.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 2ND FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

----- Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	12.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	95 sqft	Building Wt.	=	M lb/sqft
PEOPLE	: sqft/person	=	0.0	Total People	=	0
	Schedule No.	=	1	Activity Level	=	2
LIGHTING	: W/sqft	=	1.26	Total Watts	=	120
	Schedule No.	=	2	Wattage Mult.	=	1.00
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	0.00	Total Watts	=	0
	Schedule No.	=	3			
MISC. SENSIBLE:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	0.0	0.400	0.0 %	0.0 %
Ceilings	0.0	0.420	15.0 F	10.0 F
Floors	0.0	0.100	90.0 F	50.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	14 CFM	Area	: 0.0 sqft
Heating	: 0.20 CFM/sqft =	19 CFM	Perimeter	: 0.0 ft
Typical	: 0.20 CFM/sqft =	19 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 3RD FL. - OFFICE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 3RD FL. - OFFICE

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	70.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	0.0	188.0	0.0
W	0.0	0.0	0.0
NW	0.0	200.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 3RD FL. - OFFICE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

<----- Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	12.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	:	Floor Area	=	275 sqft	Building Wt. =	M	lb/sqft
PEOPLE	:	sqft/person	=	68.8	Total People =		4
	:	Schedule No.	=	1	Activity Level =		2
LIGHTING	:	W/sqft	=	1.28	Total Watts =		352
	:	Schedule No.	=	2	Wattage Mult. =		1.20
	:	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	:	W/sqft	=	3.02	Total Watts =		830
	:	Schedule No.	=	3			
MISC. SENSIBLE:	:	Load	=	2,000 BTU/hr	Schedule No. =		7
MISC. LATENT	:	Load	=	0 BTU/hr	Schedule No. =		1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
	Area (sqft)	U-Value (BTU/hr/sqft/F)	Cooling (deg F or %)	Heating (deg F or %)
Walls	130.0	0.400	90.0 %	30.0 F
Ceilings	0.0	0.420	90.0 %	10.0 F
Floors	0.0	0.570	90.0 %	10.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	41 CFM	Area	: 0.0 sqft
Heating	: 0.20 CFM/sqft =	55 CFM	Perimeter	: 0.0 ft
Typical	: 0.20 CFM/sqft =	55 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 3RD FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 3RD FL. - STAIR

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	118.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	0.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 3RD FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

<----- Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	12.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	95 sqft	Building Wt. =	M	lb/sqft
PEOPLE	: sqft/person	=	0.0	Total People	=	0
	Schedule No.	=	1	Activity Level	=	2
LIGHTING	: W/sqft	=	1.26	Total Watts	=	120
	Schedule No.	=	2	Wattage Mult.	=	1.00
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	0.00	Total Watts	=	0
	Schedule No.	=	3			
MISC. SENSIBLE:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	70.0	0.400	0.0 %	30.0 F
Ceilings	0.0	0.420	15.0 F	10.0 F
Floors	0.0	0.100	90.0 F	50.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	14 CFM	Area	: 0.0 sqft
Heating	: 0.20 CFM/sqft =	19 CFM	Perimeter	: 0.0 ft
Typical	: 0.20 CFM/sqft =	19 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 4TH FL. - RADAR RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 4TH FL. - RADAR RM.

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.560

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	0.0	0.0
E	0.0	0.0	0.0
SE	0.0	130.0	0.0
S	0.0	0.0	0.0
SW	0.0	188.0	9.0
W	0.0	0.0	0.0
NW	0.0	130.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->						
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 4TH FL. - RADAR RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

Exposure	<----- Glass Areas (sqft) ----->					
	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	3.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	275 sqft	Building Wt. =	M	lb/sqft
PEOPLE	: sqft/person	=	91.7	Total People =		3
	Schedule No.	=	8	Activity Level =		3
LIGHTING	: W/sqft	=	1.10	Total Watts =		303
	Schedule No.	=	2	Wattage Mult. =		1.00
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	12.00	Total Watts =		3,300
	Schedule No.	=	6			
MISC. SENSIBLE:	Load	=	1,000 BTU/hr	Schedule No. =		7
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No. =		1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)	Unconditioned Space Temp.			
	Area	U-Value	Cooling	Heating
	(sqft)	(BTU/hr/sqft/F)	(deg F or %)	(deg F or %)
Walls	70.0	0.420	90.0 %	30.0 F
Ceilings	0.0	0.420	90.0 %	10.0 F
Floors	0.0	0.570	90.0 %	10.0 F
INFILTRATION	GROUND ELEMENT			
Cooling	: 0.15 CFM/sqft =	41 CFM	Area :	0.0 sqft
Heating	: 0.20 CFM/sqft =	55 CFM	Perimeter :	0.0 ft
Typical	: 0.20 CFM/sqft =	55 CFM	Depth :	0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 4TH FL. - PC RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 4TH FL. - PC RM.

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	70.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	70.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 4TH FL. - PC RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

<----- Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	50 sqft	Building Wt.	=	M lb/sqft
PEOPLE	: sqft/person	=	0.0	Total People	=	0
	Schedule No.	=	1	Activity Level	=	2
LIGHTING	: W/sqft	=	1.20	Total Watts	=	60
	Schedule No.	=	2	Wattage Mult.	=	1.00
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	0.00	Total Watts	=	0
	Schedule No.	=	3			
MISC. SENSIBLE:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	0.0	0.400	110.0 %	10.0 F
Ceilings	50.0	0.270	90.0 F	30.0 F
Floors	0.0	0.270	90.0 %	40.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	8 CFM	Area	: 0.0 sqft
Heating	: 0.20 CFM/sqft =	10 CFM	Perimeter	: 0.0 ft
Typical	: 0.20 CFM/sqft =	10 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 4TH FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 4TH FL. - STAIR

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	118.0	0.0
E	0.0	0.0	0.0
SE	0.0	70.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	0.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 4TH FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

***** 4. GLASS INFORMATION (continued)

-----> Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	12.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

***** 5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	95 sqft	Building Wt. =	M	lb/sqft
PEOPLE	: sqft/person	=	0.0	Total People =		0
	Schedule No.	=	1	Activity Level =		2
LIGHTING	: W/sqft	=	1.26	Total Watts =		120
	Schedule No.	=	2	Wattage Mult. =		1.00
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	0.00	Total Watts =		0
	Schedule No.	=	3			
MISC. SENSIBLE:	Load	=	0 BTU/hr	Schedule No. =		4
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No. =		1

***** 6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	0.0	0.400	0.0 %	30.0 F
Ceilings	0.0	0.420	15.0 F	10.0 F
Floors	0.0	0.100	90.0 F	50.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	14 CFM	Area :	0.0 sqft
Heating	: 0.20 CFM/sqft =	19 CFM	Perimeter :	0.0 ft
Typical	: 0.20 CFM/sqft =	19 CFM	Depth :	0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 5TH FL. - RADIO EQ. RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 5TH FL. - RADIO EQ. RM.

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.560

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	0.0	0.0
E	0.0	0.0	0.0
SE	0.0	130.0	0.0
S	0.0	0.0	0.0
SW	0.0	188.0	0.0
W	0.0	0.0	0.0
NW	0.0	130.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 5TH FL. - RADIO EQ. RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

----- Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	12.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	275 sqft	Building Wt.	=	M lb/sqft
PEOPLE	: sqft/person	=	0.0	Total People	=	0
	Schedule No.	=	1	Activity Level	=	3
LIGHTING	: W/sqft	=	0.87	Total Watts	=	240
	Schedule No.	=	2	Wattage Mult.	=	1.00
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	10.00	Total Watts	=	2,750
	Schedule No.	=	3			
MISC. SENSIBLE:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	70.0	0.420	90.0 %	30.0 F
Ceilings	0.0	0.420	90.0 %	10.0 F
Floors	0.0	0.420	90.0 %	30.0 F
INFILTRATION		GROUND ELEMENT		
Cooling	: 0.15 CFM/sqft =	41 CFM	Area	: 0.0 sqft
Heating	: 0.20 CFM/sqft =	55 CFM	Perimeter	: 0.0 ft
Typical	: 0.20 CFM/sqft =	55 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 5TH FL. - STORAGE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 5TH FL. - STORAGE

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	70.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	70.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	

COMPLEX SPACE DESCRIPTION

Space Name : 5TH FL. - STORAGE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

<----- Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	:	Floor Area	=	50 sqft	Building Wt. =	M	lb/sqft
PEOPLE	:	sqft/person	=	0.0	Total People	=	0
	:	Schedule No.	=	1	Activity Level	=	2
LIGHTING	:	W/sqft	=	1.20	Total Watts	=	60
	:	Schedule No.	=	2	Wattage Mult.	=	1.00
	:	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	:	W/sqft	=	0.00	Total Watts	=	0
	:	Schedule No.	=	3			
MISC. SENSIBLE:	:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	:	Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	0.0	0.400	110.0 %	10.0 F
Ceilings	0.0	0.270	90.0 F	30.0 F
Floors	0.0	0.270	90.0 %	40.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	:	0.15 CFM/sqft =	8 CFM	Area : 0.0 sqft
Heating	:	0.20 CFM/sqft =	10 CFM	Perimeter : 0.0 ft
Typical	:	0.20 CFM/sqft =	10 CFM	Depth : 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 5TH FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 5TH FL. - STAIR

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	118.0	0.0
E	0.0	0.0	0.0
SE	0.0	70.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	0.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 5TH FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

Exposure	<----- Glass Areas (sqft) ----->					
	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	12.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	:	Floor Area	=	95 sqft	Building Wt. =	M	lb/sqft
PEOPLE	:	sqft/person	=	0.0	Total People	=	0
	:	Schedule No.	=	1	Activity Level	=	2
LIGHTING	:	W/sqft	=	1.26	Total Watts	=	120
	:	Schedule No.	=	2	Wattage Mult.	=	1.00
	:	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	:	W/sqft	=	0.00	Total Watts	=	0
	:	Schedule No.	=	3			
MISC. SENSIBLE:	:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	:	Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	0.0	0.420	0.0 F	30.0 F
Ceilings	0.0	0.570	0.0 F	30.0 F
Floors	0.0	0.100	90.0 F	50.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	:	0.15 CFM/sqft =	14 CFM	Area : 0.0 sqft
Heating	:	0.20 CFM/sqft =	19 CFM	Perimeter : 0.0 ft
Typical	:	0.20 CFM/sqft =	19 CFM	Depth : 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 6TH FL. - CONFERENCE RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 6TH FL. - CONFERENCE RM.

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.560

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	0.0	0.0
E	0.0	0.0	0.0
SE	0.0	130.0	0.0
S	0.0	0.0	0.0
SW	0.0	173.0	15.0
W	0.0	0.0	0.0
NW	0.0	130.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->						
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 6TH FL. - CONFERENCE RM.

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

<----- Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	12.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	:	Floor Area	=	275 sqft	Building Wt. =	M	lb/sqft
PEOPLE	:	sqft/person	=	45.8	Total People	=	6
	:	Schedule No.	=	1	Activity Level	=	2
LIGHTING	:	W/sqft	=	2.91	Total Watts	=	800
	:	Schedule No.	=	2	Wattage Mult.	=	1.20
	:	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	:	W/sqft	=	1.82	Total Watts	=	500
	:	Schedule No.	=	6			
MISC. SENSIBLE:	:	Load	=	1,000 BTU/hr	Schedule No.	=	7
MISC. LATENT	:	Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	70.0	0.420	90.0 %	30.0 F
Ceilings	0.0	0.420	90.0 %	10.0 F
Floors	0.0	0.570	90.0 %	10.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	41 CFM	Area	: 0.0 sqft
Heating	: 0.20 CFM/sqft =	55 CFM	Perimeter	: 0.0 ft
Typical	: 0.20 CFM/sqft =	55 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 6TH FL. - LATRINE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 6TH FL. - LATRINE

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	64.0	0.0
E	0.0	0.0	0.0
SE	0.0	0.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	70.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 6TH FL. - LATRINE

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

Exposure	<----- Glass Areas (sqft) ----->					
	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	6.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	50 sqft	Building Wt. =	M	lb/sqft
PEOPLE	: sqft/person	=	0.0	Total People	=	0
	Schedule No.	=	1	Activity Level	=	2
LIGHTING	: W/sqft	=	2.00	Total Watts	=	100
	Schedule No.	=	2	Wattage Mult.	=	1.00
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	0.00	Total Watts	=	0
	Schedule No.	=	3			
MISC. SENSIBLE:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	0.0	0.400	90.0 F	10.0 F
Ceilings	0.0	0.270	90.0 F	30.0 F
Floors	0.0	0.270	90.0 %	40.0 F

INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	8 CFM	Area	: 0.0 sqft
Heating	: 0.20 CFM/sqft =	10 CFM	Perimeter	: 0.0 ft
Typical	: 0.20 CFM/sqft =	10 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 6TH FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 6TH FL. - STAIR

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.570

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	115.0	15.0
E	0.0	0.0	0.0
SE	0.0	70.0	0.0
S	0.0	0.0	0.0
SW	0.0	0.0	0.0
W	0.0	0.0	0.0
NW	0.0	0.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	0.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->						
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)
Shade 1	8.0	4.0	0.0	0.0	0.0	0.0
Shade 2	8.0	4.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 6TH FL. - STAIR

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

<----- Glass Areas (sqft) ----->						
Exposure	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	0.0	0	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	0	0.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	0	0.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	0	0.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	95 sqft	Building Wt.	=	M lb/sqft
PEOPLE	: sqft/person	=	0.0	Total People	=	0
	Schedule No.	=	1	Activity Level	=	2
LIGHTING	: W/sqft	=	0.63	Total Watts	=	60
	Schedule No.	=	2	Wattage Mult.	=	1.00
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	0.00	Total Watts	=	0
	Schedule No.	=	3			
MISC. SENSIBLE:	Load	=	0 BTU/hr	Schedule No.	=	4
MISC. LATENT	: Load	=	0 BTU/hr	Schedule No.	=	1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	0.0	0.420	0.0 F	30.0 F
Ceilings	0.0	0.570	0.0 F	30.0 F
Floors	0.0	0.100	90.0 F	50.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	14 CFM	Area	: 0.0 sqft
Heating	: 0.20 CFM/sqft =	19 CFM	Perimeter	: 0.0 ft
Typical	: 0.20 CFM/sqft =	19 CFM	Depth	: 0.0 ft

COMPLEX SPACE DESCRIPTION

Space Name : 7TH FL. - OBSERVATION

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

1. SPACE NAME = 7TH FL. - OBSERVATION

2. WALL INFORMATION (Number of Wall Types = 3)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)
Wall Type 1	51	M	0.400
Wall Type 2	L	D	0.170
Wall Type 3	L	D	0.560

<----- Net Wall Areas (sqft) ----->			
Exposure	Wall Type 1	Wall Type 2	Wall Type 3
NE	0.0	100.0	0.0
E	0.0	0.0	0.0
SE	0.0	100.0	0.0
S	0.0	0.0	0.0
SW	0.0	100.0	15.0
W	0.0	0.0	0.0
NW	0.0	100.0	0.0
N	0.0	0.0	0.0

3. ROOF INFORMATION (Number of Roof Types = 1)

	Weight (lb/sqft)	Ext Color (D,M,L)	U-Value (BTU/hr/sqft/F)	Area (sqft)
Roof 1	M	M	0.220	676.0

4. GLASS INFORMATION (Number of Glass Types = 2)

	U-Value (BTU/hr/sqft/F)	Glass Factor	Internal Shades
Glass Type 1	1.100	1.00	N
Glass Type 2	0.580	0.90	N

<----- External Shading Information ----->							
Window Height (ft)	Window Width (ft)	Reveal Depth (in)	Overhang Height (in)	Overhang Extension (in)	Fin Separation (in)	Fin Exten. (in)	
Shade 1	6.0	20.0	0.0	0.0	2.0	0.0	0.0
Shade 2	6.0	4.0	0.0	0.0	0.0	0.0	0.0
Shade 3	8.0	4.0	0.0	0.0	0.0	0.0	0.0

COMPLEX SPACE DESCRIPTION

Space Name : 7TH FL. - OBSERVATION

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2 of 2

4. GLASS INFORMATION (continued)

Exposure	Glass Areas (sqft)					
	Type 1		Type 2		Type 3	
	Area	Shade	Area	Shade	Area	Shade
NE	0.0	0	120.0	1	NA	NA
E	0.0	0	0.0	0	NA	NA
SE	0.0	1	120.0	0	NA	NA
S	0.0	0	0.0	0	NA	NA
SW	0.0	1	120.0	0	NA	NA
W	0.0	0	0.0	0	NA	NA
NW	0.0	1	120.0	0	NA	NA
N	0.0	0	0.0	0	NA	NA
H	0.0	0	0.0	0	NA	NA

5. INTERNAL LOADS

SPACE DATA	: Floor Area	=	400 sqft	Building Wt. =	M	lb/sqft
PEOPLE	: sqft/person	=	80.0	Total People =		5
	Schedule No.	=	1	Activity Level =		3
LIGHTING	: W/sqft	=	0.00	Total Watts =		0
	Schedule No.	=	2	Wattage Mult. =		1.20
	Fixture Type	=	3 Free-hanging			
OTHER ELECTRIC:	W/sqft	=	4.40	Total Watts =		1,760
	Schedule No.	=	6			
MISC. SENSIBLE: Load		=	1,000 BTU/hr	Schedule No. =		7
MISC. LATENT : Load		=	0 BTU/hr	Schedule No. =		1

6. PARTITIONS, INFILTRATION, GROUND

PARTITIONS (Next to Unconditioned Spaces)			Unconditioned Space Temp.	
Area	U-Value		Cooling	Heating
(sqft)	(BTU/hr/sqft/F)		(deg F or %)	(deg F or %)
Walls	0.0	0.420	90.0 %	30.0 F
Ceilings	0.0	0.420	90.0 %	10.0 F
Floors	0.0	0.570	90.0 %	10.0 F
INFILTRATION			GROUND ELEMENT	
Cooling	: 0.15 CFM/sqft =	60 CFM	Area	: 0.0 sqft
Heating	: 0.28 CFM/sqft =	112 CFM	Perimeter	: 0.0 ft
Typical	: 0.28 CFM/sqft =	112 CFM	Depth	: 0.0 ft

AIR SYSTEM DESCRIPTION

Name : #1359 F1 2 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 F1 2 -COOLING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 1 Cooling Only

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	35.0 F	CLOSED
Unoccupied	75.0 F	35.0 F	CLOSED

Weekday : Occupied Period Begins at 6 ; Duration = 17 hrs
Saturday : Occupied Period Begins at 7 ; Duration = 11 hrs
Sunday : Occupied Period Begins at 7 ; Duration = 11 hrs
Design Day : Occupied Period Begins at 6 ; Duration = 17 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 600.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 CFM
Minimum ventilation flow rate = 0.00 CFM
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 2 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.80 in wg
Efficiency = 54 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : #1359 F1 3 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 F1 3 -COOLING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 1 Cooling Only

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	35.0 F	CLOSED
Unoccupied	75.0 F	35.0 F	CLOSED

Weekday : Occupied Period Begins at 6 ; Duration = 17 hrs
Saturday : Occupied Period Begins at 7 ; Duration = 11 hrs
Sunday : Occupied Period Begins at 7 ; Duration = 11 hrs
Design Day : Occupied Period Begins at 6 ; Duration = 17 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 600.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 CFM
Minimum ventilation flow rate = 0.00 CFM
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 3 -COOLING

04-27-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C

Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.80 in wg
Efficiency = 54 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050

Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 3 -COOLING

04-27-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C

Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved

Static = 0.80 in wg

Efficiency = 54 %

Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050

Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 4 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 4 -COOLING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 1 Cooling Only

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	35.0 F	CLOSED
Unoccupied	75.0 F	35.0 F	CLOSED
Weekday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at 8 ; Duration = 10 hrs		
Sunday	: Occupied Period Begins at 8 ; Duration = 10 hrs		
Design Day	: Occupied Period Begins at 0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 600.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 CFM
Minimum ventilation flow rate = 0.00 CFM
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 4 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.80 in wg
Efficiency = 54 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 5 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 5 -COOLING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 1 Cooling Only

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	68.0 F	CLOSED
Unoccupied	75.0 F	68.0 F	CLOSED
Weekday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at 8 ; Duration = 10 hrs		
Sunday	: Occupied Period Begins at 8 ; Duration = 10 hrs		
Design Day	: Occupied Period Begins at 0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 800.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 CFM
Minimum ventilation flow rate = 0.00 CFM
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 5 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.80 in wg
Efficiency = 54 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050

Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 6 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 6 -COOLING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 3 Cooling & Heating
Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	68.0 F	CLOSED
Unoccupied	75.0 F	68.0 F	CLOSED

Weekday	: Occupied Period Begins at 8 ; Duration = 10 hrs		
Saturday	: Occupied Period Begins at 7 ; Duration = 0 hrs		
Sunday	: Occupied Period Begins at 7 ; Duration = 0 hrs		
Design Day	: Occupied Period Begins at 8 ; Duration = 10 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1000.00 CFM
Heating supply temperature = 110.0 F
Fan operation for heating = 1 Continuous

VENTILATION AIR

Nominal ventilation flow rate = 0.00 CFM
Minimum ventilation flow rate = 0.00 CFM
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 6 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.80 in wg
Efficiency = 54 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 2 Skin Heating Units
SKIN HEATING UNITS
Heat source = 1 Baseboard Heaters
Skin heating trip temperature = 0.0 F

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 7 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 7 -COOLING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 1 Cooling Only

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	35.0 F	OPEN
Unoccupied	75.0 F	35.0 F	OPEN

Weekday : Occupied Period Begins at 0 ; Duration = 24 hrs
Saturday : Occupied Period Begins at 8 ; Duration = 10 hrs
Sunday : Occupied Period Begins at 8 ; Duration = 10 hrs
Design Day : Occupied Period Begins at 0 ; Duration = 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 2000.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 175.00 CFM
Minimum ventilation flow rate = 175.00 CFM
Damper leak rate = 5 % of vent air

RETURN AIR

Zone exhaust air flow rate = 100.00 % of vent. air
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 7 -COOLING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 7:Backward inclined or air foil
Static = 1.00 in wg
Efficiency = 54 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 1 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 1 -HEATING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 2 Space Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	110.0 F	68.0 F	CLOSED
Unoccupied	N	68.0 F	CLOSED

Weekday	: Occupied Period Begins at	0 ; Duration	= 24 hrs
Saturday	: Occupied Period Begins at	0 ; Duration	= 24 hrs
Sunday	: Occupied Period Begins at	0 ; Duration	= 24 hrs
Design Day	: Occupied Period Begins at	0 ; Duration	= 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 5 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 1 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 3 Space Heating Units
SPACE HEATING UNITS
Heat source = 1 Baseboard Heaters

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 2 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 2 -HEATING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 2 Space Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	110.0 F	68.0 F	CLOSED
Unoccupied	N	68.0 F	CLOSED

Weekday : Occupied Period Begins at 0 ; Duration = 24 hrs
Saturday : Occupied Period Begins at 0 ; Duration = 24 hrs
Sunday : Occupied Period Begins at 0 ; Duration = 24 hrs
Design Day : Occupied Period Begins at 0 ; Duration = 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 5 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 2 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 3 Space Heating Units
SPACE HEATING UNITS
Heat source = 1 Baseboard Heaters

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 3 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 3 -HEATING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 2 Space Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	110.0 F	68.0 F	CLOSED
Unoccupied	N	68.0 F	CLOSED

Weekday	: Occupied Period Begins at	0 ; Duration	= 24 hrs
Saturday	: Occupied Period Begins at	0 ; Duration	= 24 hrs
Sunday	: Occupied Period Begins at	0 ; Duration	= 24 hrs
Design Day	: Occupied Period Begins at	0 ; Duration	= 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 5 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 3 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 3 Space Heating Units
SPACE HEATING UNITS
Heat source = 1 Baseboard Heaters

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 4 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 4 -HEATING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 2 Space Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	110.0 F	68.0 F	CLOSED
Unoccupied	N	68.0 F	CLOSED

Weekday	: Occupied Period Begins at	0 ; Duration	= 24 hrs
Saturday	: Occupied Period Begins at	0 ; Duration	= 24 hrs
Sunday	: Occupied Period Begins at	0 ; Duration	= 24 hrs
Design Day	: Occupied Period Begins at	0 ; Duration	= 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 5 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 4 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 3 Space Heating Units

SPACE HEATING UNITS

Heat source = 1 Baseboard Heaters

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 5 -HEATING

04-27-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C

Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 5 -HEATING
 System Class = Constant Volume
 System Type = (SZCV) Single Zone Constant Volume
 Operation Type = 2 Heating Only
 Type of Heating = 2 Space Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	110.0 F	68.0 F	CLOSED
Unoccupied	N	68.0 F	CLOSED

Weekday : Occupied Period Begins at 0 ; Duration = 24 hrs
 Saturday : Occupied Period Begins at 0 ; Duration = 24 hrs
 Sunday : Occupied Period Begins at 0 ; Duration = 24 hrs
 Design Day : Occupied Period Begins at 0 ; Duration = 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
 Minimum ventilation flow rate = 0.00 % of supply air
 Damper leak rate = 5 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
 Zone exhaust fan power = 0.0 kW
 Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 5 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

***** 5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

***** 6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

***** 7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 3 Space Heating Units
SPACE HEATING UNITS
Heat source = 1 Baseboard Heaters

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 6 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 6 -HEATING
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 2 Space Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	110.0 F	68.0 F	CLOSED
Unoccupied	N	68.0 F	CLOSED
Weekday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Sunday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Design Day	: Occupied Period Begins at 0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 5 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 6 -HEATING
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 3 Space Heating Units
SPACE HEATING UNITS
Heat source = 1 Baseboard Heaters

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 2-OFFICE HEAT
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 2-OFFICE HEAT
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 2 Space Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period		Thermostat Cooling	Setpoints Heating	Ventilation Dampers
Occupied		110.0 F	80.0 F	CLOSED
Unoccupied		N	80.0 F	CLOSED
<hr/>				
Weekday	: Occupied Period Begins at	6 ; Duration = 17 hrs		
Saturday	: Occupied Period Begins at	7 ; Duration = 11 hrs		
Sunday	: Occupied Period Begins at	7 ; Duration = 11 hrs		
Design Day	: Occupied Period Begins at	6 ; Duration = 17 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 CFM

Minimum ventilation flow rate = 0.00 CFM

Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM

Zone exhaust fan power = 0.0 kW

Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 2-OFFICE HEAT
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 3 Space Heating Units
SPACE HEATING UNITS
Heat source = 1 Baseboard Heaters

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 3-OFFICE HEAT
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 3-OFFICE HEAT
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 2 Space Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period		Thermostat Cooling	Setpoints Heating	Ventilation Dampers
Occupied		110.0 F	80.0 F	CLOSED
Unoccupied		N	80.0 F	CLOSED
<hr/>				
Weekday	: Occupied Period Begins at	6	; Duration	= 17 hrs
Saturday	: Occupied Period Begins at	7	; Duration	= 11 hrs
Sunday	: Occupied Period Begins at	7	; Duration	= 11 hrs
Design Day	: Occupied Period Begins at	6	; Duration	= 17 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 CFM

Minimum ventilation flow rate = 0.00 CFM

Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM

Zone exhaust fan power = 0.0 kW

Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 3-OFFICE HEAT
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 3 Space Heating Units
SPACE HEATING UNITS
Heat source = 1 Baseboard Heaters

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 4-OFFICE HEAT
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 4-OFFICE HEAT
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 2 Space Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period		Thermostat Setpoints		Ventilation Dampers
		Cooling	Heating	
Occupied		110.0 F	80.0 F	CLOSED
Unoccupied		N	80.0 F	CLOSED
Weekday	: Occupied Period Begins at	0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at	8 ; Duration = 10 hrs		
Sunday	: Occupied Period Begins at	8 ; Duration = 10 hrs		
Design Day	: Occupied Period Begins at	0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM

VENTILATION AIR

Nominal ventilation flow rate = 0.00 CFM

Minimum ventilation flow rate = 0.00 CFM

Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM

Zone exhaust fan power = 0.0 kW

Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 4-OFFICE HEAT
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 3 Space Heating Units
SPACE HEATING UNITS
Heat source = 1 Baseboard Heaters

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 7 - HEAT

04-27-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C

Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 Fl 7 - HEAT
 System Class = Constant Volume
 System Type = (SZCV) Single Zone Constant Volume
 Operation Type = 2 Heating Only
 Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	110.0 F	68.0 F	OPEN
Unoccupied	110.0 F	68.0 F	OPEN
Weekday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at 8 ; Duration = 10 hrs		
Sunday	: Occupied Period Begins at 8 ; Duration = 10 hrs		
Design Day	: Occupied Period Begins at 0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 2000.00 CFM
 Heating supply temperature = 110.0 F
 Fan operation for heating = 1 Continuous

VENTILATION AIR

Nominal ventilation flow rate = 175.00 CFM
 Minimum ventilation flow rate = 175.00 CFM
 Damper leak rate = 5 % of vent air

RETURN AIR

Zone exhaust air flow rate = 100.00 % of vent. air
 Zone exhaust fan power = 0.0 kW
 Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 Fl 7 - HEAT
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 7:Backward inclined or air foil
Static = 1.00 in wg
Efficiency = 54 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 2 Skin Heating Units

SKIN HEATING UNITS

Heat source = 1 Baseboard Heaters
Skin heating trip temperature = 0.0 F

AIR SYSTEM DESCRIPTION

Name : #1359 - LIGHTING/MISC
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = #1359 - LIGHTING/MISC
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 3 Cooling & Heating
Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	110.0 F	35.0 F	CLOSED
Unoccupied	N	35.0 F	CLOSED

Weekday	: Occupied Period Begins at	0 ; Duration	= 0 hrs
Saturday	: Occupied Period Begins at	0 ; Duration	= 0 hrs
Sunday	: Occupied Period Begins at	0 ; Duration	= 0 hrs
Design Day	: Occupied Period Begins at	0 ; Duration	= 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air flow rate = 1.00 CFM
Heating supply temperature = 110.0 F
Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 0.00 CFM
Minimum ventilation flow rate = 0.00 CFM
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : #1359 - LIGHTING/MISC
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.01 in wg
Efficiency = 100 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 1 Not Used

AIR SYSTEM SPACE LIST

Name : #1359 - LIGHTING/MISC
Carrier Hourly Analysis Program
Prepared By : E A C

04-27-91
6100190202
Page 1

Space Name Qty. | Space Name Qty.

TABLE 1. SPACES IN ZONE 1

1 GROUND FL. - EQUIP. RM.	x 1	10 4TH FL. - PC RM.	x 1
2 GROUND FL. - STORAGE RM.	x 1	11 4TH FL. - STAIR	x 1
3 GROUND FL. - STAIR	x 1	12 5TH FL. - RADIO EQ. RM.	x 1
4 2ND FL. - OFFICE	x 1	13 5TH FL. - STORAGE	x 1
5 2ND FL. - LATRINE	x 1	14 5TH FL. - STAIR	x 1
6 2ND FL. - STAIR	x 1	15 6TH FL. - CONFERENCE RM.	x 1
7 3RD FL. - OFFICE	x 1	16 6TH FL. - LATRINE	x 1
8 3RD FL. - STAIR	x 1	17 6TH FL. - STAIR	x 1
9 4TH FL. - RADAR RM.	x 1	18 7TH FL. - OBSERVATION	x 1

PLANT DESCRIPTIONS

Plant : #1359 Chiller

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Individual Plants
Name = #1359 Chiller
Cooling Plant Type = Air Cooled Reciprocating
Heating Plant Type = User Defined

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
#1359 F1 2 -COOLING	1	#1359 F1 3 -COOLING	1
#1359 F1 4 -COOLING	1	#1359 F1 5 -COOLING	1
#1359 F1 6 -COOLING	1	#1359 F1 7 -COOLING	1

3a COOLING PLANT DATA (Air Cooled Reciprocating)

Estimated maximum cooling coil load = 10.96 Ton
Is an electronic expansion valve used ? Y
Capacity at 95.0 F outdoor air = 10.60 Ton
Input power rate at 95.0 F outdoor air = 1.170 kW/Ton
Is chilled water reset used ? N
Design leaving water temperature = 44.0 F
Is hot gas bypass used ? N

3b HEATING PLANT DATA (User Defined)

Estimated maximum heating coil load = 9.17 MBH
Fuel or power source = Electrical
Nominal plant capacity = 10.0 MBH
Nominal plant efficiency = 100 %
Type of heating = Direct

PART LOAD PERFORMANCE

% Load	Eff. (%)	% Load	Eff. (%)	% Load	Eff. (%)
90 -----	75	60 -----	75	30 -----	75
80 -----	75	50 -----	75	20 -----	75
70 -----	75	40 -----	75	10 -----	75

4 PUMP SYSTEM DATA

Chilled water pumping system head = 42.50 ft wg
Chilled water pumping system delta T = 10.00 F

PLANT DESCRIPTIONS

Plant : #1359 HEATING

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Individual Plants
Name = #1359 HEATING
Cooling Plant Type = User Defined
Heating Plant Type = Remote Source Heating

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
#1359 F1 1 -HEATING	1	#1359 F1 2 -HEATING	1
#1359 F1 3 -HEATING	1	#1359 F1 4 -HEATING	1
#1359 F1 5 -HEATING	1	#1359 F1 6 -HEATING	1
#1359 F1 2-OFFICE HEAT	1	#1359 F1 3-OFFICE HEAT	1
#1359 F1 4-OFFICE HEAT	1	#1359 F1 7 - HEAT	1

3a COOLING PLANT DATA (User Defined)

Estimated maximum cooling coil load = 0.00 Ton
Nominal capacity = 0.00 Ton
Nominal input power rate = 0.000 kW/Ton
Type of cooling = DX
Condenser type = Air Cooled

PART LOAD PERFORMANCE

% Load	% Power	% Load	% Power	% Load	% Power
90 -----	100	60 -----	100	30 -----	100
80 -----	100	50 -----	100	20 -----	100
70 -----	100	40 -----	100	10 -----	100

3b HEATING PLANT DATA (Remote Source Heating)

Estimated maximum heating coil load = 151.00 MBH
(No inputs required)

4 PUMP SYSTEM DATA

Hot water pumping system head = 0.00 ft wg
Hot water pumping system delta T = 0.00 F

ELECTRIC RATE DATA

Electric Rate : FED INSTALL RATE NO MIN DEMAND

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1

1. NAME, CURRENCY & TYPE

NAME

Name of rate schedule = FED INSTALL RATE NO MIN DEMAND

CURRENCY

Currency name = Dollars

Currency symbol = \$

TYPE

Type of rate schedule = 2 Complex

Frequency of billing = 1 Monthly

Is seasonal scheduling used ? Y

Is time-of-day scheduling used ? Y

2. BASIC INFORMATION

ENERGY CHARGES

Type of energy charge = 1 Declining Block

Number of steps = 1

ENERGY CHARGES - 2nd METER

Is a second meter used ? N

DEMAND CHARGES

Is a demand charge used ? Y

Number of steps = 1

DEMAND DETERMINATION (Which are used?)

Ratchet clause ? N

Trailing window clause ? Y

Minimum kW clause ? N

Power factor multiplier clause ? Y

Power multiplier clause ? N

MISCELLANEOUS CHARGES

Fixed charge = 0.00 \$

Tax rate = 0.00 %

ELECTRIC RATE DATA

Electric Rate : FED INSTALL RATE NO MIN DEMAND

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 2

3. SCHEDULING DATA

SEASONAL SCHEDULING

Month ->	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec
Schedule ->	W	W	W	W	W	S	S	S	S	W	W	W

S = Summer M = Mid-season W = Winter

TIME-OF-DAY SCHEDULING

Season	Day	0	1	2	3	4	5	6	7	8	9	0	1	2	3	4	5	6	7	8	9	0	1	2	3
Summer	Weekday	N	N	N	N	N	N	N	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	N
Summer	Saturday	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Summer	Sunday	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Winter	Weekday	N	N	N	N	N	N	N	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	P	N
Winter	Saturday	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Winter	Sunday	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

P = Peak M = Mid-Peak N = Normal O = Off-Peak

4. ENERGY CHARGES

Step	Season	Period	Block Size	Rate
1	All	All	9999999 kWh	0.02072 (\$/kWh)

5. ENERGY CHARGES - 2nd METER

(No inputs required)

6. DEMAND CHARGES

Step	Season	Period	Block Size (kW)	Rate (\$/kW)
1	All	All	999999	10.78000

ELECTRIC RATE DATA

Electric Rate : FED INSTALL RATE NO MIN DEMAND

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 3

7. DEMAND DETERMINATION

RATCHET CLAUSE

(Not used)

TRAILING WINDOW CLAUSE

Trailing window = 11 months

Trailing window multiplier = 90 %

MINIMUM kW CLAUSE

(Not used)

POWER FACTOR MULTIPLIER CLAUSE

Power factor multiplier = 99.97 %

POWER MULTIPLIER CLAUSE

(Not used)

FUEL RATE DATA

Fuel Rate : REMOTE 04-27-91
 Prepared By : E A C 6100190202
 Carrier Hourly Analysis Program Page 1 of 1

1. FUEL RATE DATA

NAME
 Name of rate schedule = REMOTE
 CURRENCY
 Currency name = Dollars
 Currency symbol = \$
 BASIC INFORMATION
 Units of measurement = MBTU
 Conversion factor = 1000.00000 kBTU/MBTU
 Type of rate schedule = 1 Simple
 Flat rate charge = 9.97000 \$/MBTU

BUILDING DESCRIPTION

Building : #1359 04-27-91
 Prepared By: E A C 6100190202
 Carrier Hourly Analysis Program Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = #1359

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW
 Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? N

OTHER INPUTS

Additional building floor area = 0.0 sqft
 Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
#1359 Chiller	1	#1359 HEATING	1

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	1	FED INSTALL RATE NO MIN DEMAND	\$
Natural Gas	1	REMOTE	\$
Fuel Oil	1	REMOTE	\$
Propane	1	REMOTE	\$
Remote Source Heating	1	REMOTE	\$
Remote Source Cooling	1	REMOTE	\$

ENERGY BUDGET <A>

Building : #1359 - BASELINE ENERGY

07-29-91

Site : FT. BELVOIR, VIRGINIA

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	260,988	64.521
Heating Loads *	155,483	38.438

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	32,794	8.107	32,794	8.107
Cooling Plants	53,681	13.271	53,681	13.271
Heating Plants	156,411	38.668	156,411	38.668
Pumps	6,478	1.602	6,478	1.602
>> HVAC Total	249,364	61.647	249,364	61.647
Lights	75,790	18.737	75,790	18.737
Other Electric	264,784	65.460	264,784	65.460
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	340,574	84.196	340,574	84.196
>> GRAND TOTAL	589,938	145.844	589,938	145.844

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,045 sqft
 Conditioned floor area = 4,045 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

/359-85

ENERGY BUDGET <A>

Building : #1359 LIGHTING/MISC
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

07-29-91
 6100190202

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	0	0.000

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	0	0.000	0	0.000
Pumps	0	0.000	0	0.000
>> HVAC Total	0	0.000	0	0.000
Lights	59,470	20.721	59,470	20.721
Other Electric	160,966	56.086	160,966	56.086
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	220,436	76.807	220,436	76.807
>> GRAND TOTAL	220,436	76.807	220,436	76.807

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 2,870 sqft
 Conditioned floor area = 2,870 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ELECTRIC POWER COSTS

Building : #1359 - BASELINE ENERGY

07-29-91

Site : FT. BELVOIR, VIRGINIA

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Demand Charges	Fixed Charges	Taxes	Totals
Jan	202	317	0	0	519
Feb	182	317	0	0	499
Mar	204	317	0	0	521
Apr	205	317	0	0	522
May	231	317	0	0	548
June	249	332	0	0	581
July	272	352	0	0	624
Aug	270	343	0	0	613
Sept	227	317	0	0	544
Oct	217	317	0	0	534
Nov	196	317	0	0	513
Dec	199	317	0	0	515
Tot.	2,655	3,879	0	0	6,535

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (kWh)	Effective Rate (\$/kWh)
Jan	519	9,772	0.05315
Feb	499	8,807	0.05670
Mar	521	9,845	0.05291
Apr	522	9,888	0.05277
May	548	11,155	0.04913
June	581	12,021	0.04835
July	624	13,141	0.04752
Aug	613	13,053	0.04699
Sept	544	10,951	0.04966
Oct	534	10,482	0.05096
Nov	513	9,450	0.05426
Dec	515	9,582	0.05379
Tot.	6,535	128,147	0.05099

REMOTE HEATING COSTS

Building : #1359-BASELINE-REMOTE(\$)
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

 TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Fixed Charges	Taxes	Total Charges
Jan	369	0	0	369
Feb	283	0	0	283
Mar	186	0	0	186
Apr	67	0	0	67
May	24	0	0	24
June	11	0	0	11
July	8	0	0	8
Aug	9	0	0	9
Sept	15	0	0	15
Oct	55	0	0	55
Nov	170	0	0	170
Dec	325	0	0	325
Tot.	1,522	0	0	1,522

 TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (MBTU)	Effective Rate (\$/MBTU)
Jan	369	37	9.97000
Feb	283	28	9.97000
Mar	186	19	9.97000
Apr	67	7	9.97000
May	24	2	9.97000
June	11	1	9.97000
July	8	1	9.97000
Aug	9	1	9.97000
Sept	15	2	9.97000
Oct	55	6	9.97000
Nov	170	17	9.97000
Dec	325	33	9.97000
Tot.	1,522	153	9.97000

BUILDING 1359

ECO #1 - Radiator Control Valves

Description - Radiators and unit heaters have steam flowing through them even when the thermostat set point is met, thus overheating the respective spaces. Control valves will stop the flow of steam when the thermostat set point is reached.

Energy Saved	= 25 MBTU/year
Cost	= \$945 (incl. SIOH)
SIR	= 3.3

ENERGY BUDGET <A>

Building : #1359-Control Valves
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

07-29-91
 6100190202

Page 1 of 1

 TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	260,988	64.521
Heating Loads *	131,054	32.399

 TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	32,780	8.104	32,780	8.104
Cooling Plants	53,681	13.271	53,681	13.271
Heating Plants	131,981	32.628	131,981	32.628
Pumps	6,478	1.602	6,478	1.602
>> HVAC Total	224,921	55.605	224,921	55.605
Lights	75,790	18.737	75,790	18.737
Other Electric	264,784	65.460	264,784	65.460
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	340,574	84.196	340,574	84.196
>> GRAND TOTAL	565,495	139.801	565,495	139.801

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,045 sqft
 Conditioned floor area = 4,045 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ELECTRIC POWER COSTS

Building : #1359-Control Valves

07-29-91

Site : FT. BELVOIR, VIRGINIA

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Demand Charges	Fixed Charges	Taxes	Totals
Jan	202	317	0	0	519
Feb	182	317	0	0	499
Mar	204	317	0	0	521
Apr	205	317	0	0	522
May	231	317	0	0	548
June	249	332	0	0	581
July	272	352	0	0	624
Aug	270	343	0	0	613
Sept	227	317	0	0	544
Oct	217	317	0	0	534
Nov	196	317	0	0	513
Dec	199	317	0	0	515
Tot.	2,655	3,879	0	0	6,535

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (kWh)	Effective Rate (\$/kWh)
Jan	519	9,772	0.05315
Feb	499	8,807	0.05670
Mar	521	9,844	0.05291
Apr	522	9,887	0.05277
May	548	11,155	0.04913
June	581	12,021	0.04835
July	624	13,141	0.04752
Aug	613	13,053	0.04699
Sept	544	10,950	0.04966
Oct	534	10,481	0.05096
Nov	513	9,450	0.05426
Dec	515	9,582	0.05379
Tot.	6,535	128,143	0.05099

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Control Tower
Building 1359
Fort Belvoir, VA

By: Engineering Applications Consultants

ECO: Install thermostatic radiator control valves

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install valves	4	each	\$10	\$40	\$94	\$376	\$416
Remove exist. manual valve	4	each	\$30	\$120	---	---	\$120
Install fittings	8	each	\$15	\$120	\$1	\$8	\$128
SUB-TOTAL:				\$280		\$384	\$664
labor Markup: 21%				\$59		---	\$59
Taxes: 4.5%				---		\$17	\$17
SUB-TOTAL:				\$339		\$401	\$740
Overhead: 10%				\$34		\$40	\$74
SUB-TOTAL:				\$373		\$441	\$814
Profit: 10%				\$37		\$44	\$81
TOTAL:				\$410		\$486	\$896

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Radiator Control Val
 Prepared By : E A C, PC BURKE, VA.
 E20-II Advanced Economic Analysis Program
 LCCID - based (version 1, level 35).

09-26-91
 60901891.00
 Page 1 of 2

STUDY IDENTIFICATION BLOCK

Project Title : ESOS
 Installation Name : FORT BELVOIR, BLDG 1359
 Project Number : DACA-31-89-C-0198
 Fiscal Year : 1991
 Name of Analyst : EAC

KEY STUDY DATES

ECIP Economic Life : 15 (years)

INVESTMENT COST SUMMARY

Construction cost	\$	896
SIOH costs	\$	49
Design costs	\$	54
Energy credit calc	\$	899
Salvage value cost	-\$	0
Total investment cost	\$	899

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	0	0	8.78	0
DIST	0.00	0	0	12.34	0
RESID	9.97	25	244	12.05	2943
NAT G	0.00	0	0	12.48	0
COAL	0.00	0	0	10.01	0
TOTAL		25	244		\$ 2943

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
------	----------------------	--------------------	-----------------------

No cost items.

Total discounted savings(+) / costs(-) \$ 0

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Radiator Control Val
 Prepared By : E A C, PC BURKE, VA.
 E20-II Advanced Economic Analysis Program
 LCCID - based (version 1, level 35).

09-26-91
 60901891.00
 Page 2 of 2

 NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	---------------------	------	-----------------	--------------------

No cost items.

Total discounted savings(+) / costs(-)			\$	0
--	--	--	----	---

 DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings			\$	0
Non-energy one-time savings			\$	0
Total non-energy savings			\$	0

 PROJECT QUALIFICATION TESTS

Project non-energy qualification test.

Energy savings calc			\$	971
Non-energy qualification not applicable.				
First year Dollar savings			\$	244
Total net discounted savings			\$	2943
Discounted savings ratio				3.27
Simple payback period (years)				3.68

BUILDING 1359

ECO #2 - Ceiling Insulation

Description - The existing heat loss/heat gain through the roof/ceiling assembly will be reduced by installing additional R-19 insulation, improving the U-value from 0.22 to 0.0425 BTU/hr.- Sq. Ft. - °F.

Energy Saved	= 9 MBTU/year
Cost	= \$530 (incl. SIOH)
SIR	= 3.2

ENERGY BUDGET <A>

Building : #1359-Ceiling Insulation
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

07-29-91
 6100190202

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	257,283	63.605
Heating Loads *	124,375	30.748

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	31,920	7.891	31,920	7.891
Cooling Plants	52,719	13.033	52,719	13.033
Heating Plants	125,302	30.977	125,302	30.977
Pumps	6,478	1.602	6,478	1.602
>> HVAC Total	216,420	53.503	216,420	53.503
Lights	75,790	18.737	75,790	18.737
Other Electric	264,784	65.460	264,784	65.460
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	340,574	84.196	340,574	84.196
>> GRAND TOTAL	556,994	137.699	556,994	137.699

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency = 100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,045 sqft
 Conditioned floor area = 4,045 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

1359-96

ELECTRIC POWER COSTS

Building : #1359-Ceiling Insulation
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

07-29-91
 6100190202

Page 1 of 1

 TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Demand Charges	Fixed Charges	Taxes	Totals
Jan	202	314	0	0	516
Feb	182	314	0	0	496
Mar	204	314	0	0	518
Apr	205	314	0	0	519
May	230	314	0	0	545
June	247	330	0	0	577
July	269	349	0	0	619
Aug	268	341	0	0	609
Sept	226	314	0	0	540
Oct	217	314	0	0	531
Nov	196	314	0	0	510
Dec	198	314	0	0	512
Tot.	2,644	3,848	0	0	6,492

 TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (kWh)	Effective Rate (\$/kWh)
Jan	516	9,748	0.05296
Feb	496	8,786	0.05649
Mar	518	9,843	0.05265
Apr	519	9,877	0.05254
May	545	11,113	0.04900
June	577	11,916	0.04839
July	619	13,000	0.04758
Aug	609	12,939	0.04704
Sept	540	10,904	0.04954
Oct	531	10,478	0.05071
Nov	510	9,447	0.05399
Dec	512	9,558	0.05360
Tot.	6,492	127,609	0.05087

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Control Tower
Building 1359
Fort Belvoir, VA

By: Engineering Applications Consultants

ECO: Add insulation above drop ceiling

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install R-19 insulation	676	sq. ft.	\$0.17	\$115	\$0.39	\$264	\$379
SUB-TOTAL:				\$115		\$264	\$379
labor Markup: 21%				\$24		---	\$24
Taxes: 4.5%				---		\$12	\$12
SUB-TOTAL:				\$139		\$276	\$415
Overhead: 10%				\$14		\$28	\$41
SUB-TOTAL:				\$153		\$303	\$456
Profit: 10%				\$15		\$30	\$46
TOTAL:				\$168		\$333	\$502

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Ceiling Insulation

09-26-91

Prepared By : E A C, PC BURKE, VA.

60901891.00

E20-II Advanced Economic Analysis Program

Page 1 of 2

LCCID - based (version 1, level 35).

STUDY IDENTIFICATION BLOCK

Project Title : ESOS
 Installation Name : FORT BELVOIR, BLDG 1359
 Project Number : DACA-31-89-C-0198
 Fiscal Year : 1991
 Name of Analyst : EAC

KEY STUDY DATES

ECIP Economic Life : 25 (years)

INVESTMENT COST SUMMARY

Construction cost	\$	502
SIOH costs	\$	28
Design costs	\$	30
Energy credit calc	\$	504
Salvage value cost	-\$	0
Total investment cost	\$	504

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	2	12	11.37	131
DIST	0.00	0	0	17.06	0
RESID	9.97	7	66	16.85	1109
NAT G	0.00	0	0	17.52	0
COAL	0.00	0	0	13.34	0
TOTAL		9	77		\$ 1240

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Demand Charges	31	11.65	361
Total discounted savings(+) / costs(-)			\$ 361

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Ceiling Insulation
 Prepared By : E A C, PC BURKE, VA.
 E20-II Advanced Economic Analysis Program
 LCCID - based (version 1, level 35).

09-26-91
 60901891.00
 Page 2 of 2

 NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
No cost items.				
Total discounted savings(+) / costs(-)				\$ 0

 DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings				\$ 361
Non-energy one-time savings				\$ 0
Total non-energy savings				\$ 361

 PROJECT QUALIFICATION TESTS

Project non-energy qualification test.				
Energy savings calc				\$ 409
Non-energy qualification not applicable.				
First year Dollar savings				\$ 108
Total net discounted savings				\$ 1601
Discounted savings ratio				3.18
Simple payback period (years)				4.65

BUILDING 1359

ECO #3 - Weatherstripping

Description - The building doors and windows are loose and have lost effective sealing.
Weatherstripping will cut down on infiltration through them and will help in saving energy.

Energy Saved	= 21 MBTU/year
Cost	= \$723 (incl. SIOH)
SIR	= 1.7

ENERGY BUDGET <A>

Building : #1359-Weatherstripping
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	263,048	65.030
Heating Loads *	103,327	25.544

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	31,694	7.835	31,694	7.835
Cooling Plants	53,186	13.149	53,186	13.149
Heating Plants	103,984	25.707	103,984	25.707
Pumps	6,606	1.633	6,606	1.633
>> HVAC Total	195,470	48.324	195,470	48.324
Lights	75,790	18.737	75,790	18.737
Other Electric	264,784	65.460	264,784	65.460
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	340,574	84.196	340,574	84.196
>> GRAND TOTAL	536,045	132.520	536,045	132.520

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,045 sqft
 Conditioned floor area = 4,045 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ELECTRIC POWER COSTS

Building : #1359-Weatherstripping

08-29-91

Site : FT. BELVOIR, VIRGINIA

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Demand Charges	Fixed Charges	Taxes	Totals
Jan	201	310	0	0	510
Feb	181	310	0	0	491
Mar	204	310	0	0	514
Apr	206	310	0	0	516
May	231	310	0	0	541
June	246	327	0	0	573
July	267	344	0	0	611
Aug	266	336	0	0	603
Sept	226	311	0	0	537
Oct	219	310	0	0	528
Nov	195	310	0	0	505
Dec	197	310	0	0	507
Tot.	2,640	3,797	0	0	6,437

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (kWh)	Effective Rate (\$/kWh)
Jan	510	9,682	0.05272
Feb	491	8,743	0.05616
Mar	514	9,833	0.05223
Apr	516	9,942	0.05188
May	541	11,165	0.04847
June	573	11,889	0.04823
July	611	12,886	0.04743
Aug	603	12,855	0.04689
Sept	537	10,916	0.04920
Oct	528	10,548	0.05009
Nov	505	9,433	0.05356
Dec	507	9,509	0.05330
Tot.	6,437	127,401	0.05052

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Control Tower
Building 1359
Fort Belvoir, VA

By: Engineering Applications Consultants

ECO: Weatherstrip around windows
and first floor door

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Weatherstrip around windows	12	each	\$24	\$288	\$8	\$96	\$384
Weatherstrip door	1	each	\$65	\$65	\$37	\$37	\$102
SUB-TOTAL:				\$353		\$133	\$486
Labor Markup: 21%				\$74		---	\$74
Taxes: 4.5%				---		\$6	\$6
UB-TOTAL:				\$427		\$139	\$566
Overhead: 10%				\$43		\$14	\$57
SUB-TOTAL:				\$470		\$153	\$623
Profit: 10%				\$47		\$15	\$62
TOTAL:				\$517		\$168	\$685

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Weatherstripping

09-26-91

Prepared By : E A C, PC BURKE, VA.

60901891.00

E20-II Advanced Economic Analysis Program

Page 1 of 2

LCCID - based (version 1, level 35).

STUDY IDENTIFICATION BLOCK

Project Title : ESOS
 Installation Name : FORT BELVOIR, BLDG 1359
 Project Number : DACA-31-89-C-0198
 Fiscal Year : 1991
 Name of Analyst : EAC

KEY STUDY DATES

ECIP Economic Life : 5 (years)

INVESTMENT COST SUMMARY

Construction cost	\$	685
SIOH costs	\$	38
Design costs	\$	0
Energy credit calc	\$	651
Salvage value cost	-\$	0
Total investment cost	\$	651

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	0	0	3.95	0
DIST	0.00	0	0	4.65	0
RESID	9.97	21	212	4.34	922
NAT G	0.00	0	0	4.47	0
COAL	0.00	0	0	4.27	0
TOTAL		21	212		\$ 922

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Demand Charges	51	4.10	209
Total discounted savings(+) / costs(-)			\$ 209

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Weatherstripping 09-26-91
 Prepared By : E A C, PC BURKE, VA. 60901891.00
 E20-II Advanced Economic Analysis Program Page 2 of 2
 _CCID - based (version 1, level 35).

 NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	---------------------	------	-----------------	--------------------

No cost items.

Total discounted savings(+) / costs(-)			\$	0
--	--	--	----	---

 DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings			\$	209
Non-energy one-time savings			\$	0
Total non-energy savings			\$	209

 PROJECT QUALIFICATION TESTS

Project non-energy qualification test.				
Energy savings calc			\$	304
Non-energy qualification not applicable.				
First year Dollar savings			\$	263
Total net discounted savings			\$	1131
Discounted savings ratio				1.74
Simple payback period (years)				2.47

BUILDING 1359

ECO #4 - Night Set-Back

Description - The building does not have any night set-back controls and, as such, wastes energy by maintaining the same comfort conditions during unoccupied hours as those during occupied periods. Night set-backs will allow the conditions to slide to less stringent conditions, thus saving energy.

Energy Saved	= 20 MBTU/year
Cost	= \$1188 (incl. SIOH)
SIR	= 1.4

ENERGY BUDGET <A>

Building : #1359-Night setback
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	226,409	55.972
Heating Loads *	96,666	23.898

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	25,849	6.390	25,849	6.390
Cooling Plants	45,979	11.367	45,979	11.367
Heating Plants	96,696	23.905	96,696	23.905
Pumps	6,606	1.633	6,606	1.633
>> HVAC Total	175,130	43.295	175,130	43.295
Lights	75,790	18.737	75,790	18.737
Other Electric	264,784	65.460	264,784	65.460
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	340,574	84.196	340,574	84.196
>> GRAND TOTAL	515,704	127.492	515,704	127.492

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency = 100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,045 sqft
 Conditioned floor area = 4,045 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ELECTRIC POWER COSTS

Building : #1359-Night setback

08-29-91

Site : FT. BELVOIR, VIRGINIA

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Demand Charges	Fixed Charges	Taxes	Totals
Jan	194	310	0	0	504
Feb	176	310	0	0	486
Mar	200	310	0	0	510
Apr	202	310	0	0	512
May	223	310	0	0	533
June	234	327	0	0	561
July	250	344	0	0	595
Aug	253	336	0	0	589
Sept	215	311	0	0	526
Oct	214	310	0	0	524
Nov	193	310	0	0	503
Dec	191	310	0	0	501
Tot.	2,545	3,797	0	0	6,342

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (kWh)	Effective Rate (\$/kWh)
Jan	504	9,386	0.05373
Feb	486	8,486	0.05723
Mar	510	9,656	0.05280
Apr	512	9,752	0.05249
May	533	10,768	0.04949
June	561	11,271	0.04974
July	595	12,086	0.04920
Aug	589	12,191	0.04831
Sept	526	10,375	0.05069
Oct	524	10,347	0.05066
Nov	503	9,301	0.05403
Dec	501	9,220	0.05432
Tot.	6,342	122,839	0.05163

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Control Tower
Building 1359
Fort Belvoir, VA

By: Engineering Applications Consultants

ECO: Install setback thermostats and
outside air damper control on AHU

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install setback thermostat	5	each	\$24	\$120	\$64	\$320	\$440
Remove thermostat	5	each	\$15	\$75	---	---	\$75
Motorized damper	1	each	\$25	\$25	\$120	\$120	\$145
Interlock control	1	each	\$25	\$25	\$167	\$167	\$192
SUB-TOTAL:				\$245		\$607	\$852
Labor Markup: 21%				\$51		---	\$51
Taxes: 4.5%				---		\$27	\$27
SUB-TOTAL:				\$296		\$634	\$931
Overhead: 10%				\$30		\$63	\$93
SUB-TOTAL:				\$326		\$698	\$1,024
Profit: 10%				\$33		\$70	\$102
TOTAL:				\$359		\$768	\$1,126

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Night Setback

09-26-91

Prepared By : E A C, PC BURKE, VA.

60901891.00

E20-II Advanced Economic Analysis Program

Page 1 of 2

LCCID - based (version 1, level 35).

STUDY IDENTIFICATION BLOCK

Project Title : ESOS
 Installation Name : FORT BELVOIR, BLDG 1359
 Project Number : DACA-31-89-C-0198
 Fiscal Year : 1991
 Name of Analyst : EAC

KEY STUDY DATES

ECIP Economic Life : 15 (years)

INVESTMENT COST SUMMARY

Construction cost	\$	1126
SIOH costs	\$	62
Design costs	\$	68
Energy credit calc	\$	1130
Salvage value cost	-\$	0
Total investment cost	\$	1130

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	13	77	8.78	677
DIST	0.00	0	0	12.34	0
RESID	9.97	7	73	12.05	877
NAT G	0.00	0	0	12.48	0
COAL	0.00	0	0	10.01	0
TOTAL		20	150		\$ 1554

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
No cost items.			
Total discounted savings(+) / costs(-)			\$ 0

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Night Setback

09-26-91

Prepared By : E A C, PC BURKE, VA.

60901891.00

E20-II Advanced Economic Analysis Program

Page 2 of 2

LCCID - based (version 1, level 35).

NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	------------------------	------	--------------------	-----------------------

No cost items.

Total discounted savings(+) / costs(-)			\$	0
--	--	--	----	---

DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings			\$	0
---------------------------	--	--	----	---

Non-energy one-time savings			\$	0
-----------------------------	--	--	----	---

Total non-energy savings			\$	0
--------------------------	--	--	----	---

PROJECT QUALIFICATION TESTS

Project non-energy qualification test.

Energy savings calc			\$	513
---------------------	--	--	----	-----

Non-energy qualification not applicable.

First year Dollar savings			\$	150
---------------------------	--	--	----	-----

Total net discounted savings			\$	1554
------------------------------	--	--	----	------

Discounted savings ratio				1.37
--------------------------	--	--	--	------

Simple payback period (years)				7.54
-------------------------------	--	--	--	------

BUILDING 1359

ECO #5 - Reflectors

Description - Fluorescent light fixtures on the third floor are open type fixtures. Reflectors for these fixtures will generate both lighting and cooling costs.

Energy Saved	= 4 MBTU/year
Cost	= \$768 (incl. SIOH)
SIR	= 1.3

ENERGY BUDGET <A>

Building : #1359-Reflectors
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	222,345	54.968
Heating Loads *	97,636	24.137

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	25,849	6.390	25,849	6.390
Cooling Plants	45,224	11.180	45,224	11.180
Heating Plants	97,665	24.145	97,665	24.145
Pumps	6,606	1.633	6,606	1.633
>> HVAC Total	175,345	43.348	175,345	43.348
Lights	64,643	15.981	64,643	15.981
Other Electric	264,784	65.460	264,784	65.460
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	329,428	81.441	329,428	81.441
>> GRAND TOTAL	504,772	124.789	504,772	124.789

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency = 100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,045 sqft
 Conditioned floor area = 4,045 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ELECTRIC POWER COSTS

Building : #1359-Reflectors
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

 TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Demand Charges	Fixed Charges	Taxes	Totals
Jan	189	302	0	0	491
Feb	171	302	0	0	473
Mar	194	302	0	0	496
Apr	196	302	0	0	498
May	217	302	0	0	519
June	227	319	0	0	546
July	244	336	0	0	580
Aug	246	328	0	0	574
Sept	209	303	0	0	512
Oct	208	302	0	0	510
Nov	187	302	0	0	489
Dec	185	302	0	0	488
Tot.	2,473	3,704	0	0	6,177

 TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (kWh)	Effective Rate (\$/kWh)
Jan	491	9,108	0.05391
Feb	473	8,232	0.05744
Mar	496	9,365	0.05300
Apr	498	9,466	0.05266
May	519	10,465	0.04961
June	546	10,972	0.04978
July	580	11,777	0.04924
Aug	574	11,873	0.04835
Sept	512	10,089	0.05073
Oct	510	10,043	0.05082
Nov	489	9,019	0.05424
Dec	488	8,943	0.05452
Tot.	6,177	119,351	0.05176

1359-114

REMOTE HEATING COSTS

Building : #1359-REFLECT-REMOTE (\$)
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

 TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Fixed Charges	Taxes	Total Charges
Jan	242	0	0	242
Feb	180	0	0	180
Mar	108	0	0	108
Apr	38	0	0	38
May	19	0	0	19
June	11	0	0	11
July	9	0	0	9
Aug	10	0	0	10
Sept	15	0	0	15
Oct	35	0	0	35
Nov	99	0	0	99
Dec	206	0	0	206
Tot.	973	0	0	973

 TABLE 2. MONTHLY TOTALS

Month	Charges, (\$)	Energy (MBTU)	Effective Rate (\$/MBTU)
Jan	242	24	9.97000
Feb	180	18	9.97000
Mar	108	11	9.97000
Apr	38	4	9.97000
May	19	2	9.97000
June	11	1	9.97000
July	9	1	9.97000
Aug	10	1	9.97000
Sept	15	1	9.97000
Oct	35	3	9.97000
Nov	99	10	9.97000
Dec	206	21	9.97000
Tot.	973	98	9.97000

1359-115

ENERGY BUDGET <A>

Building : #1359 LIGHTING-REFLECTOR
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

 TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	0	0.000

 TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	0	0.000	0	0.000
Pumps	0	0.000	0	0.000
>> HVAC Total	0	0.000	0	0.000
Lights	53,897	18.779	53,897	18.779
Other Electric	160,966	56.086	160,966	56.086
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	214,863	74.865	214,863	74.865
>> GRAND TOTAL	214,863	74.865	214,863	74.865

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 2,870 sqft
 Conditioned floor area = 2,870 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Control Tower
Building 1359
Fort Belvoir, VA

By: Engineering Applications Consultants

ECO: Install fluorescent fixture reflectors, third floor

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install reflectors	3	each	\$75	\$225	\$105	\$315	\$540
SUB-TOTAL:				\$225		\$315	\$540
Labor Markup: 21%				\$47	---		\$47
Taxes: 4.5%				---		\$14	\$14
SUB-TOTAL:				\$272		\$329	\$601
Overhead: 10%				\$27		\$33	\$60
SUB-TOTAL:				\$299		\$362	\$662
Profit: 10%				\$30		\$36	\$66
TOTAL:				\$329		\$398	\$728

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Reflectors

Prepared By : E A C, PC BURKE, VA.

09-26-91

60901891.00

E20-II Advanced Economic Analysis Program

Page 1 of 2

LCCID - based (version 1, level 35).

STUDY IDENTIFICATION BLOCK

Project Title : ESOS

Installation Name : FORT BELVOIR, BLDG 1359

Project Number : DACA-31-89-C-0198

Fiscal Year : 1991

Name of Analyst : EAC

KEY STUDY DATES

ECIP Economic Life : 15 (years)

INVESTMENT COST SUMMARY

Construction cost	\$	728
SIOH costs	\$	40
Design costs	\$	0
Energy credit calc	\$	691
Salvage value cost	-\$	0
Total investment cost	\$	691

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	6	38	8.78	336
DIST	0.00	0	0	12.34	0
RESID	9.97	-2	-20	12.05	-240
NAT G	0.00	0	0	12.48	0
COAL	0.00	0	0	10.01	0
TOTAL		4	18		\$ 95

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Demand Charges	93	9.11	847
Total discounted savings(+) / costs(-)			\$ 847

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Reflectors

09-26-91

Prepared By : E A C, PC BURKE, VA.

60901891.00

E20-II Advanced Economic Analysis Program

Page 2 of 2

LCCID - based (version 1, level 35).

NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	------------------------	------	--------------------	-----------------------

No cost items.

Total discounted savings(+) / costs(-)			\$	0
--	--	--	----	---

DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings			\$	847
---------------------------	--	--	----	-----

Non-energy one-time savings			\$	0
-----------------------------	--	--	----	---

Total non-energy savings			\$	847
--------------------------	--	--	----	-----

PROJECT QUALIFICATION TESTS

Project non-energy qualification test.

Energy savings calc			\$	32
---------------------	--	--	----	----

Non-energy savings-to-investment ratio				0.18
--	--	--	--	------

(SIR < 1) Project does not qualify.

First year Dollar savings			\$	111
---------------------------	--	--	----	-----

Total net discounted savings			\$	943
------------------------------	--	--	----	-----

Discounted savings ratio				1.36
--------------------------	--	--	--	------

Simple payback period (years)				6.21
-------------------------------	--	--	--	------

BUILDING 1359

ECO #6 - Occupancy Sensors

Description - The lights in the sixth floor conference room stay on for long periods.
Occupancy sensors are proposed to reduce lighting and cooling costs.

Energy Saved	= 1 MBTU/year
Cost	= \$121 (incl. SIOH)
SIR	= 0.5

ENERGY BUDGET <A>

Building : #1359-OCCUPANCY SENSORS
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	221,947	54.870
Heating Loads *	97,648	24.140

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	25,849	6.390	25,849	6.390
Cooling Plants	45,156	11.163	45,156	11.163
Heating Plants	97,681	24.149	97,681	24.149
Pumps	6,606	1.633	6,606	1.633
>> HVAC Total	175,292	43.336	175,292	43.336
Lights	63,892	15.795	63,892	15.795
Other Electric	264,784	65.460	264,784	65.460
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	328,677	81.255	328,677	81.255
>> GRAND TOTAL	503,969	124.591	503,969	124.591

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency = 100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,045 sqft
 Conditioned floor area = 4,045 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ELECTRIC POWER COSTS

Building : #1359-OCCUPANCY SENSORS

08-29-91

Site : FT. BELVOIR, VIRGINIA

6100190202

Prepared By : E A C, PC BURKE, VA.

Page 1 of 1

Carrier Hourly Analysis Program

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Demand Charges	Fixed Charges	Taxes	Totals
Jan	188	302	0	0	490
Feb	170	302	0	0	472
Mar	194	302	0	0	495
Apr	196	302	0	0	497
May	216	302	0	0	518
June	227	318	0	0	545
July	244	335	0	0	579
Aug	246	327	0	0	573
Sept	209	302	0	0	511
Oct	208	302	0	0	509
Nov	186	302	0	0	488
Dec	185	302	0	0	487
Tot.	2,468	3,697	0	0	6,165

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (kWh)	Effective Rate (\$/kWh)
Jan	490	9,088	0.05392
Feb	472	8,214	0.05746
Mar	495	9,345	0.05301
Apr	497	9,446	0.05266
May	518	10,444	0.04961
June	545	10,951	0.04977
July	579	11,756	0.04924
Aug	573	11,851	0.04835
Sept	511	10,069	0.05072
Oct	509	10,022	0.05083
Nov	488	9,000	0.05425
Dec	487	8,928	0.05452
Tot.	6,165	119,115	0.05176

ENERGY BUDGET <A>

Building : #1359-LIGHTING-OCC SENSO
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

 TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	0	0.000

 TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	0	0.000	0	0.000
Pumps	0	0.000	0	0.000
>> HVAC Total	0	0.000	0	0.000
Lights	53,146	18.518	53,146	18.518
Other Electric	160,966	56.086	160,966	56.086
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	214,112	74.604	214,112	74.604
>> GRAND TOTAL	214,112	74.604	214,112	74.604

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 2,870 sqft
 Conditioned floor area = 2,870 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Control Tower
Building 1359
Fort Belvoir, VA

By: Engineering Applications Consultants

ECO: Install occupancy sensor for conference room

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install sensor	1	each	\$25	\$25	\$60	\$60	\$85
Remove existing switch	1	each	\$2	\$2	---	---	\$2
SUB-TOTAL:				\$27		\$60	\$87
Labor Markup: 21%				\$6		---	\$6
Taxes: 4.5%				---		\$3	\$3
SUB-TOTAL:				\$33		\$63	\$95
Overhead: 10%				\$3		\$6	\$10
SUB-TOTAL:				\$36		\$69	\$105
Profit: 10%				\$4		\$7	\$10
TOTAL:				\$40		\$76	\$115

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Occupancy Sensors
 Prepared By : E A C, PC BURKE, VA.
 E20-II Advanced Economic Analysis Program
 LCCID - based (version 1, level 35).

09-26-91
 60901891.00
 Page 1 of 2

STUDY IDENTIFICATION BLOCK

Project Title : ESOS
 Installation Name : FORT BELVOIR, BLDG 1359
 Project Number : DACA-31-89-C-0198
 Fiscal Year : 1991
 Name of Analyst : EAC

KEY STUDY DATES

ECIP Economic Life : 10 (years)

INVESTMENT COST SUMMARY

Construction cost	\$	115
SIOH costs	\$	6
Design costs	\$	0
Energy credit calc	\$	109
Salvage value cost	-\$	0
Total investment cost	\$	109

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	0	1	6.72	8
DIST	0.00	0	0	8.77	0
RESID	9.97	0	0	8.40	0
NAT G	0.00	0	0	8.68	0
COAL	0.00	0	0	7.53	0
TOTAL		0	1		\$ 8

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Demand Charges	7	7.02	49
Total discounted savings(+) / costs(-)			\$ 49

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Occupancy Sensors
 Prepared By : E A C, PC BURKE, VA.
 E20-II Advanced Economic Analysis Program
 LCCID - based (version 1, level 35).

09-26-91
 60901891.00
 Page 2 of 2

 NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	---------------------	------	-----------------	--------------------

No cost items.

Total discounted savings(+) / costs(-)			\$	0
--	--	--	----	---

 DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings			\$	49
---------------------------	--	--	----	----

Non-energy one-time savings			\$	0
-----------------------------	--	--	----	---

Total non-energy savings			\$	49
--------------------------	--	--	----	----

 PROJECT QUALIFICATION TESTS

Project non-energy qualification test.

Energy savings calc			\$	3
---------------------	--	--	----	---

Non-energy savings-to-investment ratio				0.10
--	--	--	--	------

(SIR < 1) Project does not qualify.

First year Dollar savings			\$	8
---------------------------	--	--	----	---

Total net discounted savings			\$	57
------------------------------	--	--	----	----

Discounted savings ratio				0.53
--------------------------	--	--	--	------

(SIR < 1) Project does not qualify.

Simple payback period (years)				13.26
-------------------------------	--	--	--	-------

BUILDING 1359

ECO #7 - Wall Insulation

Description - The wall assembly does not have any insulation. A proposed exterior wall system will provide 2" wall insulation (R-11), which will improve U-value from 0.4 to 0.074 BTU/hr. - Sq. Ft. - °F. This improvement should provide energy savings by reducing heat loss and heat gain through the walls.

Energy Saved	= 31 MBTU/year
Cost	= \$36,826 (incl. SIOH)
SIR	= 0.2

ENERGY BUDGET <A>

Building : #1359-WALL INSULATION

08-29-91

Site : FT. BELVOIR, VIRGINIA

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	225,406	55.725
Heating Loads *	68,256	16.874

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	25,402	6.280	25,402	6.280
Cooling Plants	44,751	11.063	44,751	11.063
Heating Plants	68,256	16.874	68,256	16.874
Pumps	6,945	1.717	6,945	1.717
>> HVAC Total	145,354	35.934	145,354	35.934
Lights	63,892	15.795	63,892	15.795
Other Electric	264,784	65.460	264,784	65.460
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	328,677	81.255	328,677	81.255
>> GRAND TOTAL	474,031	117.189	474,031	117.189

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency = 100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,045 sqft
 Conditioned floor area = 4,045 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ELECTRIC POWER COSTS

Building : #1359-WALL INSULATION

08-29-91

Site : FT. BELVOIR, VIRGINIA

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Demand Charges	Fixed Charges	Taxes	Totals
Jan	188	296	0	0	484
Feb	171	296	0	0	466
Mar	196	296	0	0	491
Apr	197	296	0	0	493
May	216	296	0	0	512
June	224	313	0	0	537
July	240	329	0	0	568
Aug	242	321	0	0	564
Sept	207	299	0	0	506
Oct	209	296	0	0	505
Nov	189	296	0	0	484
Dec	186	296	0	0	482
Tot.	2,464	3,628	0	0	6,092

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (kWh)	Effective Rate (\$/kWh)
Jan	484	9,091	0.05325
Feb	466	8,242	0.05660
Mar	491	9,437	0.05206
Apr	493	9,512	0.05181
May	512	10,418	0.04910
June	537	10,823	0.04965
July	568	11,561	0.04914
Aug	564	11,684	0.04823
Sept	506	10,009	0.05056
Oct	505	10,079	0.05006
Nov	484	9,103	0.05320
Dec	482	8,967	0.05370
Tot.	6,092	118,926	0.05122

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Control Tower
Building 1359
Fort Belvoir, VA

By: Engineering Applications Consultants

ECO: Add 2" of insulation to exterior walls

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install exterior insulation	4259	sq. ft.	\$3.18	\$13,543	\$2.80	\$11,924	\$25,467

SUB-TOTAL:				\$13,543		\$11,924	\$25,467
labor Markup: 21%				\$2,844		---	\$2,844
Taxes: 4.5%				---		\$537	\$537
SUB-TOTAL:				\$16,387		\$12,461	\$28,848
Overhead: 10%				\$1,639		\$1,246	\$2,885
SUB-TOTAL:				\$18,025		\$13,707	\$31,732
Profit: 10%				\$1,803		\$1,371	\$3,173
TOTAL:				\$19,828		\$15,078	\$34,906

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Wall Insulation
 Prepared By : E A C, PC BURKE, VA.
 E20-II Advanced Economic Analysis Program
 .CCID - based (version 1, level 35).

09-26-91
 60901891.00
 Page 1 of 2

STUDY IDENTIFICATION BLOCK

Project Title : ESOS
 Installation Name : FORT BELVOIR, BLDG 1359
 Project Number : DACA-31-89-C-0198
 Fiscal Year : 1991
 Name of Analyst : EAC

KEY STUDY DATES

ECIP Economic Life : 25 (years)

INVESTMENT COST SUMMARY

Construction cost	\$	34906
SIOH costs	\$	1920
Design costs	\$	2094
Energy credit calc	\$	35028
Salvage value cost	-\$	0
Total investment cost	\$	35028

ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	1	7	11.37	76
DIST	0.00	0	0	17.06	0
RESID	9.97	29	293	16.85	4939
NAT G	0.00	0	0	17.52	0
COAL	0.00	0	0	13.34	0
TOTAL		31	300		\$ 5015

NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Demand Charges	69	11.65	804
Total discounted savings(+) / costs(-)			\$ 804

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Wall Insulation

09-26-91

Prepared By : E A C, PC BURKE, VA.

60901891.00

E20-II Advanced Economic Analysis Program

Page 2 of 2

LCCID - based (version 1, level 35).

NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	------------------------	------	--------------------	-----------------------

No cost items.

Total discounted savings(+) / costs(-)				\$ 0
--	--	--	--	------

DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings				\$ 804
---------------------------	--	--	--	--------

Non-energy one-time savings				\$ 0
-----------------------------	--	--	--	------

Total non-energy savings				\$ 804
--------------------------	--	--	--	--------

PROJECT QUALIFICATION TESTS

Project non-energy qualification test.

Energy savings calc				\$ 1655
---------------------	--	--	--	---------

Non-energy qualification not applicable.

First year Dollar savings				\$ 369
---------------------------	--	--	--	--------

Total net discounted savings				\$ 5819
------------------------------	--	--	--	---------

Discounted savings ratio				0.17
--------------------------	--	--	--	------

(SIR < 1) Project does not qualify.

Simple payback period (years)				94.98
-------------------------------	--	--	--	-------

BUILDING 1359

ECO #8 - Double Insulated Glass

Description - This is another proposed building envelope improvement to reduce energy usage. Existing single galss windows (U-value 1.0) will be replaced by double glassed windows with a U-value of 0.58.

Energy Saved	= 4 MBTU/year
Cost	= \$5,129 (incl. SIOH)
SIR	= 0.2

ENERGY BUDGET <A>

Building : #1359-DOUBLE GLAZED WIND

08-29-91

Site : FT. BELVOIR, VIRGINIA

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	226,109	55.898
Heating Loads *	63,855	15.786

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	25,379	6.274	25,379	6.274
Cooling Plants	44,793	11.074	44,793	11.074
Heating Plants	63,855	15.786	63,855	15.786
Pumps	6,978	1.725	6,978	1.725
>> HVAC Total	141,005	34.859	141,005	34.859
Lights	63,892	15.795	63,892	15.795
Other Electric	264,784	65.460	264,784	65.460
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	0	0.000	0	0.000
>> Non-HVAC Total	328,677	81.255	328,677	81.255
>> GRAND TOTAL	469,682	116.114	469,682	116.114

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,045 sqft
 Conditioned floor area = 4,045 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ELECTRIC POWER COSTS

Building : #1359-DOUBLE GLAZED WIND
 Site : FT. BELVOIR, VIRGINIA
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

08-29-91
 6100190202

Page 1 of 1

 TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Demand Charges	Fixed Charges	Taxes	Totals
Jan	188	295	0	0	484
Feb	171	295	0	0	466
Mar	196	295	0	0	491
Apr	197	295	0	0	492
May	216	295	0	0	511
June	224	313	0	0	537
July	239	328	0	0	567
Aug	242	321	0	0	563
Sept	207	298	0	0	506
Oct	209	295	0	0	504
Nov	189	295	0	0	484
Dec	186	295	0	0	481
Tot.	2,464	3,622	0	0	6,087

 TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (kWh)	Effective Rate (\$/kWh)
Jan	484	9,092	0.05319
Feb	466	8,246	0.05653
Mar	491	9,452	0.05196
Apr	492	9,516	0.05175
May	511	10,419	0.04906
June	537	10,817	0.04963
July	567	11,550	0.04913
Aug	563	11,674	0.04822
Sept	506	10,006	0.05054
Oct	504	10,085	0.05000
Nov	484	9,110	0.05313
Dec	481	8,974	0.05362
Tot.	6,087	118,941	0.05118

1359-135

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Control Tower
Building 1359
Fort Belvoir, VA

By: Engineering Applications Consultants

ECO: Replace single glaze windows with double glaze windows

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install windows (3x4)	10	each	\$38	\$380	\$250	\$2,500	\$2,880
Install windows (3x3)	2	each	\$27	\$54	\$220	\$440	\$494
Remove windows	12	each	\$29	\$348	---	---	
SUB-TOTAL:				\$782		\$2,940	\$3,374
labor Markup: 21%				\$164		---	\$164
Taxes: 4.5%				---		\$132	\$132
SUB-TOTAL:				\$946		\$3,072	\$3,671
Overhead: 10%				\$95		\$307	\$402
SUB-TOTAL:				\$1,041		\$3,380	\$4,072
Profit: 10%				\$104		\$338	\$442
TOTAL:				\$1,145		\$3,717	\$4,514

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Double Glazed Window
 Prepared By : E A C, PC BURKE, VA.
 320-II Advanced Economic Analysis Program
 LCCID - based (version 1, level 35).

09-26-91
 60901891.00
 Page 1 of 2

 STUDY IDENTIFICATION BLOCK

 Project Title : ESOS
 Installation Name : FORT BELVOIR, BLDG 1359
 Project Number : DACA-31-89-C-0198
 Fiscal Year : 1991
 Name of Analyst : EAC

 KEY STUDY DATES

 ECIP Economic Life : 25 (years)

 INVESTMENT COST SUMMARY

 Construction cost \$ 4862
 SIOH costs \$ 267
 Design costs \$ 292
 Energy credit calc \$ 4879
 Salvage value cost -\$ 0
 Total investment cost \$ 4879

 ANNUAL ENERGY SAVINGS(+) / COST(-), DOE REGION 3 , CENSUS REGION 3

Fuel	Unit Cost \$/MBTU	Savings MBTU / Yr	Annual Savings \$	Discount Factor	Discounted Savings
ELEC	6.07	0	0	11.37	0
DIST	0.00	0	0	17.06	0
RESID	9.97	4	44	16.85	739
NAT G	0.00	0	0	17.52	0
COAL	0.00	0	0	13.34	0
TOTAL		4	44		\$ 739

 NON-ENERGY ANNUAL SAVINGS(+) / COST(-)

Item	Annual Savings \$	Discount Factor	Discounted Savings
Maintenance	6	11.65	70
Total discounted savings(+) / costs(-)			\$ 70

ENERGY CONSERVATION INVESTMENT PROGRAM REPORT

Discrete Portion : Double Glazed Window

09-26-91

Prepared By : E A C, PC BURKE, VA.

60901891.00

E20-II Advanced Economic Analysis Program

Page 2 of 2

LCCID - based (version 1, level 35).

NON-ENERGY ONE-TIME SAVINGS(+) / COST(-)

Item	One-Time Savings \$	Year	Discount Factor	Discounted Savings
------	------------------------	------	--------------------	-----------------------

No cost items.

Total discounted savings(+) / costs(-)	\$	0
--	----	---

DISCOUNTED NON-ENERGY SAVINGS(+) / COST(+) TOTALS

Non-energy annual savings	\$	70
---------------------------	----	----

Non-energy one-time savings	\$	0
-----------------------------	----	---

Total non-energy savings	\$	70
--------------------------	----	----

PROJECT QUALIFICATION TESTS

Project non-energy qualification test.

Energy savings calc	\$	244
---------------------	----	-----

Non-energy qualification not applicable.

First year Dollar savings	\$	50
---------------------------	----	----

Total net discounted savings	\$	809
------------------------------	----	-----

Discounted savings ratio		0.17
--------------------------	--	------

(SIR < 1) Project does not qualify.

Simple payback period (years)		97.84
-------------------------------	--	-------

FORT BELVOIR

BUILDING 1359

	COST	SIOH	DESIGN	ENERGY ELEC MBTU	SAVINGS OIL MBTU	ANNUAL \$	DISCNTD \$	NON-ENERGY ANNUAL \$	DISCNTD \$	DOLLAR SAVINGS 1st YEAR DISCOUNTED	
RADIATOR CONTROL VALVES	896	49	54	0	25	244	2943	0	0	244	2943
CLG. INSUL	502	28	30	2	7	77	1240	31	361	108	1601
WEATHER- STRIPPING	685	38	0	0	21	212	922	51	209	263	1131
NIGHT- SETBACK	1126	62	68	13	7	150	1554	0	0	150	1554
REFLECTORS	728	40	0	6	-2	18	95	93	847	111	943
TOTALS	3937	217	151	21	58	701	6754	175	1417	876	8172

LIFE CYCLE COST ANALYSIS SUMMARY
ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

LOCATION: FORT BELVOIR REGION NO. 3 PROJECT NUMBER DACA-31-89-C-0198

PROJECT TITLE: ENERGY SAVINGS OPPORTUNITY SURVEY FISCAL YR. 1991

DISCRETE PORTION NAME BUILDING 1359 - TOTAL ALL ECO's

ANALYSIS DATE AUGUST 1991 ECONOMIC LIFE _____ YEARS PREPARED BY EAC

1. INVESTMENT

A. CONSTRUCTION COST	\$ <u>3,937</u>	
B. SIOH	\$ <u>217</u>	
C. DESIGN COST	\$ <u>151</u>	
D. SALVAGE VALUE	- \$ _____	
E. TOTAL INVESTMENT (1A + 1B + 1C - 1D)		\$ <u>4,305</u>

2. ENERGY SAVINGS (+) / COST (-)

ANALYSIS DATE ANNUAL SAVINGS, UNIT COST AND DISCOUNTED SAVINGS

	FUEL	COST \$/MBTU/YR(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS (5)
A. ELEC		\$ <u>6.07</u>	<u>21</u>	\$ _____	_____	\$ _____
B. DIST		\$ <u>7.43</u>	_____	\$ _____	_____	\$ _____
C. RESID		\$ <u>9.97</u>	<u>58</u>	\$ _____	_____	\$ _____
D. NG		\$ <u>5.33</u>	_____	\$ _____	_____	\$ _____
E. COAL		\$ _____	_____	\$ _____	_____	\$ _____
F. TOTAL			<u>79</u>	\$ <u>701</u>		\$ <u>6,754</u>

3. NONENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)

(1) DISCOUNT FACTOR (TABLE A)	_____	\$ <u>175</u>
(2) DISCOUNTED SAVING/COST (3A X 3A1)	_____	\$ <u>1,417</u>

B. NONRECURRING SAVINGS (+) / COST (-)

ITEM	SAVINGS (+) COST (-)(1)	YEAR OF OCCUR.(2)	DISCOUNT FACTOR(3)	DISCOUNTED SAV- INGS(+) COST(-)(4)
(1) _____	\$ _____	_____	_____	\$ _____
(2) _____	\$ _____	_____	_____	\$ _____
(3) _____	\$ _____	_____	_____	\$ _____
(4) TOTAL	\$ _____			\$ _____

C. TOTAL NONENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ _____

D. PROJECT NONENERGY QUALIFICATION TEST

(1) 25% MAX NONENERGY CALC (2F5 x .33) \$ _____

a. IF 3D1 IS = OR > 3C GO TO ITEM 4

b. IF 3D1 IS < 3C CALC S1R = (2F5+3D1) - 1E = _____

c. IF 3D1 IS = > 1 GO TO ITEM 4

d. IF 3D1 IS < 1 PROJECT DOES NOT QUALIFY

4. FIRST YEAR DOLLAR SAVINGS 2F3 + 3A + (3B1d - YEARS ECONOMIC LIFE) \$ 876

5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C) \$ 8,171

6. DISCOUNTED SAVINGS RATION (IF < 1 PROJECT DOES NOT QUALIFY) (S1R) = (5-1E) = 1.9

1359-140

BUILDINGS 1 TO 60
GENERAL OFFICERS' QUARTERS
(TYPICALS)

QUARTERS 1 THROUGH 60

Fuel Conversion:

Description - Existing oil-fired boilers used for heating and oil-fired water heaters are proposed to be replaced by gas-fired boilers and water heaters respectively.

Energy Saved	= 1,607	MBTU/year
Cost	= \$ 520,753	(incl. SIOH)
SIR	= 1.3	

QUARTERS 1 THROUGH 60

Bldg No.	Location	Complex Code	Bed- rooms	Sq Ft	Year
1	Fairfax Drive	OX	5	7,262 ✓	35
2	Fairfax Drive	OX	5	4,803 ✓	34
3	Fairfax Drive	OX	5	3,461 ✓	34
4	Fairfax Drive	OX	5	4,803	34
5	Fairfax Drive	3X	4/SP	3,575 ✓	35
6	Fairfax Drive	3X	4	3,295 ✓	34
7	Woodlawn Drive	3X	4	3,575	35
8	Woodlawn Drive	3X	4	3,575	35
9	Woodlawn Drive	3X	4	3,295	34
10	Woodlawn Drive	3X	4	3,575	35
11	Woodlawn Drive	3X	4	3,295	34
12	Woodlawn Drive	3X	4/SP	3,473 ✓	35
13	Woodlawn Drive	OX	5	4,803	34
14	Woodlawn Drive	3X	5	4,803	34
15	Woodlawn Drive	3X	5	4,803	34
16	Woodlawn Drive	OX	5	4,803	34
17	Woodlawn Drive	3X	5	4,803	34
18	Woodlawn Drive	3X	5	4,803 -	34
19	Woodlawn Drive	3X	5	3,461 -	34
21	Mason Drive	3X	4/SP	3,473	35
22	Mason Drive	3X	4	3,257 ✓	34
23	Mason Drive	3X	4/SP	3,473	35
24	Mason Drive	3X	4/SP	3,473	34
25	Mason Drive	3X	4	3,257	34
26	Mason Drive	3X	4	3,257	34
27	Mason Drive	3X	4/SP	3,575	35
28	Mason Drive	3X	4/SP	3,575	35
29	Mason Drive	3X	4	3,295	34
30	Mason Drive	3X	4	3,575	35
31	Mason Drive	3X	4	3,295	34
32	Mason Drive	3X	4/SP	3,575	35
33	Mason Drive	3X	4	3,295	34
34	Belvoir Drive	3X	4	3,295	34
35	Belvoir Drive	3X	4	3,575	35
36	Belvoir Drive	3X	4	3,295	34
37	Belvoir Drive	3X	4	3,575	35
38	Belvoir Drive	3X	4	3,575	35
39	Belvoir Drive	3X	4	3,295	34
40	Belvoir Drive	3X	4	3,295	34
41	Belvoir Drive	3X	4	3,575	35
42	Belvoir Drive	3X	4	3,575	34
43	Belvoir Drive	3X	4/SP	3,575	35
44	Belvoir Drive	3X	4/SP	3,575	35
45	Belvoir Drive	3X	4	3,295	34
46	Belvoir Drive	3X	4/SP	3,575	35
47	Belvoir Drive	3X	4	3,295	34

Bldg No.	Location	Complex Code	Bed- rooms	Sq Ft	Year
48	Belvoir Drive	3X	4/SP	3,575	35
49	Belvoir Drive	3X	4	3,295	34
50	Belvoir Drive	3X	4/SP	3,575	35
51	Belvoir Drive	3X	4	3,295	34
52	Fairfax Drive	3X	5	4,803	34
53	Fairfax Drive	OX	5	4,803	34
54	Fairfax Drive	OX	5	4,803	34
55	Fairfax Drive	OX	5	4,803	34
56	Fairfax Drive	3X	5	4,803	34
57	Fairfax Drive	3X	5	4,803	34
58	Fairfax Drive	OX	5	4,803	34
59	Fairfax Drive	OX	5	4,803	34
60	Fairfax Drive	OX	5	4,803	34

QUARTERS 1-60

TABLE OF CONTENTS

Input Data	1
Output Data	24
ECIP Analysis	
Energy Savings	33
Cost Summary	34-48
LCC Analysis	50

DESIGN PARAMETERS, SHGs

Location : FT. BELVOIR, VIRGINIA

04-27-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

DESIGN WEATHER PARAMETERS

City Name.....: FT. BELVOIR
 Location.....: VIRGINIA
 Latitude.....: 38.4 deg
 Elevation.....: 69.0 ft
 Summer Design Dry Bulb Temp.....: 90.0 F
 Summer Design Wet Bulb Temp.....: 75.0 F
 Daily Temperature Range.....: 23.0 F
 Winter Design Dry Bulb Temp.....: 12.0 F
 Atmospheric Clearness Number.....: 1.00

TABLE 1. MAXIMUM SOLAR HEAT GAINS - AVERAGE DAYS
(BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	24.2	61.1	97.3	110.1	97.3	61.1	24.2	24.2	80.0
Feb	31.8	74.8	105.7	113.8	105.7	74.8	31.8	31.8	107.2
Mar	40.8	87.0	106.9	108.0	106.9	87.0	40.8	40.8	136.8
Apr	60.0	97.4	104.4	97.2	104.4	97.4	60.0	49.3	164.3
May	74.9	103.0	98.4	84.0	98.4	103.0	74.9	54.9	181.8
Jun	85.1	109.3	97.5	79.2	97.5	109.3	85.1	57.9	195.2
Jul	80.6	106.7	98.1	81.4	98.1	106.7	80.6	56.4	189.3
Aug	69.1	104.1	105.7	94.4	105.7	104.1	69.1	52.2	177.6
Sep	52.3	99.3	114.8	111.6	114.8	99.3	52.3	45.4	158.1
Oct	36.4	88.3	117.7	122.9	117.7	88.3	36.4	36.4	128.2
Nov	26.7	66.5	101.8	113.3	101.8	66.5	26.7	26.7	89.4
Dec	21.4	53.0	87.6	100.9	87.6	53.0	21.4	21.4	68.4

TABLE 2. MAXIMUM SOLAR HEAT GAINS - DESIGN DAYS
(BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	20.4	158.9	243.9	253.8	243.9	158.9	20.4	20.4	142.0
Feb	53.0	189.1	246.5	237.5	246.5	189.1	53.0	24.7	187.7
Mar	95.9	219.8	234.5	200.7	234.5	219.8	95.9	29.4	229.0
Apr	141.6	224.4	200.1	146.7	200.1	224.4	141.6	34.1	256.0
May	166.1	220.1	170.7	104.6	170.7	220.1	166.1	37.4	268.0
Jun	173.2	215.4	156.7	87.8	156.7	215.4	173.2	47.4	269.7
Jul	163.7	215.7	166.5	101.4	166.5	215.7	163.7	38.3	264.7
Aug	136.4	216.6	193.1	141.7	193.1	216.6	136.4	35.8	251.3
Sep	90.3	207.2	224.7	194.9	224.7	207.2	90.3	30.6	221.4
Oct	52.0	182.7	238.2	230.6	238.2	182.7	52.0	25.5	184.4
Nov	20.7	156.1	239.8	249.9	239.8	156.1	20.7	20.7	141.3
Dec	18.5	141.9	236.4	254.2	236.4	141.9	18.5	18.5	122.2

MASTER SCHEDULE SUMMARY

Page 1

Prepared By : E A C

04-14-91

Carrier Hourly Analysis Program

6100190202

MASTER SCHEDULE 1. OCCUPANCY

Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	100	100	100	100	100	100	100	50	30	30	30	30
Saturday	100	100	100	100	100	100	100	100	100	100	100	100
Sunday	100	100	100	100	100	100	100	100	100	100	100	100
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	50	30	30	30	30	50	70	100	100	100	100	100
Saturday	100	100	100	100	100	100	100	100	100	100	100	100
Sunday	100	100	100	100	100	100	100	100	100	100	100	100
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

MASTER SCHEDULE 2. HOT WATER

Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	0	0	0	0	0	100	100	100	80	60	30	10
Saturday	0	0	0	0	0	0	100	100	100	100	70	70
Sunday	0	0	0	0	0	0	100	100	100	100	70	70
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	10	10	10	10	10	30	30	30	30	60	40	20
Saturday	10	10	10	10	10	10	10	30	30	30	30	10
Sunday	10	10	10	10	10	10	10	30	30	30	30	10
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

MASTER SCHEDULE 3. EMPTY

Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	100	100	100	100	100	100	100	100	100	100	100	100
Saturday	100	100	100	100	100	100	100	100	100	100	100	100
Sunday	100	100	100	100	100	100	100	100	100	100	100	100
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	100	100	100	100	100	100	100	100	100	100	100	100
Saturday	100	100	100	100	100	100	100	100	100	100	100	100
Sunday	100	100	100	100	100	100	100	100	100	100	100	100
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

SIMPLE SPACE DESCRIPTION

Space Name : OFFICERS' QUARTERS TYP A

04-14-91

Prepared By : E A C

6100190202

Barrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.300	0.200	0.500	Building Weight :	M
Weight :	M	M		Glass Factor :	0.80
Color :	M	M		Internal Shades ?	N

People : sqft/person = 533.0 Schedule = 1 Activity Level = 1
Lights : W/sqft = 0.00 Schedule = 1 Wattage Mult. = 1.00
: Fixture Type = 1 Recessed, not vented

SPACE NAME = OFFICERS' QUARTERS TYP A

		Floor Area :	4,803.0 sqft
Exposure :	NE	E Roof Area :	1,648.0 sqft
Wall Area :	4,631.0	0.0 Current	
Glass Area :	367.0	0.0 Elements :	In,Gr,Gl

ADDITIONAL ELEMENT - Infiltration

Cooling :	0.00 CFM/sqft =	0 CFM
Heating :	0.10 CFM/sqft =	480 CFM
Typical :	0.10 CFM/sqft =	480 CFM

ADDITIONAL ELEMENT - Ground

Slab Floor Area	=	1,120.0 sqft
Perimeter	=	136.0 ft
Depth	=	4.0 ft

ADDITIONAL ELEMENT - Glass

U-Value	=	0.640 BTU/hr/sqft/F	Exposure	=	S
Glass Factor	=	0.52	Area	=	98.0 sqft
Internal Shades	?	N			

SIMPLE SPACE DESCRIPTION

Space Name : OFFICERS' QUARTERS TYP B

04-14-91

Prepared By : E A C

6100190202

Barrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.300	0.200	0.500	Building Weight :	M
Weight :	M	M		Glass Factor :	0.80
Color :	M	M		Internal Shades ?	N

People : sqft/person = 533.0 Schedule = 1 Activity Level = 1
Lights : W/sqft = 0.00 Schedule = 1 Wattage Mult. = 1.00
: Fixture Type = 1 Recessed, not vented

SPACE NAME = OFFICERS' QUARTERS TYP B

Exposure :	NE	E	Floor Area :	3,295.0 sqft
Wall Area :	3,730.0	0.0	Roof Area :	1,340.0 sqft
Glass Area :	304.0	0.0	Current Elements :	In,Gr,Gl

ADDITIONAL ELEMENT - Infiltration

Cooling : 0.00 CFM/sqft = 0 CFM
Heating : 0.10 CFM/sqft = 340 CFM
Typical : 0.10 CFM/sqft = 340 CFM

ADDITIONAL ELEMENT - Ground

Slab Floor Area = 1,080.0 sqft
Perimeter = 136.0 ft
Depth = 4.0 ft

ADDITIONAL ELEMENT - Glass

U-Value = 0.640 BTU/hr/sqft/F Exposure = S
Glass Factor = 0.52 Area = 90.0 sqft
Internal Shades ? N

SIMPLE SPACE DESCRIPTION

Space Name : OFFICERS' QUARTERS TYP C

04-14-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.300	0.200	0.500	Building Weight :	M
Weight :	M	M		Glass Factor :	0.80
Color :	M	M		Internal Shades ?	N

People : sqft/person = 533.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 1 Wattage Mult. = 1.00
 : Fixture Type = 1 Recessed, not vented

SPACE NAME = OFFICERS' QUARTERS TYP C

Exposure :	NE	E	Floor Area :	3,575.0 sqft
Wall Area :	3,603.0	0.0	Roof Area :	1,100.0 sqft
Glass Area :	410.0	0.0	Current	
			Elements :	In,Gr,Gl

ADDITIONAL ELEMENT - Infiltration

Cooling :	0.00 CFM/sqft =	0 CFM
Heating :	0.13 CFM/sqft =	455 CFM
Typical :	0.13 CFM/sqft =	455 CFM

ADDITIONAL ELEMENT - Ground

Slab Floor Area	=	1,100.0 sqft
Perimeter	=	136.0 ft
Depth	=	4.0 ft

ADDITIONAL ELEMENT - Glass

U-Value	=	0.640 BTU/hr/sqft/F	Exposure	=	S
Glass Factor	=	0.52	Area	=	171.0 sqft
Internal Shades	?	N			

AIR SYSTEM DESCRIPTION

Name : QUARTER #1
Carrier Hourly Analysis Program
Prepared By : E A C

04-28-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = QUARTER #1
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	100.0 F	68.0 F	CLOSED
Unoccupied	100.0 F	68.0 F	CLOSED

Weekday : Occupied Period Begins at 0 ; Duration = 24 hrs
Saturday : Occupied Period Begins at 0 ; Duration = 24 hrs
Sunday : Occupied Period Begins at 0 ; Duration = 24 hrs
Design Day : Occupied Period Begins at 0 ; Duration = 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
Heating supply temperature = 110.0 F
Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 20.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : QUARTER #1

04-28-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C

Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 12:User defined

kW at full air flow = 0.0 kW

Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050

Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : QUARTER TYPE A
Carrier Hourly Analysis Program
Prepared By : E A C

04-28-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = QUARTER TYPE A
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period		Thermostat Setpoints		Ventilation Dampers
		Cooling	Heating	
Occupied		100.0 F	68.0 F	CLOSED
Unoccupied		100.0 F	68.0 F	CLOSED
Weekday	: Occupied Period Begins at	0 ; Duration		= 24 hrs
Saturday	: Occupied Period Begins at	0 ; Duration		= 24 hrs
Sunday	: Occupied Period Begins at	0 ; Duration		= 24 hrs
Design Day	: Occupied Period Begins at	0 ; Duration		= 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
Heating supply temperature = 110.0 F
Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 20.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : QUARTER TYPE A
Carrier Hourly Analysis Program
Prepared By : E A C

04-28-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 12:User defined
kW at full air flow = 0.0 kW
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050

Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : QUARTER TYPE B

04-28-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C

Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = QUARTER TYPE B
 System Class = Constant Volume
 System Type = (SZCV) Single Zone Constant Volume
 Operation Type = 2 Heating Only
 Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	100.0 F	68.0 F	CLOSED
Unoccupied	100.0 F	68.0 F	CLOSED

Weekday : Occupied Period Begins at 0 ; Duration = 24 hrs
 Saturday : Occupied Period Begins at 0 ; Duration = 24 hrs
 Sunday : Occupied Period Begins at 0 ; Duration = 24 hrs
 Design Day : Occupied Period Begins at 0 ; Duration = 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
 Heating supply temperature = 110.0 F
 Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 20.00 % of supply air
 Minimum ventilation flow rate = 0.00 % of supply air
 Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
 Zone exhaust fan power = 0.0 kW
 Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : QUARTER TYPE B
Carrier Hourly Analysis Program
Prepared By : E A C

04-28-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 12:User defined
kW at full air flow = 0.0 kW
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : QUARTER TYPE C

04-28-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C

Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = QUARTER TYPE C
 System Class = Constant Volume
 System Type = (SZCV) Single Zone Constant Volume
 Operation Type = 2 Heating Only
 Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	100.0 F	68.0 F	CLOSED
Unoccupied	100.0 F	68.0 F	CLOSED

Weekday : Occupied Period Begins at 0 ; Duration = 24 hrs
 Saturday : Occupied Period Begins at 0 ; Duration = 24 hrs
 Sunday : Occupied Period Begins at 0 ; Duration = 24 hrs
 Design Day : Occupied Period Begins at 0 ; Duration = 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
 Heating supply temperature = 110.0 F
 Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 20.00 % of supply air
 Minimum ventilation flow rate = 0.00 % of supply air
 Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
 Zone exhaust fan power = 0.0 kW
 Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : QUARTER TYPE C

04-28-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C

Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 12:User defined
kW at full air flow = 0.0 kW
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050

Type of supplemental heating = 1 Not Used

FUEL RATE DATA

Fuel Rate : NATURAL GAS

04-28-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. FUEL RATE DATA

NAME

Name of rate schedule = NATURAL GAS

CURRENCY

Currency name = Dollars

Currency symbol = \$

BASIC INFORMATION

Units of measurement = Therms

Conversion factor = 100.00000 kBTU/Therms

Type of rate schedule = 1 Simple

Flat rate charge = 0.53290 \$/Therms

FUEL RATE DATA

Fuel Rate : FUEL OIL #2

04-28-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. FUEL RATE DATA

NAME

Name of rate schedule = FUEL OIL #2

CURRENCY

Currency name = Dollars

Currency symbol = \$

BASIC INFORMATION

Units of measurement = gal

Conversion factor = 138.70000 kBTU/gal

Type of rate schedule = 1 Simple

Flat rate charge = 1.03000 \$/gal

BUILDING DESCRIPTION

Building : QUARTER #1 (OIL)

04-28-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = QUARTER #1 (OIL)

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW

Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y

Maximum hourly hot water use = 6.0 gal

Hot water schedule = 1

Average entering water temperature = 57.0 F

Average hot water supply temperature = 140.0 F

Heating plant type = 2 : Combustion

Fuel type = 2 : Fuel Oil

Plant capacity = 60.0 MBH

Is plant efficiency computer generated ? N

Annual plant efficiency = 70 %

OTHER INPUTS

Additional building floor area = 0.0 sqft

Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
QUARTER #1 (OIL)	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	3	Virginia Power Schedule MS	\$
Natural Gas	1	NATURAL GAS	\$
Fuel Oil	5	FUEL OIL #2	\$
Propane	5	FUEL OIL #2	\$
Remote Source Heating	5	FUEL OIL #2	\$
Remote Source Cooling	5	FUEL OIL #2	\$

BUILDING DESCRIPTION

Building : QUARTER TYPE A (OIL)

04-28-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = QUARTER TYPE A (OIL)

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW

Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y

Maximum hourly hot water use = 6.0 gal

Hot water schedule = 1

Average entering water temperature = 57.0 F

Average hot water supply temperature = 140.0 F

Heating plant type = 2 : Combustion

Fuel type = 2 : Fuel Oil

Plant capacity = 60.0 MBH

Is plant efficiency computer generated ? N

Annual plant efficiency = 70 %

OTHER INPUTS

Additional building floor area = 0.0 sqft

Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
QUARTER TYPE A (OIL)	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	3	Virginia Power Schedule MS	\$
Natural Gas	1	NATURAL GAS	\$
Fuel Oil	5	FUEL OIL #2	\$
Propane	5	FUEL OIL #2	\$
Remote Source Heating	5	FUEL OIL #2	\$
Remote Source Cooling	5	FUEL OIL #2	\$

BUILDING DESCRIPTION

Building : QUARTER TYPE B (OIL)

04-28-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = QUARTER TYPE B (OIL)

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW
Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y
Maximum hourly hot water use = 6.0 gal
Hot water schedule = 1
Average entering water temperature = 57.0 F
Average hot water supply temperature = 140.0 F
Heating plant type = 2 : Combustion
Fuel type = 2 : Fuel Oil
Plant capacity = 60.0 MBH
Is plant efficiency computer generated ? N
Annual plant efficiency = 70 %

OTHER INPUTS

Additional building floor area = 0.0 sqft
Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
QUARTER TYPE B (OIL)	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	3	Virginia Power Schedule MS	\$
Natural Gas	1	NATURAL GAS	\$
Fuel Oil	5	FUEL OIL #2	\$
Propane	5	FUEL OIL #2	\$
Remote Source Heating	5	FUEL OIL #2	\$
Remote Source Cooling	5	FUEL OIL #2	\$

BUILDING DESCRIPTION

Building : QUARTER TYPE C (OIL)

04-28-91

Prepared By: E A C

6100190202

Barrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = QUARTER TYPE C (OIL)

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW

Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y

Maximum hourly hot water use = 6.0 gal

Hot water schedule = 1

Average entering water temperature = 57.0 F

Average hot water supply temperature = 140.0 F

Heating plant type = 2 : Combustion

Fuel type = 2 : Fuel Oil

Plant capacity = 60.0 MBH

Is plant efficiency computer generated ? N

Annual plant efficiency = 70 %

OTHER INPUTS

Additional building floor area = 0.0 sqft

Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
QUARTER TYPE C (OIL)	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	3	Virginia Power Schedule MS	\$
Natural Gas	1	NATURAL GAS	\$
Fuel Oil	5	FUEL OIL #2	\$
Propane	5	FUEL OIL #2	\$
Remote Source Heating	5	FUEL OIL #2	\$
Remote Source Cooling	5	FUEL OIL #2	\$

BUILDING DESCRIPTION

Building : QUARTER #1 (GAS)

04-28-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = QUARTER #1 (GAS)

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW
Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y
Maximum hourly hot water use = 6.0 gal
Hot water schedule = 1
Average entering water temperature = 57.0 F
Average hot water supply temperature = 140.0 F
Heating plant type = 2 : Combustion
Fuel type = 1 : Natural Gas
Plant capacity = 60.0 MBH
Is plant efficiency computer generated ? N
Annual plant efficiency = 78 %

OTHER INPUTS

Additional building floor area = 0.0 sqft
Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
QUARTER #1 (GAS)	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	3	Virginia Power Schedule MS	\$
Natural Gas	1	NATURAL GAS	\$
Fuel Oil	5	FUEL OIL #2	\$
Propane	5	FUEL OIL #2	\$
Remote Source Heating	5	FUEL OIL #2	\$
Remote Source Cooling	5	FUEL OIL #2	\$

BUILDING DESCRIPTION

Building : QUARTER TYPE A (GAS)
 Prepared By: E A C
 Carrier Hourly Analysis Program

04-28-91
 6100190202
 Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = QUARTER TYPE A (GAS)

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW
 Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y
 Maximum hourly hot water use = 6.0 gal
 Hot water schedule = 1
 Average entering water temperature = 57.0 F
 Average hot water supply temperature = 140.0 F
 Heating plant type = 2 : Combustion
 Fuel type = 1 : Natural Gas
 Plant capacity = 60.0 MBH
 Is plant efficiency computer generated ? N
 Annual plant efficiency = 78 %

OTHER INPUTS

Additional building floor area = 0.0 sqft
 Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
QUARTER TYPE A (GAS)	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	3	Virginia Power Schedule MS	\$
Natural Gas	1	NATURAL GAS	\$
Fuel Oil	5	FUEL OIL #2	\$
Propane	5	FUEL OIL #2	\$
Remote Source Heating	5	FUEL OIL #2	\$
Remote Source Cooling	5	FUEL OIL #2	\$

BUILDING DESCRIPTION

Building : QUARTER TYPE B (GAS)

04-28-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = QUARTER TYPE B (GAS)

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW
Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y
Maximum hourly hot water use = 6.0 gal
Hot water schedule = 1
Average entering water temperature = 57.0 F
Average hot water supply temperature = 140.0 F
Heating plant type = 2 : Combustion
Fuel type = 1 : Natural Gas
Plant capacity = 60.0 MBH
Is plant efficiency computer generated ? N
Annual plant efficiency = 78 %

OTHER INPUTS

Additional building floor area = 0.0 sqft
Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
QUARTER TYPE B (GAS)	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	3	Virginia Power Schedule MS	\$
Natural Gas	1	NATURAL GAS	\$
Fuel Oil	5	FUEL OIL #2	\$
Propane	5	FUEL OIL #2	\$
Remote Source Heating	5	FUEL OIL #2	\$
Remote Source Cooling	5	FUEL OIL #2	\$

BUILDING DESCRIPTION

Building : QUARTER TYPE C (GAS)

04-28-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = QUARTER TYPE C (GAS)

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW
Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y
Maximum hourly hot water use = 6.0 gal
Hot water schedule = 1
Average entering water temperature = 57.0 F
Average hot water supply temperature = 140.0 F
Heating plant type = 2 : Combustion
Fuel type = 1 : Natural Gas
Plant capacity = 60.0 MBH
Is plant efficiency computer generated ? N
Annual plant efficiency = 78 %

OTHER INPUTS

Additional building floor area = 0.0 sqft
Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
QUARTER TYPE C (GAS)	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	3	Virginia Power Schedule MS	\$
Natural Gas	1	NATURAL GAS	\$
Fuel Oil	5	FUEL OIL #2	\$
Propane	5	FUEL OIL #2	\$
Remote Source Heating	5	FUEL OIL #2	\$
Remote Source Cooling	5	FUEL OIL #2	\$

ENERGY BUDGET <A>

Building : QUARTER #1 (OIL)
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-28-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	249,768	34.394

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	356,811	49.134	356,811	49.134
Pumps	1,839	0.253	1,839	0.253
>> HVAC Total	358,649	49.387	358,649	49.387
Lights	0	0.000	0	0.000
Other Electric	0	0.000	0	0.000
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	41,570	5.724	41,570	5.724
>> Non-HVAC Total	41,570	5.724	41,570	5.724
>> GRAND TOTAL	400,219	55.111	400,219	55.111

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 7,262 sqft
 Conditioned floor area = 7,262 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ENERGY BUDGET <A>

Building : QUARTER TYPE A (OIL)

04-28-91

Site : Fort Belvoir, Virginia

6100190202

Prepared By : E A C

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	177,479	36.952

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	253,542	52.788	253,542	52.788
Pumps	0	0.000	0	0.000
>> HVAC Total	253,542	52.788	253,542	52.788
Lights	0	0.000	0	0.000
Other Electric	0	0.000	0	0.000
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	41,570	8.655	41,570	8.655
>> Non-HVAC Total	41,570	8.655	41,570	8.655
>> GRAND TOTAL	295,111	61.443	295,111	61.443

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 4,803 sqft
 Conditioned floor area = 4,803 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ENERGY BUDGET <A>

Building : QUARTER TYPE B (OIL)
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-28-91
 6100190202

Page 1 of 1

Carrier Hourly Analysis Program

 TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	138,626	42.072

 TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	198,037	60.102	198,037	60.102
Pumps	0	0.000	0	0.000
>> HVAC Total	198,037	60.102	198,037	60.102
Lights	0	0.000	0	0.000
Other Electric	0	0.000	0	0.000
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	41,570	12.616	41,570	12.616
>> Non-HVAC Total	41,570	12.616	41,570	12.616
>> GRAND TOTAL	239,607	72.718	239,607	72.718

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 3,295 sqft
 Conditioned floor area = 3,295 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ENERGY BUDGET <A>

Building : QUARTER TYPE C (OIL)

04-28-91

Site : Fort Belvoir, Virginia

6100190202

Prepared By : E A C

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	148,636	41.576

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	212,337	59.395	212,337	59.395
Pumps	0	0.000	0	0.000
>> HVAC Total	212,337	59.395	212,337	59.395
Lights	0	0.000	0	0.000
Other Electric	0	0.000	0	0.000
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	41,570	11.628	41,570	11.628
>> Non-HVAC Total	41,570	11.628	41,570	11.628
>> GRAND TOTAL	253,907	71.023	253,907	71.023

- * Notes: 1. Site energy is the actual energy consumed.
2. Source energy accounts for electrical generating inefficiencies. For this study:
Electric generating efficiency =100.0 %
3. Energy per unit floor area is based on the gross building floor area. For this building:
Gross floor area = 3,575 sqft
Conditioned floor area = 3,575 sqft
4. Annual cooling load is the sum of all cooling plant loads.
5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ENERGY BUDGET <A>

Building : QUARTER #1 (GAS)
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-28-91

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	249,768	34.394

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	320,215	44.095	320,215	44.095
Pumps	1,839	0.253	1,839	0.253
>> HVAC Total	322,053	44.348	322,053	44.348
Lights	0	0.000	0	0.000
Other Electric	0	0.000	0	0.000
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	37,306	5.137	37,306	5.137
>> Non-HVAC Total	37,306	5.137	37,306	5.137
>> GRAND TOTAL	359,359	49.485	359,359	49.485

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency = 100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 7,262 sqft
 Conditioned floor area = 7,262 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ENERGY BUDGET <A>

Building : QUARTER TYPE A (GAS)

04-28-91

Site : Fort Belvoir, Virginia

6100190202

Prepared By : E A C

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	177,479	36.952

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	227,538	47.374	227,538	47.374
Pumps	0	0.000	0	0.000
>> HVAC Total	227,538	47.374	227,538	47.374
Lights	0	0.000	0	0.000
Other Electric	0	0.000	0	0.000
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	37,306	7.767	37,306	7.767
>> Non-HVAC Total	37,306	7.767	37,306	7.767
>> GRAND TOTAL	264,844	55.141	264,844	55.141

* Notes: 1. Site energy is the actual energy consumed.

2. Source energy accounts for electrical generating inefficiencies. For this study:

Electric generating efficiency =100.0 %

3. Energy per unit floor area is based on the gross building floor area. For this building:

Gross floor area = 4,803 sqft

Conditioned floor area = 4,803 sqft

4. Annual cooling load is the sum of all cooling plant loads.

5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ENERGY BUDGET <A>

Building : QUARTER TYPE B (GAS)

04-28-91

Site : Fort Belvoir, Virginia

6100190202

Prepared By : E A C

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft)*
Cooling Loads *	0	0.000
Heating Loads *	138,626	42.072

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft)*	(kBTU)	(kBTU/sqft)*
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	177,726	53.938	177,726	53.938
Pumps	0	0.000	0	0.000
>> HVAC Total	177,726	53.938	177,726	53.938
Lights	0	0.000	0	0.000
Other Electric	0	0.000	0	0.000
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	37,306	11.322	37,306	11.322
>> Non-HVAC Total	37,306	11.322	37,306	11.322
>> GRAND TOTAL	215,032	65.260	215,032	65.260

- * Notes: 1. Site energy is the actual energy consumed.
 2. Source energy accounts for electrical generating inefficiencies. For this study:
 Electric generating efficiency =100.0 %
 3. Energy per unit floor area is based on the gross building floor area. For this building:
 Gross floor area = 3,295 sqft
 Conditioned floor area = 3,295 sqft
 4. Annual cooling load is the sum of all cooling plant loads.
 5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

ENERGY BUDGET <A>

Building : QUARTER TYPE C (GAS)

04-28-91

Site : Fort Belvoir, Virginia

6100190202

Prepared By : E A C

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. ANNUAL LOADS

Component	(kBTU)	(kBTU/sqft) *
Cooling Loads *	0	0.000
Heating Loads *	148,636	41.576

TABLE 2. ENERGY BY SYSTEM COMPONENT

Component	<----- Site Energy ----->		<----- Source Energy ----->	
	(kBTU)	(kBTU/sqft) *	(kBTU)	(kBTU/sqft) *
Air System Fans	0	0.000	0	0.000
Cooling Plants	0	0.000	0	0.000
Heating Plants	190,559	53.303	190,559	53.303
Pumps	0	0.000	0	0.000
>> HVAC Total	190,559	53.303	190,559	53.303
Lights	0	0.000	0	0.000
Other Electric	0	0.000	0	0.000
Misc. Electric	0	0.000	0	0.000
Dom. Hot Water	37,306	10.435	37,306	10.435
>> Non-HVAC Total	37,306	10.435	37,306	10.435
>> GRAND TOTAL	227,865	63.738	227,865	63.738

* Notes: 1. Site energy is the actual energy consumed.

2. Source energy accounts for electrical generating inefficiencies. For this study:

Electric generating efficiency =100.0 %

3. Energy per unit floor area is based on the gross building floor area. For this building:

Gross floor area = 3,575 sqft

Conditioned floor area = 3,575 sqft

4. Annual cooling load is the sum of all cooling plant loads.

5. Annual heating load is the sum of all primary and auxiliary heating plant loads. It does not include the domestic water heating load.

QUARTERS 1 THROUGH 60

Fuel Conversion:

Description - Existing oil-fired boilers used for heating and oil-fired water heaters are proposed to be replaced by gas-fired boilers and water heaters respectively.

Energy Saved	= 1,607	MBTU/year
Cost	= \$ 520,753	(incl. SIOH)
SIR	= 1.3	

PORT BELVOIR OFFICERS QUARTERS

CONSTRUCTION COSTS AND ENERGY SAVINGS CONSOLIDATION

TYPE	No.	ENERGY SAVINGS, MBTU/BLDG			TOTAL ENERGY SAVINGS, MBTU		
		ELEC.	OIL	GAS	ELEC.	OIL	GAS
1	1	0	398	-357	0	398	-357
A	19	0	295	-265	0	5605	-5035
B	18	0	240	-215	0	4320	-3870
C	21	0	254	-228	0	5334	-4788
TOTAL	59				0	15657	-14050

CONSTRUCTION COST ESTIMATE				DATE PREPARED APR. 1991		SHEET OF	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY				BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____			
LOCATION FT. BELVOIR, VIRGINIA							
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS							
DRAWING NO. 1-60 QUARTERS		ESTIMATOR REF		CHECKED BY VP			
TYPE 1 SUMMARY CONVERSION TO GAS		QUANTITY		LABOR		MATERIAL	
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL
DEMOLITION							
REMOVE 275 GAL OIL TANK							
CLEANING, & DISPOSAL		2	EA	420	840	-	840
REMOVE OIL BOILER		1	EA		320		320
PATCH PIPE OPENING		1	EA		50	20	70
						-	
NEW WORK							
GAS BOILER w/CONTROLS		1	EA		850	2050	2900
PRES. REG., VALVES, ETC.			LS		85	160	245
GAS PIPING		40	LF	4.00	160	1.84	74
HAND EXCAVATING		2.5	CY	34.	85	-	85
HOLE THRU BSMT. WALL		1	EA		54	-	54
BACKFILLING, HAND		2.5	CY	12.45	32	-	32
MISC & GENERAL CLEANUP			LS		125	51	176
FLUES TO CHIMNEY 4"		12	LF	5.15	62	2.86	35
6"		12	LF	2.00	70	3.96	48
SUB-TOTAL					2733	2438	5171
LABOR INS & TAXES 21%					574		574
SALES TAX 4.5%						110	110
SUB-TOTAL							5855
OVERHEAD 10%							586
SUB-TOTAL							6441
PROFIT 10%							644
SUB-TOTAL							7085
TOTAL							\$7085

CONSTRUCTION COST ESTIMATE				DATE PREPARED APR. 1991		SHEET OF	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY					BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____		
LOCATION FT. BELVOIR, VIRGINIA							
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS							
DRAWING NO. 1-60 QUARTERS			ESTIMATOR REF		CHECKED BY VP		
TYPE A,B & C CONVERSION TO GAS SUMMARY		QUANTITY		LABOR		MATERIAL	
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL
DEMOLITION							
REMOVE 275 GAL OIL TANK,							
CLEANING & DISPOSAL		1	EA		420		420
REMOVE OIL BOILER		1	EA		320		320
PATCH FIRE OPENING		1	EA		50	20	70
NEW WORK							
GAS BOILER W/CONTROLS		1	EA		840	1600	2440
PRES. REG., VALVES ETC		1	LS		85	160	245
GAS PIPING		30	LF	4.00	120	1.84	175
HAND EXCAVATING		2.5	CY	34.	85		85
HOLE THRU BSMT WALL		1	EA		54		54
BACKFILLING, HAND			LS		125	51	176
FLUES TO CHIMNEY 4"		12	LF	5.15	62	2.86	97
6"		10	LF	5.85	59	3.96	99
MISC & GENERAL CLEANUP			LS		125	51	176
SUB-TOTAL					2345	2012	4357
LABOR INS & TAXES 21%					492		492
SALES TAX 4.5%						91	91
SUB-TOTAL							4940
OVERHEAD 10%							494
SUB-TOTAL							5434
PROFIT 10%							543
SUB-TOTAL							5977
TOTAL							\$ 5977

CONSTRUCTION COST ESTIMATE

DATE PREPARED APR 1991

SHEET OF

PROJECT

ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION

FT. BELVOIR, VIRGINIA

ARCHITECT ENGINEER

ENGINEERING APPLICATIONS CONSULTANTS

BASIS FOR ESTIMATE

- ☐ CODE A (No design completed)
☐ CODE B (Preliminary design)
☐ CODE C (Final design)
☐ OTHER (Specify) _____

DRAWING NO.

I-60 QUARTERS

ESTIMATOR

REF

CHECKED BY

VP

TYPE ALL SUMMARY	QUANTITY		LABOR		MATERIAL		TOTAL COST
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	
REPLACE GAS HOT WATER HEATER W/SAME							
REMOVE HOT WATER HEATER				50			50
GAS HOT WATER HEATER INCLUDING PIPING AND FITTINGS WITHIN 10' OF SAME	1	EA		680		470	1150
SUB-TOTAL				730		470	1200
LABOR INS & TAXES 21%				153			153
SALES TAX 4.5%						21	21
SUB-TOTAL							1374
OVERHEAD 10%							137
SUB-TOTAL							1511
PROFIT 10%							151
SUB-TOTAL							1662
TOTAL							\$1665.

CONSTRUCTION COST ESTIMATE

DATE PREPARED

APR 1991

SHEET

OF

PROJECT

ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION

FT. BELVOIR, VIRGINIA

ARCHITECT ENGINEER

ENGINEERING APPLICATIONS CONSULTANTS

BASIS FOR ESTIMATE

- ☐ CODE A (No design completed)
☐ CODE D (Preliminary design)
☐ CODE C (Final design)
☐ OTHER (Specify) _____

DRAWING NO.

1-600 QUARTERS

ESTIMATOR

REF

CHECKED BY

VP

TYPE 1 REPLACE OIL BOILERS & HW HEATERS WITH SAME	QUANTITY		LABOR		MATERIAL		TOTAL COST
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	
REMOVE BOILER	1	EA		320			320
CHANGE OIL TANK FILTERS	2	EA	10	20	10	20	40
OIL BOILER W/CONTROLS	1	EA		916		2070	2986
OIL CONNECTIONS	2	EA	10	20	10	20	40
FLUE TO CHIMNEY 6"	12	LF	5.85	70	3.96	48	118
MISC & GENERAL CLEANUP		LS		125		50	175
SUB-TOTAL				1174		2208	3382.
LABOR INS & TAXES 21%				247			247.
SALES TAX 4.5%						100	100.
SUB-TOTAL							3729.
OVERHEAD 10%							373.
SUB-TOTAL							4102.
PROFIT 10%							410.
SUB-TOTAL							4,512.
TOTAL							\$4,515.

CONSTRUCTION COST ESTIMATE				DATE PREPARED APR 1991		SHEET OF	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY				BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____			
LOCATION FT. BELVOIR, VIRGINIA							
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS							
DRAWING NO. 1-60 QUARTERS			ESTIMATOR REF		CHECKED BY VP		
TYPE A,B,&C SUMMARY REPLACE OIL BOILERS & H/W HEATERS WITH SAME		QUANTITY		LABOR		MATERIAL	
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL
REMOVE BOILER		1	EA		320		320
							50
CHANGE OIL TANK FILTER		1	EA		10		20
OIL BOILER w/CONTROLS		1	EA		755		2425
OIL CONNECTIONS		1	EA		10		20
FLUE TO CHIMNEY 6"		10	LF		59		99
MISC & GENERAL CLEANUP			LS		125		175
SUB-TOTAL					1279		3059
LABOR, INS & TAXES 21%					269		269
SALES TAX 45%						80	80
SUB-TOTAL							3405
OVERHEAD 10%							341
SUB-TOTAL							3749
PROFIT 10%							375
SUB-TOTAL							4,124
TOTAL							\$ 4,125

CONSTRUCTION COST ESTIMATE				DATE PREPARED APR 1991		SHEET OF	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY				BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____			
LOCATION FT. BELVOIR, VIRGINIA							
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS							
DRAWING NO. 1-60 QUARTERS		ESTIMATOR REF		CHECKED BY VP			
ALL TYPES SUMMARY REPLACE OIL HOT WATER HEATER W/SAVE		QUANTITY		LABOR		MATERIAL	
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL
REMOVE HW HEATER		1	EA		50		50
OIL HW HEATER 50 GAL		1	EA		640	1200	1840
INCLUDING PIPING & FITTINGS							
WITHIN 10' OF HEATER &							
FLUE CONNECTION							
SUB-TOTAL					690	1200	1890
LABOR, INS, & TAXES 21%					145		145
SALES TAX 4.5%						54	54
SUB-TOTAL							2089
OVERHEAD 10%							209
SUB-TOTAL							2298
PROFIT 10%							230
SUB-TOTAL							2528
TOTAL							\$ 2590.

CONSTRUCTION COST ESTIMATE					DATE PREPARED APR. 1991		SHEET OF	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY					BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____			
LOCATION FT. BELVOIR, VIRGINIA								
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS								
DRAWING NO. 1-60 QUARTERS			ESTIMATOR REF		CHECKED BY VF			
TYPE <u>1</u> SUMMARY CONVERSION TO GAS		QUANTITY		LABOR		MATERIAL		TOTAL COST
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	
DEMOLITION								
REMOVE 275 GAL OIL TANK								
CLEANING, & DISPOSAL		2	EA	420	840		-	840
REMOVE OIL BOILER		1	EA		320			320
PATCH PIPE OPENING		1	EA		50		20	70
NEW WORK								
GAS BOILER w/controls		1	EA		850		2050	2900
PRES. REG., VALVES, ETC.			LS		85		160	245
GAS PIPING		40	LF	4.00	160	1.84	74	234
HAND EXCAVATING		2.5	CY	34.	85		-	85
HOLE THRU BSMT. WALL		1	EA		54		-	54
BACKFILLING, HAND		2.5	CY	12.45	32		-	32
MISC & GENERAL CLEANUP			LS		125		51	176
FLUES TO CHIMNEY 4"		12	LF	5.15	62	2.86	35	97
6"		12	LF	5.85	70	3.96	48	118
SUB-TOTAL					2733		2438	5171
LABOR INS & TAXES 21%					574			574
SALES TAX 4.5%							11.0	110
SUB-TOTAL								5855
OVERHEAD 10%								586
SUB-TOTAL								6441
PROFIT 10%								644
SUB-TOTAL								7085
TOTAL								57085

CONSTRUCTION COST ESTIMATE					DATE PREPARED APR. 1991		SHEET OF	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY					BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____			
LOCATION FT. BELVOIR, VIRGINIA								
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS								
DRAWING NO. 1-60 QUARTERS			ESTIMATOR REF		CHECKED BY VP			
TYPE A,B & C SUMMARY CONVERSION TO GAS		QUANTITY		LABOR		MATERIAL		TOTAL COST
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	
DEMOLITION								
REMOVE 275 GAL OIL TANK,								
CLEANING & DISPOSAL		1	EA		420			420
REMOVE OIL BOILER		1	EA		320			320
PATCH PIPE OPENING		1	EA		50		20	70
NEW WORK								
GAS BOILER W/CONTROLS		1	EA		840		1600	2440
PRES. REG., VALVES ETC		1	LS		85		160	245
GAS PIPING		30	LF	4.00	120	1.84	55	175
HAND EXCAVATING		2.5	CY	34.	85			85
HOLE THRU BSMT WALL		1	EA		54			54
BACKFILLING, HAND			LS		125		51	176
FLUES TO CHIMNEY 4"		12	LF	5.15	62	2.86	35	97
6"		10	LF	5.85	59	3.96	40	99
MISC & GENERAL CLEANUP			LS		125		51	176
SUB-TOTAL					2345		2012	4357
LABOR INS & TAXES 21%					492			492
SALES TAX 4.5%							91	91
SUB-TOTAL								4940
OVERHEAD 10%								494
SUB-TOTAL								5434
PROFIT 10%								543
SUB-TOTAL								5977
TOTAL								\$ 5977

CONSTRUCTION COST ESTIMATE					DATE PREPARED APR 1991		SHEET OF	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY					BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____			
LOCATION FT. BELVOIR, VIRGINIA								
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS								
DRAWING NO. 1-60 QUARTERS			ESTIMATOR REF		CHECKED BY VP			
TYPE ALL		SUMMARY		QUANTITY		LABOR		MATERIAL
				NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT
								TOTAL
								TOTAL COST
REPLACE GAS HOT WATER HEATER W/SAME								
REMOVE HOT WATER HEATER							50	
								50
GAS HOT WATER HEATER INCLUDING PIPING AND FITTINGS WITHIN 10' OF SAME				1	EA		680	470
								1150
SUB-TOTAL							730	470
								1200
LABOR INS & TAXES 21%							153	
								153
SALES TAX 4.5%								21
								21
SUB-TOTAL								1374
OVERHEAD 10%								137
								137
SUB-TOTAL								1511
PROFIT 10%								151
								151
SUB-TOTAL								1662
TOTAL								\$1665.

CONSTRUCTION COST ESTIMATE						DATE PREPARED APR 1991		SHEET OF
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY						BASIS FOR ESTIMATE		
LOCATION FT. BELVOIR, VIRGINIA						<input type="checkbox"/> CODE A (No design completed)		
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS						<input type="checkbox"/> CODE B (Preliminary design)		
						<input type="checkbox"/> CODE C (Final design)		
						<input type="checkbox"/> OTHER (Specify) _____		
DRAWING NO.	ESTIMATOR		REF		CHECKED BY			
I-60 QUARTERS			REF		VP			
ALL TYPES SUMMARY	QUANTITY		LABOR		MATERIAL	TOTAL COST		
REPLACE OIL HOT WATER HEATER w/SAME	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT TOTAL			
REMOVE HW HEATER	1	EA		50			50	
OIL HW HEATER 50 GAL INCLUDING PIPING & FITTINGS WITHIN 10' OF HEATER & FLUE CONNECTION	1	EA		640		1200	1840	
SUB-TOTAL				690		1200	1890	
LABOR, INS, & TAXES 2%				145			145	
SALES TAX 4.5%						54	54	
SUB-TOTAL							2089	
OVERHEAD 10%							209	
SUB-TOTAL							2298	
PROFIT 10%							230	
SUB-TOTAL							2528	
TOTAL							\$ 2590.	

CONSTRUCTION COST ESTIMATE					DATE PREPARED AUG '91		SHEET 1 OF 1	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY					BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____			
LOCATION FT. BELVOIR, VIRGINIA								
ARCHITECT/ENGINEER ENGINEERING APPLICATIONS CONSULTANTS								
DRAWING NO. OFFICERS QTRS-BLDG 1-60				ESTIMATOR REF		CHECKED BY VP		
GAS to BLDGS — SUMMARY		QUANTITY		LABOR		MATERIAL		TOTAL COST
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	
TRENCH & BACKFILL		2400	LF	1.01	2424	.74	1776	4200
HAND EXCAVATION		200	CY	34.00	6800		—	6800
HAND BACKFILL		200	CY	12.45	2490		—	2490
POLYETHYLENE PIPE - 1/4"		2400	LF	1.17	2808	.55	1320	4128
BLACK STEEL PIPE - 3/4"		900	LF	3.21	2889	.87	783	3672
MAIN CONNECTION		60	EA	15.00	900	5.00	300	1200
STOP VALVES		60	EA	9.00	540	8.05	483	1023
PRESSURE REGULATORS		60	EA	10.00	600	50.00	3000	3600
HAULING		60	CY	2.21	133	4.33	260	392
DISPOSAL & MATERIAL			LS	300	300		—	300
MATERIAL HANDL. / STORAGE			LS	200	200		—	200
SEED / SOD			LS	300	300		—	300
GAS LINE TESTING		60	EA	10.00	600		—	600
GENERAL CLEAN-UP		60	EA	10.00	600		—	600
SUB-TOTAL					21,584.		7,922	29,506
LABOR, INS. & TAXES 21%					4,533.		—	4,533
SALES TAX 4.5%					—		356	356
SUB-TOTAL					26,117.		8,278	34,395
OVERHEAD 10%								3,440
SUB-TOTAL								37,835
PROFIT 10%								3,784
SUB-TOTAL								41,619
TOTAL								\$ 41,619.

$$\text{PROPORTIONAL COST / UNIT} = \frac{46,619.}{59} = \$790.$$

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.00

FUEL CONVERSION COST ANALYSIS

GENERAL OFFICERS' QUARTERS - TYPE 1 (1 building)

Proposed conversion

Estimated cost of gas-fired furnace	= \$	7,085
Estimated cost of gas-fired water heater	= \$	1,665
Cost of conversion	= \$	8,750
Total Cost of Conversion	\$ 8,750 X 1	= \$ 8,750

Water heater replacement costs

Gas-fired water heaters	= \$1,665 X 1	= \$1,665
Oil-fired water heaters	= \$2,590 X 1	= \$2,590

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.00

FUEL CONVERSION COST ANALYSIS

GENERAL OFFICERS' QUARTERS - TYPES A, B & C (58 buildings)

Proposed conversion

Estimated cost of gas-fired furnace	= \$ 5,977	
Estimated cost of gas-fired water heater	= \$ 1,665	
Cost of conversion now	= \$ 7,642	
Total Cost of Conversion	\$ 7,642 X 58	= \$443,236

Water heater replacement costs

Gas-fired water heaters =	\$ 1,665 X 58=	\$ 96,570
Oil-fired water heaters =	\$ 2,590 X 58=	\$150,220

CONSTRUCTION COST ESTIMATE				DATE PREPARED AUG '91		SHEET 1 OF 1	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY					BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____		
LOCATION FT. BELVOIR, VIRGINIA							
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS							
DRAWING NO. OFFICERS QTRS-BLDG 1-60			ESTIMATOR REF		CHECKED BY VP		
<u>GAS to BLDGS</u> SUMMARY		QUANTITY		LABOR		MATERIAL	
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL
TRENCH & BACKFILL	2400	LF	1.01	2424	.74	1776	4200
HAND EXCAVATION	200	CY	34.00	6800		-	6800
HAND BACKFILL	200	CY	12.45	2490		-	2490
POLYETHYLENE PIPE - 1/4"	2400	LF	1.17	2808	.55	1320	4128
BLACK STEEL PIPE - 3/4"	900	LF	3.21	2889	.87	783	3672
MAIN CONNECTION	60	EA	15.00	900	5.00	300	1200
STOP VALVES	60	EA	9.00	540	8.05	483	1023
PRESSURE REGULATORS	60	EA	10.00	600	50.00	3000	3600
HAULING	60	CY	2.21	133	4.33	260	392
DISPOSAL & MATERIAL		LS	300	300		-	300
MATERIAL HANDL. / STORAGE		LS	200	200		-	200
SEED / SOD		LS	300	300		-	300
GAS LINE TESTING	60	EA	10.00	600		-	600
GENERAL CLEAN-UP	60	EA	10.00	600		-	600
SUB-TOTAL				21,584.		7,922	29,506
LABOR, INS. & TAXES 21%				4,533.		-	4,533
SALES TAX 4.5%				-		356	356
SUB-TOTAL				26,117.		8,278	34,395
OVERHEAD 10%							3,440
SUB-TOTAL							37,835
PROFIT 10%							3,784
SUB-TOTAL							41,619
TOTAL							\$ 41,619.

PROPORTIONAL COST / UNIT = $\frac{41,619}{47.59} = \$874.90$

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.00

FUEL CONVERSION COST ANALYSIS

GENERAL OFFICERS' QUARTERS - SUMMARY OF COSTS

Type 1 (1 building)	\$ 8,750
Types A, B & C (58 buildings)	\$443,236
Cost to Govt for curb to buildings gas lines	\$ 41,619
TOTAL	\$493,605

Replacement costs of water heaters:

	<u>Gas-fired</u>	<u>Oil-fired</u>
Typical Building 1	\$ 1,665	\$ 2,590
Typical buildings A, B & C	\$ 96,570	\$ 150,220
TOTAL	\$ 98,235	\$ 152,810

PORT BELVOIR OFFICERS QUARTERS

CONSOLIDATION OF OTHER COSTS

TYPE	No.	ONE TIME REPLAC. COSTS			MAINT. COSTS	ONE TIME REPLAC. COSTS	
		MAINT. COST PER BLDG	\$/BLDG OIL WH	GAS WH		\$ OIL WH	GAS WH
1	1	10	2590	-1665	10	2590	-1665
A	19	10	2590	-1665	190	49210	-31635
B	18	10	2590	-1665	180	46620	-29970
C	21	10	2590	-1665	210	54390	-34965
TOTAL	59				590	0 152810	-98235

LIFE CYCLE COST ANALYSIS SUMMARY
ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

LOCATION: FORT BELVOIR REGION NO. 3 PROJECT NUMBER DACA-31-89-C-0198
PROJECT TITLE: ENERGY SAVINGS OPPORTUNITY SURVEY FISCAL YR. 1991
DISCRETE PORTION NAME GENERAL OFFICERS' QUARTERS - OIL TO GAS CONVERSION
ANALYSIS DATE AUGUST 1991 ECONOMIC LIFE 20 YEARS PREPARED BY EAC

1. INVESTMENT
A. CONSTRUCTION COST \$ 493,605
B. SIOH \$ 27,148
C. DESIGN COST \$ 29,616
D. SALVAGE VALUE - \$
E. TOTAL INVESTMENT (1A + 1B + 1C - 1D) \$ 550,369

2. ENERGY SAVINGS (+) / COST (-)
ANALYSIS DATE ANNUAL SAVINGS, UNIT COST AND DISCOUNTED SAVINGS

	FUEL	COST \$/MBTU/YR(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS (5)
A. ELEC		\$ <u> </u>		\$ <u> </u>		\$ <u> </u>
B. DIST		\$ <u>7.43</u>	<u>15,657</u>	\$ <u>116,332</u>	<u>18.26</u>	\$ <u>2,124,222</u>
C. RESID		\$ <u>6.62</u>		\$ <u> </u>		\$ <u> </u>
D. NG		\$ <u>5.33</u>	<u>-14,050</u>	\$ <u>-74,887</u>	<u>19.38</u>	\$ <u>-1,451,310</u>
E. COAL		\$ <u> </u>		\$ <u> </u>		\$ <u> </u>
F. TOTAL			<u>1,607</u>	\$ <u>41,445</u>		\$ <u>672,912</u>

3. NONENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)
(1) DISCOUNT FACTOR (TABLE A) 12.97 MAINT. → \$ 590
(2) DISCOUNTED SAVING/COST (3A X 3A1) \$ 7,652

B. NONRECURRING SAVINGS (+) / COST (-)

ITEM	SAVINGS (+) COST (-)(1)	YEAR OF OCCUR.(2)	DISCOUNT FACTOR(3)	DISCOUNTED SAV- INGS(+) COST(-)(4)
REPL.				
(1) OIL WH	\$ <u>152,810</u>	<u>10</u>	<u>0.63</u>	\$ <u>96,270</u>
(2) GAS WH	\$ <u>-98,235</u>	<u>10</u>	<u>0.63</u>	\$ <u>-61,888</u>
(3)	\$ <u> </u>			\$ <u> </u>
(4) TOTAL	\$ <u>54,575</u>			\$ <u>34,382</u>

C. TOTAL NONENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 42,034

D. PROJECT NONENERGY QUALIFICATION TEST

(1) 25% MAX NONENERGY CALC (2F5 x .33) \$ 222,061
a. IF 3D1 IS = OR > 3C GO TO ITEM 4
b. IF 3D1 IS < 3C CALC S1R = (2F5+3D1) - 1E =
c. IF 3D1 IS = > 1 GO TO ITEM 4
d. IF 3D1 IS < 1 PROJECT DOES NOT QUALIFY

4. FIRST YEAR DOLLAR SAVINGS 2F3 + 3A + (3B1d ÷ YEARS ECONOMIC LIFE) \$ 44,764

5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C) \$ 714,946

6. DISCOUNTED SAVINGS RATION (IF < 1 PROJECT DOES NOT QUALIFY) (S1R) = (5÷1E) = 1.3

SIMPLE PAYBACK PERIOD (YEARS) = 12.3


BUILDINGS 401 TO 432
ROSSELL VILLAGE
(TYPICALS)

400 AREA (ROSSELL VILLAGE)

Fuel Conversion:

Description - Existing oil-fired boilers used for heating and oil-fired water heaters are proposed to be replaced by gas-fired boilers and water heaters respectively.

Energy Saved	= -325	MBTU/year
Cost	= \$181,839	(incl. SIOH)
SIR	= 0.69	



Rossell Village - Buildings 401 to 432

Bldg No.	Location	Bed-rooms	Sq Ft	Year
401 A	Fries Place	4	1,849	55
B	Fries Place	4	1,849	55
402 A	Fries Place	4	1,849	55
B	Fries Place	4	1,849	55
403 A	Fries Place	4	1,849	55
B	Fries Place	4	1,849	55
404 A	Fries Place	4	1,849	55
B	Fries Place	4	1,849	55
405 A	Fries Place	4	1,849	55
B	Fries Place	4	1,849	55
406 A	Fries Place	4	2,089	55
B	Fries Place	4	2,089	55
407 A	Caldwell Place	4	2,089	55
B	Caldwell Place	4	2,089	55
408 A	Caldwell Place	4	2,089	55
B	Caldwell Place	4	2,089	55
409 A	Caldwell Place	4	2,089	55
B	Caldwell Place	4	2,089	55
410 A	Caldwell Place	4	2,089	55
B	Caldwell Place	4	2,089	55
411 A	Caldwell Place	4	2,089	55
B	Caldwell Place	4	2,089	55
412 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55
413 A	Presnell Place	4	2,089	55
B	Presnell Place	4	2,089	55
414 A	Presnell Place	4	2,089	55
B	Presnell Place	4	2,089	55
415 A	Rossell Place	4	2,089	55
B	Rossell Place	4	2,089	55
416 A	Rossell Place	4	2,089	55
B	Rossell Place	4	2,089	55
417 A	Rossell Place	4	2,089	55
B	Rossell Place	4	2,089	55
418 A	Lacey Place	4	2,089	55
B	Lacey Place	4	2,089	55
419 A	Lacey Place	4	2,089	55
B	Lacey Place	4	2,089	55
421 A	Lacey Place	4	2,089	55
B	Lacey Place	4	2,089	55
423 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55
424 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55
425 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55

Bldg No.	Location	Bed- rooms	Sq Ft	Year
426 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55
427 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55
428 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55
429 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55
430 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55
431 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55
432 A	Rossell Loop	4	2,089	55
B	Rossell Loop	4	2,089	55

400 AREA (ROSSELL VILLAGE)

TABLE OF CONTENTS

Input Data	4
Output Data	25
ECIP Analysis	
Energy Savings	38
Cost Summary	39-45
LCC Analysis	47

DESIGN PARAMETERS, SHGs

Location : Fort Belvoir, Virginia
 Prepared By : E A C, PC BURKE, VA.
 Carrier Hourly Analysis Program

01-23-91
 6100190202
 Page 1 of 1

DESIGN WEATHER PARAMETERS

City Name.....: Fort Belvoir
 Location.....: Virginia
 Latitude.....: 38.7 deg
 Elevation.....: 69.0 ft
 Summer Design Dry Bulb Temp.....: 90.0 F
 Summer Design Wet Bulb Temp.....: 75.0 F
 Daily Temperature Range.....: 23.0 F
 Winter Design Dry Bulb Temp.....: 12.0 F
 Atmospheric Clearness Number.....: 1.00

TABLE 1. MAXIMUM SOLAR HEAT GAINS - AVERAGE DAYS
 (BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	24.2	61.9	98.8	111.9	98.8	61.9	24.2	24.2	80.1
Feb	31.7	75.4	106.8	115.1	106.8	75.4	31.7	31.7	107.3
Mar	40.7	87.4	107.7	108.9	107.7	87.4	40.7	40.7	136.8
Apr	59.9	97.6	104.8	97.9	104.8	97.6	59.9	49.2	164.2
May	74.7	103.1	98.7	84.7	98.7	103.1	74.7	54.9	181.6
Jun	84.9	109.2	97.9	79.8	97.9	109.2	84.9	57.8	194.9
Jul	80.4	106.6	98.5	82.0	98.5	106.6	80.4	56.4	189.0
Aug	69.0	104.2	106.2	95.1	106.2	104.2	69.0	52.1	177.5
Sep	52.3	99.7	115.4	112.4	115.4	99.7	52.3	45.3	158.1
Oct	36.3	88.9	118.8	124.1	118.8	88.9	36.3	36.3	128.3
Nov	26.6	67.2	103.2	114.9	103.2	67.2	26.6	26.6	89.5
Dec	21.3	53.7	89.1	102.7	89.1	53.7	21.3	21.3	68.5

TABLE 2. MAXIMUM SOLAR HEAT GAINS - DESIGN DAYS
 (BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	20.2	157.9	243.4	253.9	243.4	157.9	20.2	20.2	140.3
Feb	52.5	188.6	246.3	238.2	246.3	188.6	52.5	24.6	186.3
Mar	95.5	219.4	234.8	201.8	234.8	219.4	95.5	29.3	227.8
Apr	141.3	224.3	200.7	148.1	200.7	224.3	141.3	34.1	255.2
May	165.9	220.1	171.5	106.1	171.5	220.1	165.9	37.3	267.4
Jun	173.0	215.4	157.5	89.2	157.5	215.4	173.0	47.4	269.3
Jul	163.5	215.7	167.2	102.9	167.2	215.7	163.5	38.2	264.2
Aug	136.2	216.5	193.7	143.1	193.7	216.5	136.2	35.7	250.5
Sep	89.8	206.8	224.9	195.9	224.9	206.8	89.8	30.4	220.2
Oct	51.4	182.2	238.2	231.2	238.2	182.2	51.4	25.4	183.0
Nov	20.6	155.1	239.4	250.0	239.4	155.1	20.6	20.6	139.7
Dec	18.3	140.7	235.7	254.0	235.7	140.7	18.3	18.3	120.5

STATE	Station	WINTER DESIGN DATA HEATING				DEGREE DAYS	SUMMER DESIGN DATA AIR CONDITIONING										SUMMER CRITERIA DA AIR CONDITIONING								
		LOCATION		Elev feet	Dry Bulb			Dry Bulb					Wet Bulb		Dry Bulb		Wet Bulb		hrs	hrs					
		Lat	Long					1% MCWB	2.5% MCWB		Mean Daily Range	Pvg Wind	1% MCWB	5% MCWB	≥ 93°F	≥ 80°F	≥ 73°F	≥ 67°F							
					°F	°F	dir	knots	annual	Heating	°F	°F	°F	°F	°F	°F	°F	°F	hrs	hrs					
UTAH (CONT)																									
	Ogden MAP	N 41 12	112 01	4455	1	5	S	6	6012	93 63	91 61	26	SW	88 61	66 65	64			37	727	0	19			
	Provo	N 40 13	111 43	4448	1	6	SE	5	5720	98 62	96 62	32	SW	94 61	66 65	64			185	989	0	26			
	Salt Lake City IAP	N 40 46	111 58	4220	3	8	SSE	6	5983	97 62	95 62	32	N	92 61	66 65	64			139	932	0	26			
	Tooele Army Depot	N 40 31	112 25	4700	4	7	SE	4	5941	93 61	91 61	24	N	88 60	65 64	63			41	704	0	5			
	Utah Army Depot	N 41 15	112 00	4270	2	6	S	6	6012	94 63	92 61	26	SW	89 61	66 65	64			59	849	0	19			
	Wendover AF Range	N 40 44	114 02	4237	8	12	ENE	4	5673	97 60	95 59	25	E	93 59	65 64	62			158	1144	0	4			
VERMONT																									
	Burlington IAP	N 44 28	73 09	332	-12	-7	E	7	7876	88 72	85 70	24	SSW	82 69	74 72	71			4	263	67	546			
	St Albans AFS	N 44 46	73 03	1310	-17	-11	E	9	8790	85 70	82 68	24	SSW	79 67	72 70	69			1	119	21	307			
VIRGINIA																									
	Arlington Hall	N 38 52	77 06	200	13	17	WNW	11	4211	94 75	91 74	21	S	89 74	78 77	76			55	815	580	1744			
	Bedford AFS	N 37 31	79 30	4220	-3	1	NW	9	7382	82 66	80 66	22	SW	77 65	69 68	67			0	87	0	216			
	Cameron Station	N 38 48	77 07	60	13	17	WNW	11	4211	94 75	91 74	21	S	89 74	78 77	76			55	815	580	1744			
	Camp A P Hill	N 38 08	77 21	230	10	14	NW	6	4398	96 77	93 76	21	S	90 75	80 78	77			90	897	710	1884			
	Camp Pickett/Blackstone AAF	N 37 05	77 57	390	15	19	NW	6	3841	95 77	92 76	22	SW	90 76	79 78	77			66	905	804	2086			
	Cape Charles AFS	N 37 08	75 57	13	20	23	N	11	3474	90 77	88 76	17	SW	86 75	79 78	77			0	596	856	2184			
	Charlottesville	N 38 02	78 31	870	14	18	NE	7	4162	94 74	91 74	23	SW	88 73	77 76	75			54	964	376	1544			
	Dahlgren NAVSURFWPNCEN	N 38 20	77 02	21	10	14	NW	6	4498	93 77	91 76	21	S	89 75	80 78	77			39	892	710	1884			
	Dam Neck	N 36 47	75 57	10	19	22	N	11	3639	91 77	89 76	17	SW	87 75	79 78	77			12	708	856	2184			
	Dulles IAP	N 38 57	77 27	313	7	11	NW	9	5010	93 74	90 73	23	S	88 73	77 76	75			28	749	386	1417			
	Fort Belvoir/Davison AAF	N 38 43	77 11	69	8	12	NW	9	4891	92 76	90 75	23	S	88 74	78 77	76			23	781	551	1668			
	Fort Eustis/Felker AAF	N 37 08	76 37	12	17	20	N	10	3752	92 77	90 76	17	SSW	88 75	80 78	77			26	875	807	2065			
	Fort Lee	N 37 14	77 21	145	14	17	N	6	3939	95 76	92 76	22	SW	90 75	79 78	77			70	932	765	1973			
	Fort Lee AFS	N 37 14	77 20	75	14	17	N	6	3939	95 76	92 76	22	SW	90 75	79 78	77			70	932	765	1973			
	Fort Monroe	N 37 00	76 19	15	17	20	NW	9	3623	92 78	90 77	17	SW	87 76	79 78	77			21	809	1010	2290			
	Fort Myer	N 38 53	77 05	220	14	17	WNW	11	4211	93 75	91 74	19	S	89 74	78 77	76			41	910	580	1744			
	Fort Story	N 36 56	76 00	13	19	22	N	11	3639	91 77	89 76	17	SW	87 75	79 78	77			12	708	856	2184			
	Langley AFB/Hampton	N 37 05	76 21	10	17	20	NW	9	3623	92 78	90 77	17	SW	87 76	79 78	77			21	809	1010	2290			
	Little Creek NAVPHIBASE	N 36 54	76 09	15	20	22	NW	10	3488	93 77	91 76	19	SW	89 76	79 78	77			41	874	961	2238			
	Lynchburg MAP	N 37 20	79 12	916	12	16	NE	7	4233	93 74	90 74	23	SW	88 73	77 76	75			31	696	376	1544			
	Manassas/Davis Field	N 38 43	77 31	186	10	14	NW	6	4398	96 76	93 75	22	S	90 74	78 77	76			90	897	548	1650			
	Newport News/Patrick Henry	N 37 08	76 30	41	17	20	NW	9	3549	92 78	90 77	17	SW	87 76	79 78	77			21	809	1010	2290			
	Norfolk	N 36 54	76 12	22	20	22	NW	10	3488	93 77	91 76	19	SW	89 76	79 78	77			41	874	961	2238			

U-VALUE CALCULATION FORM

FOR ROOF/FLOOR

Project: Roswell Village, Fort Belvoir

EAC Project Number: 89034.01 Date: August 1990 By: JB

☒ Roof

☐ Floor

Material	Resistance (h-sq. ft.-F/Btu)	
	Summer	Winter
1. <u>Top Surface (Moving Air)</u>	<u>0.25</u>	<u>0.61</u>
2. <u>Bottom Surface (Still Air)</u>		<u>0.61</u>
3. <u>INSULATION</u>		<u>30.00</u>
4. <u>PLASTER</u>		<u>0.45</u>
5. _____		
6. _____		
7. _____		
8. _____		
Total (R) =		<u>31.67</u>
U = 1/R =		<u>0.032</u>

(Btu/h-sq.ft. - F)

MATERIAL	DIRECTION OF HEAT FLOW	R*	MATERIAL	R*
Air Space 3/4" (0 F)	UP	0.93	Batt/Blanket	
Air Space 4"	UP	1.03	2-2 3/4 in.	7.00
Air Space 3/4" (90 F)	DN	0.85	3-4 in.	11.00
Air Space 4"	DN	1.00	3.5 in.	13.00
Still Air	UP	0.61	5.5-6.5 in.	19.00
Still Air	DN	0.92	6-7.5 in.	22.00
Moving Air 7 1/2 MPH	ANY	0.25	9-10 in.	30.00
Moving Air 15 MPH	ANY	0.17	12-13 in.	38.00
Acoustical Tile 1/2"		1.25	Rigid Insul. 1"	2.78
Acoustical Tile 3/4"		1.89	Stryfoam 1"	4.00
Sand Plaster 3/8"		0.08	Built-up Roof 3/8"	0.33
Gypsum Plaster 1/2"		0.45	Asphalt Shingles	0.44

*(h-sq.ft. - F/Btu)

U-VALUE CALCULATION FORM

FOR WALL/PARTITION

Project: ROSSELL VILLAGE, FORT BELVOIR

EAC Project Number: 89034.01 Date: AUGUST, 1990 By: JB

☒ Wall

☐ Partition

Material	Resistance (h-ft ² - F/Btu)	
	Summer	Winter
1. <u>Outside Air</u>	<u>0.25</u>	<u>0.17</u>
2. <u>Inside Still Air</u>	<u>0.68</u>	<u>0.68</u>
3. <u>4" FACE BRICK</u>		<u>0.44</u>
4. <u>4" CINDER BLOCK</u>		<u>1.11</u>
5. <u>PLASTER</u>		<u>0.45</u>
6. _____		
7. _____		
8. _____		
Total (R) =		<u>2.85</u>
U = 1/R =		<u>0.351</u>

(Btu/h-sq.ft. - F)

MATERIAL	R*	MATERIAL	R*
Air Space 3/4" (90 F)	0.84	Blanket/Batt Insul.	
Air Space 3/4" (0 F)	1.18	2-2 3/4 in.	7.00
Still Air	0.68	3-4 in.	11.00
Moving Air 7 1/2 MPH	0.25	3.5 in.	13.00
Moving Air 15 MPH	0.17	5.5-6.5 in.	19.00
Face Brick 4"	0.44	6-7.5 in.	22.00
Cinderblock 4"	1.11	9-10 in.	30.00
Cinderblock 8"	1.72	12-13 in.	38.00
Cinderblock 12"	1.89	Rigid Insul. 1"	2.78
Gypsum Bd 3/8"	0.32	Styrofoam 1"	4.00
Gypsum Bd 1/2"	0.45	Vermiculite 1"	2.27
Gypsum Plaster 1/2"	0.45	Vapor Barr.-felt	0.06
Sand Plaster 3/8"	0.08	Fir, Pine & Simil.	
Loose Fill Sandust 1"	2.22	Woods 3/4"	0.94
Perlite Expanded 1"	2.90		

*(h-sq.ft. - F/Btu)

ENGINEERING ANALYSIS

Sheet 1 of 1

By: JP

Calculations for Infiltration

Rosell Village - Tyndall

Project: ESOS, Fort Belvoir Date: August, 1990

Contract No: DACA-31-89-C-0189 EAC Project No.: 89034.01

Calculations based on ASHRAE 1989 Page F 23.14.

Building Leakage Area

	Effective Leakage Area, in ²	Building Component Parameter	Building Leakage Area D _L , in ²
	L _L	D _L	L
Sill foundation	0.19/ft. of perimeter	200 ft.	38
Joints, ceiling/wall	0.12/ft. of wall	200 ft.	24
Windows	0.063/ft ² . of window	438 ft ² .	28
Doors	0.215/ft ² . of doors	140 ft ² .	30
Wall - Window frames	0.15/ft ² . of window	438 ft ² .	66
- Door frames	0.072/ft ² . of door	140 ft ² .	10
Elec. outlet/switch	0.16/ switch outlet	50 switch out.	8
Recessed lights	1.6/fixture	6 fix.	13
Pipe penetration	0.155 3.84 /in ² . of pipe	4 fix.	1
Exhaust Fans	6.0/fan	40 4	240
Duct penetration	2.2/67	1057	22
			<u>242</u>

$$\begin{aligned} \text{Infiltration } Q(\text{cfm}) &= L \times (A \Delta t + B v^2)^{1/2} \\ &= L(0.0313 \times 51 + 0.0157 \times 14^2)^{1/2} \\ &= L \times 2.2 = 242 \times 2.2 = 532 \text{ CFM} \end{aligned}$$

$$\begin{aligned} \text{Infiltration through walls} &= 0.1 \times 360 (\text{SF}) \\ &= 360 \text{ CFM} \end{aligned}$$

⁹²
(ASHRAE 1989, p. 23.17)

$$\text{Total Infiltration} = 532 + 360 = 892 \text{ CFM}$$

$$\begin{aligned} \text{Infiltration Rate} &= \frac{892}{4102} = 0.217 \approx 0.2 \text{ CFM/SF} \end{aligned}$$

MASTER SCHEDULE SUMMARY

Page 1

Prepared By : E A C

04-15-91

Carrier Hourly Analysis Program

6100190202

MASTER SCHEDULE 1. OCCUPANCY

Hourly Percentages

Hour ---->	0	1	2	3	4	5	6	7	8	9	10	11
Weekday	100	100	100	100	100	100	100	50	30	30	30	30
Saturday	100	100	100	100	100	100	100	100	100	100	100	100
Sunday	100	100	100	100	100	100	100	100	100	100	100	100
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100
Hour ---->	12	13	14	15	16	17	18	19	20	21	22	23
Weekday	50	30	30	30	30	50	70	100	100	100	100	100
Saturday	100	100	100	100	100	100	100	100	100	100	100	100
Sunday	100	100	100	100	100	100	100	100	100	100	100	100
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

MASTER SCHEDULE SUMMARY

Page 1

Prepared By : E A C

04-15-91

Carrier Hourly Analysis Program

6100190202

MASTER SCHEDULE 2. HOT WATER

Hourly Percentages

Hour ----->	0	1	2	3	4	5	6	7	8	9	10	11
-------------	---	---	---	---	---	---	---	---	---	---	----	----

Weekday	10	3	1	1	1	1	3	15	65	70	85	70
Saturday	10	3	1	1	1	1	3	15	65	70	85	70
Sunday	10	3	1	1	1	1	3	15	65	70	85	70
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

Hour ----->	12	13	14	15	16	17	18	19	20	21	22	23
-------------	----	----	----	----	----	----	----	----	----	----	----	----

Weekday	60	55	50	45	40	45	50	60	75	70	65	60
Saturday	60	55	50	45	40	45	50	60	75	70	65	60
Sunday	60	55	50	45	40	45	50	60	75	70	65	60
DESIGN	100	100	100	100	100	100	100	100	100	100	100	100

PROJECTED NAVFAC COST INDEX
MONTHLY
JULY 1989

YEAR	JAN.	FEB.	MAR.	APR.	MAY.	JUNE	JULY	AUG.	SEPT.	OCT.	NOV.	DEC.
1974	1156	1154	1155	1177	1177	1199	1233	1240	1238	1246	1239	1240
1975	1242	1265	1265	1269	1287	1307	1317	1330	1333	1351	1349	1354
1976	1362	1370	1378	1391	1398	1416	1425	1455	1467	1476	1479	1484
1977	1489	1499	1504	1506	1507	1521	1539	1554	1587	1617	1603	1606
1978	1609	1617	1620	1621	1652	1663	1696	1705	1720	1721	1732	1734
1979	1740	1740	1750	1749	1753	1809	1829	1849	1900	1899	1902	1909
1980	1895	1894	1915	1899	1888	1916	1950	1971	1976	1981	2000	2017
1981	2015	2016	2014	2064	2076	2083	2109	2118	2139	2156	2186	2184
1982	2184	2200	2195	2195	2220	2219	2233	2253	2249	2248	2260	2295
1983	2311	2348	2352	2347	2351	2388	2414	2428	2430	2416	2419	2406
1984	2402	2407	2412	2422	2419	2417	2418	2428	2430	2424	2421	2408
1985	2410	2414	2406	2405	2411	2429	2448	2442	2440	2441	2446	2439
1986	2440	2446	2447	2458	2479	2493	2499	2498	2504	2511	2511	2511
1987	2515	2510	2518	2523	2524	2525	2538	2557	2565	2569	2564	2589
1988	2574	2576	2586	2591	2592	2595	2598	2611	2612	2612	2616	2617
1989	2619	2613	2616	2620	2621	2626	2633	2640	2648	2655	2663	2670
1990	2677	2683	2690	2697	2704	2710	2717	2724	2731	2738	2744	2751
1991	2757	2763	2769	2776	2782	2788	2794	2800	2806	2812	2819	2825
1992	2830	2835	2840	2845	2850	2855	2861	2866	2871	2876	2881	2886
1993	2891	2896	2900	2905	2910	2914	2919	2924	2928	2933	2938	2942

ANNUAL MARK-UP FACTORS FOR ESCALATION
(BEYOND FY 93, USE 1.80% ESCALATION COMPOUNDED EACH YEAR)

FISCAL-YEAR	4-87	4-88	4-89	4-90	4-91	4-92	4-93	4-94	4-95
4-83	1.07	1.10	1.12	1.15	1.18	1.21	1.24	1.26	1.28
4-84	1.04	1.07	1.08	1.11	1.15	1.17	1.20	1.22	1.24
4-85	1.05	1.08	1.09	1.12	1.15	1.18	1.21	1.23	1.25
4-86	1.03	1.05	1.07	1.10	1.13	1.16	1.18	1.20	1.22
4-87	1.00	1.03	1.04	1.07	1.10	1.13	1.15	1.17	1.19
4-88	0.97	1.00	1.01	1.04	1.07	1.10	1.12	1.14	1.16
4-89	0.96	0.99	1.00	1.03	1.06	1.09	1.11	1.13	1.15
4-90	0.94	0.96	0.97	1.00	1.03	1.05	1.08	1.10	1.12
4-91	0.91	0.93	0.94	0.97	1.00	1.02	1.05	1.07	1.08
4-92	0.89	0.91	0.92	0.95	0.98	1.00	1.02	1.04	1.06
4-93	0.87	0.89	0.90	0.93	0.96	0.98	1.00	1.02	1.04

NOTE: Escalation rate change to be 1.80% after 1993.

Figure 9
Projected NAVFAC Cost Index

STUDY PARAMETER INPUT PRINTOUT

Prepared By : E A C
Advanced Engineering Economic Analysis Program

05-01-91
60901891.00
Page 1 of 1

STUDY CRITERIA

ECIP - FEMP/10CFR436A (Army TM 5-802-1, Para. 2-3&4)

Discount Rate	:	7.0 %
Investment Credit	:	10.0 %
Payment Time	:	1.0 (1 = end of year)

KEY STUDY DATES

ECIP Economic Life : 15 (years)

ENERGY RELATED STUDY PARAMETERS

State : VA
Prices of Electricity : 18.05
Distillate Oil : 7.43
Residual Oil : 6.62
Natural Gas : 5.33
Coal : 0.00

Prices are specified in \$ / Million BTU, FEMP Date (JUL 1988)

STUDY IDENTIFICATION BLOCK

Project Title : FORT BELVOIR E.S.O.S
Installation Name : ROSSELL VILLAGE
Project Number : DACA-31-89-C-0198
Fiscal Year : 1991
Name of Analyst : E A C, P.C. Burke, Va.

SIMPLE SPACE DESCRIPTION

Space Name : Rossell Village type 1

04-15-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	1.00
Color :	M	M		Internal Shades :	? N

People : sqft/person = 500.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = Rossell Village type 1

		Floor Area :	1,849.0 sqft
Exposure :	E	W Roof Area :	924.0 sqft
Wall Area :	632.0	598.0 Current	
Glass Area :	90.0	99.0 Elements :	Pt,Wl,Gl,Gr,In

ADDITIONAL ELEMENT - Partition

Area =	600.0 sqft	Uncond. Space Temp:Cooling =	90.0 F
U-Value =	0.543 BTU/hr/sqft/F	Uncond. Space Temp:Heating =	50.0 F

ADDITIONAL ELEMENT - Wall

Weight =	M (lb/sqft)	Exposure =	S
Color =	M	Net Area =	338.0 sqft
U-Value =	0.351 BTU/hr/sqft/F		

ADDITIONAL ELEMENT - Glass

U-Value =	0.550 BTU/hr/sqft/F	Exposure =	S
Glass Factor =	0.90	Area =	45.0 sqft
Internal Shades ?	N		

ADDITIONAL ELEMENT - Ground

Slab Floor Area =	324.0 sqft
Perimeter =	45.0 ft
Depth =	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling :	0.22 CFM/sqft =	407 CFM
Heating :	0.22 CFM/sqft =	407 CFM
Typical :	0.22 CFM/sqft =	407 CFM

SIMPLE SPACE DESCRIPTION

Space Name : Rossell Village type 2

04-15-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	1.00
Color :	M	M		Internal Shades :	N

People : sqft/person = 500.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = Rossell Village type 2

Exposure :	E	W	Floor Area :	1,849.0 sqft
Wall Area :	632.0	598.0	Roof Area :	924.0 sqft
Glass Area :	90.0	99.0	Current Elements :	Pt,Wl,Gl,Gr,In

ADDITIONAL ELEMENT - Partition

Area = 250.0 sqft Uncond. Space Temp:Cooling = 90.0 F
 U-Value = 0.543 BTU/hr/sqft/F Uncond. Space Temp:Heating = 50.0 F

ADDITIONAL ELEMENT - Wall

Weight =	M (lb/sqft)	Exposure =	S
Color =	M	Net Area =	338.0 sqft
U-Value =	0.351 BTU/hr/sqft/F		

ADDITIONAL ELEMENT - Glass

U-Value =	0.550 BTU/hr/sqft/F	Exposure =	S
Glass Factor =	0.90	Area =	45.0 sqft
Internal Shades ?	N		

ADDITIONAL ELEMENT - Ground

Slab Floor Area =	674.0 sqft
Perimeter =	65.0 ft
Depth =	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling :	0.22 CFM/sqft =	407 CFM
Heating :	0.22 CFM/sqft =	407 CFM
Typical :	0.22 CFM/sqft =	407 CFM

SIMPLE SPACE DESCRIPTION

Space Name : Rossell Village type 3

04-15-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	1.00
Color :	M	M		Internal Shades :	N

People : sqft/person = 500.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = Rossell Village type 3

		Floor Area :	2,089.0 sqft
Exposure :	E	W Roof Area :	1,044.0 sqft
Wall Area :	723.0	Current	
Glass Area :	90.0	Elements :	Pt,Wl,Gl,Gr,In

ADDITIONAL ELEMENT - Partition

Area = 600.0 sqft Uncond. Space Temp:Cooling = 90.0 F
 U-Value = 0.543 BTU/hr/sqft/F Uncond. Space Temp:Heating = 50.0 F

ADDITIONAL ELEMENT - Wall

Weight = M (lb/sqft) Exposure = S
 Color = M Net Area = 338.0 sqft
 U-Value = 0.351 BTU/hr/sqft/F

ADDITIONAL ELEMENT - Glass

U-Value = 0.550 BTU/hr/sqft/F Exposure = S
 Glass Factor = 0.90 Area = 45.0 sqft
 Internal Shades ? N

ADDITIONAL ELEMENT - Ground

Slab Floor Area = 444.0 sqft
 Perimeter = 45.0 ft
 Depth = 0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling : 0.22 CFM/sqft = 460 CFM
 Heating : 0.22 CFM/sqft = 460 CFM
 Typical : 0.22 CFM/sqft = 460 CFM

SIMPLE SPACE DESCRIPTION

Space Name : Rossell Village type 4

04-15-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	1.00
Color :	M	M		Internal Shades ?	N

People : sqft/person = 500.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = Rossell Village type 4

Exposure :	E	W	Floor Area :	2,089.0 sqft
Wall Area :	723.0	689.0	Roof Area :	1,044.0 sqft
Glass Area :	90.0	99.0	Current	
			Elements :	Pt,Wl,Gl,Gr,In

ADDITIONAL ELEMENT - Partition

Area =	250.0 sqft	Uncond. Space Temp:Cooling =	90.0 F
U-Value =	0.543 BTU/hr/sqft/F	Uncond. Space Temp:Heating =	50.0 F

ADDITIONAL ELEMENT - Wall

Weight =	M (lb/sqft)	Exposure =	S
Color =	M	Net Area =	338.0 sqft
U-Value =	0.351 BTU/hr/sqft/F		

ADDITIONAL ELEMENT - Glass

U-Value =	0.550 BTU/hr/sqft/F	Exposure =	S
Glass Factor =	0.90	Area =	45.0 sqft
Internal Shades ?	N		

ADDITIONAL ELEMENT - Ground

Slab Floor Area =	794.0 sqft
Perimeter =	65.0 ft
Depth =	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling :	0.22 CFM/sqft =	460 CFM
Heating :	0.22 CFM/sqft =	460 CFM
Typical :	0.22 CFM/sqft =	460 CFM

DESIGN SPACE HEATING LOADS

Location : Fort Belvoir, Virginia

04-15-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building 401

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 12.0 F

Space Name		Mult	Space Sensible (BTU/hr/space)	Water Flow (gpm/space)
Rossell Village type 1	x	1	78,884.9	6.4
Rossell Village type 2	x	1	75,995.9	6.1

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia

04-15-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building 401

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	61,641
ROOF TRANSMISSION	3,312
GLASS TRANSMISSION	14,414
TRANSMISSION LOSS TO UNCOND. SPACES	8,308
INFILTRATION LOSS	49,080
SLAB FLOOR	4,045
HEATING SAFETY BTU/hr	14,080
SUB-TOTAL	154,881
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	154,881
HOT WATER TEMPERATURE DROP	25.0 deg F
ZONE BASEBOARD WATER FLOW	12.47 gpm
VENTILATION PREHEAT WATER FLOW	0.00 gpm
TOTAL WATER FLOW REQ'D	12.47 gpm
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

PLANT DESCRIPTIONS

Plant : Building 401 Oil

04-20-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Individual Plants

Name = Building 401 Oil

Cooling Plant Type = User Defined

Heating Plant Type = Combustion

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Building 401	1		

3a COOLING PLANT DATA (User Defined)

Estimated maximum cooling coil load = 0.00 Ton

Nominal capacity = 0.00 Ton

Nominal input power rate = 0.000 kW/Ton

Type of cooling = DX

Condenser type = Air Cooled

PART LOAD PERFORMANCE

% Load	% Power	% Load	% Power	% Load	% Power
90 -----	100	60 -----	100	30 -----	100
80 -----	100	50 -----	100	20 -----	100
70 -----	100	40 -----	100	10 -----	100

3b HEATING PLANT DATA (Combustion)

Estimated maximum heating coil load = 140.80 MBH

Fuel type = Fuel Oil

Rated plant output = 229.6 MBH

Type of heating = Hydronic

Is plant efficiency computer generated ? N

Seasonal plant efficiency = 70 %

4 PUMP SYSTEM DATA

Hot water pumping system head = 20.00 ft wg

Hot water pumping system delta T = 20.00 F

BUILDING DESCRIPTION

Building : Building 401 Oil
 Prepared By: E A C
 Carrier Hourly Analysis Program

04-23-91
 6100190202
 Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = Building 401 Oil

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW
 Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y
 Maximum hourly hot water use = 14.0 gal
 Hot water schedule = 2
 Average entering water temperature = 57.0 F
 Average hot water supply temperature = 140.0 F
 Heating plant type = 2 : Combustion
 Fuel type = 2 : Fuel Oil
 Plant capacity = 180.0 MBH
 Is plant efficiency computer generated ? N
 Annual plant efficiency = 62 %

OTHER INPUTS

Additional building floor area = 0.0 sqft
 Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
Building 401 Oil	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	2	ELECTRIC (generic)	MBTU
Natural Gas	3	NATURAL GAS (generic)	MBTU
Fuel Oil	4	DISTILLATE FUEL OIL (generic)	MBTU
Propane	8	Propane (generic)	MBTU
Remote Source Heating	9	Remote source heating (generic)	MBTU
Remote Source Cooling	10	Remote Source Cooling (generic)	MBTU

ANNUAL COMPONENT COSTS

Building : Building 401 Oil
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-23-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	0	0.000	0.0 %
Cooling Plants	0	0.000	0.0 %
Heating Plants	156	0.042	72.4 %
Pumps	1	0.000	0.7 %
>>> HVAC Subtotal	157	0.043	73.1 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	58	0.016	26.9 %
>>> Non-HVAC Sub-total	58	0.016	26.9 %
>>> GRAND TOTAL	215	0.058	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 3,698 sqft
 Conditioned floor area = 3,698 sqft

ANNUAL ENERGY COSTS

Building : Building 401 Oil
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-23-91
 6100190202

Page 1 of 1

Carrier Hourly Analysis Program

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<--- Annual Costs * --->		% of Total
		(MBTU)	(MBTU/sqft)	
Electric	418 kWh	1	0.000	0.7 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	1124 gallon	156	0.042	72.4 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		157	0.043	73.1 %
Non-HVAC Component				
Electric	0 kWh	0	0.000	0.0 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	418 gallon	58	0.016	26.9 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		58	0.016	26.9 %
=====				
>>> GRAND TOTAL		215	0.058	100.0 %
=====				

* Note: 1. Cost per unit floor area is based on the gross building floor area. For this building:

Gross floor area = 3,698 sqft
 Conditioned floor area = 3,698 sqft

PLANT DESCRIPTIONS

Plant : Building 401 Gas

04-23-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Individual Plants
Name = Building 401 Gas
Cooling Plant Type = User Defined
Heating Plant Type = Combustion

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Building 401	1		

3a COOLING PLANT DATA (User Defined)

Estimated maximum cooling coil load = 0.00 Ton
Nominal capacity = 0.00 Ton
Nominal input power rate = 0.000 kW/Ton
Type of cooling = DX
Condenser type = Air Cooled

PART LOAD PERFORMANCE

% Load	% Power	% Load	% Power	% Load	% Power
90 -----	100	60 -----	100	30 -----	100
80 -----	100	50 -----	100	20 -----	100
70 -----	100	40 -----	100	10 -----	100

3b HEATING PLANT DATA (Combustion)

Estimated maximum heating coil load = 140.80 MBH
Fuel type = Natural Gas
Rated plant output = 229.6 MBH
Type of heating = Hydronic
Is plant efficiency computer generated ? N
Seasonal plant efficiency = 66 %

4 PUMP SYSTEM DATA

Hot water pumping system head = 20.00 ft wg
Hot water pumping system delta T = 20.00 F

BUILDING DESCRIPTION

Building : Building 401 Gas

04-23-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = Building 401 Gas

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW

Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y

Maximum hourly hot water use = 14.0 gal

Hot water schedule = 2

Average entering water temperature = 57.0 F

Average hot water supply temperature = 140.0 F

Heating plant type = 2 : Combustion

Fuel type = 1 : Natural Gas

Plant capacity = 180.0 MBH

Is plant efficiency computer generated ? N

Annual plant efficiency = 62 %

OTHER INPUTS

Additional building floor area = 0.0 sqft

Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
Building 401 Gas	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	2	ELECTRIC (generic)	MBTU
Natural Gas	3	NATURAL GAS (generic)	MBTU
Fuel Oil	4	DISTILLATE FUEL OIL (generic)	MBTU
Propane	8	Propane (generic)	MBTU
Remote Source Heating	9	Remote source heating (generic)	MBTU
Remote Source Cooling	10	Remote Source Cooling (generic)	MBTU

ANNUAL COMPONENT COSTS

Building : Building 401 Gas
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-23-91
 6100190202

Page 1 of 1

Carrier Hourly Analysis Program

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	0	0.000	0.0 %
Cooling Plants	0	0.000	0.0 %
Heating Plants	165	0.045	73.6 %
Pumps	1	0.000	0.6 %

>>> HVAC Subtotal	167	0.045	74.2 %

Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	58	0.016	25.8 %

>>> Non-HVAC Sub-total	58	0.016	25.8 %
=====			
>>> GRAND TOTAL	225	0.061	100.0 %
=====			

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 3,698 sqft

Conditioned floor area = 3,698 sqft

ANNUAL ENERGY COSTS

Building : Building 401 Gas
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-23-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * -->		% of Total
		(MBTU)	(MBTU/sqft)	
Electric	418 kWh	1	0.000	0.6 %
Natural Gas	1653 Therms	165	0.045	73.6 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		167	0.045	74.2 %
Non-HVAC Component				
Electric	0 kWh	0	0.000	0.0 %
Natural Gas	580 Therms	58	0.016	25.8 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		58	0.016	25.8 %
=====				
>>> GRAND TOTAL		225	0.061	100.0 %
=====				

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 3,698 sqft
 Conditioned floor area = 3,698 sqft

DESIGN SPACE HEATING LOADS

Location : Fort Belvoir, Virginia

04-15-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building 406

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 12.0 F

Space Name	Mult	Space Sensible (BTU/hr/space)	Water Flow (gpm/space)
Rossell Village type 3	x 1	86,606.6	7.0
Rossell Village type 4	x 1	83,717.6	6.7

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia

04-15-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building 406

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	68,796
ROOF TRANSMISSION	3,742
GLASS TRANSMISSION	14,414
TRANSMISSION LOSS TO UNCOND. SPACES	8,308
INFILTRATION LOSS	55,451
SLAB FLOOR	4,129
HEATING SAFETY BTU/hr	15,484
SUB-TOTAL	170,324
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	170,324
HOT WATER TEMPERATURE DROP	25.0 deg F
ZONE BASEBOARD WATER FLOW	13.71 gpm
VENTILATION PREHEAT WATER FLOW	0.00 gpm
TOTAL WATER FLOW REQ'D	13.71 gpm
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

PLANT DESCRIPTIONS

Plant : Building 406 Oil

04-22-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Individual Plants
Name = Building 406 Oil
Cooling Plant Type = User Defined
Heating Plant Type = Combustion

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Building 406	1		

3a COOLING PLANT DATA (User Defined)

Estimated maximum cooling coil load = 0.00 Ton
Nominal capacity = 0.00 Ton
Nominal input power rate = 0.000 kW/Ton
Type of cooling = DX
Condenser type = Air Cooled

PART LOAD PERFORMANCE

% Load	% Power	% Load	% Power	% Load	% Power
90 -----	100	60 -----	100	30 -----	100
80 -----	100	50 -----	100	20 -----	100
70 -----	100	40 -----	100	10 -----	100

3b HEATING PLANT DATA (Combustion)

Estimated maximum heating coil load = 154.84 MBH
Fuel type = Fuel Oil
Rated plant output = 229.6 MBH
Type of heating = Hydronic
Is plant efficiency computer generated ? N
Seasonal plant efficiency = 70 %

4 PUMP SYSTEM DATA

Hot water pumping system head = 20.00 ft wg
Hot water pumping system delta T = 20.00 F

BUILDING DESCRIPTION

Building : Building 406 Oil

04-23-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = Building 406 Oil

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW

Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y

Maximum hourly hot water use = 14.0 gal

Hot water schedule = 2

Average entering water temperature = 57.0 F

Average hot water supply temperature = 140.0 F

Heating plant type = 2 : Combustion

Fuel type = 2 : Fuel Oil

Plant capacity = 180.0 MBH

Is plant efficiency computer generated ? N

Annual plant efficiency = 62 %

OTHER INPUTS

Additional building floor area = 0.0 sqft

Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
Building 406 Oil	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	2	ELECTRIC (generic)	MBTU
Natural Gas	3	NATURAL GAS (generic)	MBTU
Fuel Oil	4	DISTILLATE FUEL OIL (generic)	MBTU
Propane	8	Propane (generic)	MBTU
Remote Source Heating	9	Remote source heating (generic)	MBTU
Remote Source Cooling	10	Remote Source Cooling (generic)	MBTU

ANNUAL COMPONENT COSTS

Building : Building 406 Oil
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-23-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	0	0.000	0.0 %
Cooling Plants	0	0.000	0.0 %
Heating Plants	184	0.044	75.5 %
Pumps	2	0.000	0.6 %

>>> HVAC Subtotal	185	0.044	76.2 %

Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	58	0.014	23.8 %

>>> Non-HVAC Sub-total	58	0.014	23.8 %
=====			
>>> GRAND TOTAL	243	0.058	100.0 %
=====			

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 4,178 sqft
 Conditioned floor area = 4,178 sqft

ANNUAL ENERGY COSTS

Building : Building 406 Oil
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-23-91
 6100190202

Page 1 of 1

Carrier Hourly Analysis Program

 TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	443 kWh	2	0.000	0.6 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	1324 gallon	184	0.044	75.5 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		185	0.044	76.2 %

Non-HVAC Component

Electric	0 kWh	0	0.000	0.0 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	418 gallon	58	0.014	23.8 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		58	0.014	23.8 %

=====
 >>> GRAND TOTAL 243 0.058 100.0 %
 =====

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 4,178 sqft
 Conditioned floor area = 4,178 sqft

PLANT DESCRIPTIONS

Plant : Building 406 Gas

04-23-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Individual Plants
Name = Building 406 Gas
Cooling Plant Type = User Defined
Heating Plant Type = Combustion

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Building 406	1		

3a COOLING PLANT DATA (User Defined)

Estimated maximum cooling coil load = 0.00 Ton
Nominal capacity = 0.00 Ton
Nominal input power rate = 0.000 kW/Ton
Type of cooling = DX
Condenser type = Air Cooled

PART LOAD PERFORMANCE

% Load	% Power	% Load	% Power	% Load	% Power
90	100	60	100	30	100
80	100	50	100	20	100
70	100	40	100	10	100

3b HEATING PLANT DATA (Combustion)

Estimated maximum heating coil load = 154.84 MBH
Fuel type = Natural Gas
Rated plant output = 229.6 MBH
Type of heating = Hydronic
Is plant efficiency computer generated ? N
Seasonal plant efficiency = 66 %

4 PUMP SYSTEM DATA

Hot water pumping system head = 20.00 ft wg
Hot water pumping system delta T = 20.00 F

BUILDING DESCRIPTION

Building : Building 406 Gas

04-23-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = Building 406 Gas

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW

Power schedule = 1

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y

Maximum hourly hot water use = 14.0 gal

Hot water schedule = 2

Average entering water temperature = 57.0 F

Average hot water supply temperature = 140.0 F

Heating plant type = 2 : Combustion

Fuel type = 1 : Natural Gas

Plant capacity = 180.0 MBH

Is plant efficiency computer generated ? N

Annual plant efficiency = 62 %

OTHER INPUTS

Additional building floor area = 0.0 sqft

Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
Building 406 Gas	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	2	ELECTRIC (generic)	MBTU
Natural Gas	3	NATURAL GAS (generic)	MBTU
Fuel Oil	4	DISTILLATE FUEL OIL (generic)	MBTU
Propane	8	Propane (generic)	MBTU
Remote Source Heating	9	Remote source heating (generic)	MBTU
Remote Source Cooling	10	Remote Source Cooling (generic)	MBTU

ANNUAL COMPONENT COSTS

Building : Building 406 Gas
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-23-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	0	0.000	0.0 %
Cooling Plants	0	0.000	0.0 %
Heating Plants	195	0.047	76.6 %
Pumps	2	0.000	0.6 %
>>> HVAC Subtotal	196	0.047	77.2 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	58	0.014	22.8 %
>>> Non-HVAC Sub-total	58	0.014	22.8 %
>>> GRAND TOTAL	254	0.061	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 4,178 sqft
 Conditioned floor area = 4,178 sqft

ANNUAL ENERGY COSTS

Building : Building 406 Gas
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-23-91
 6100190202

Page 1 of 1

Carrier Hourly Analysis Program

 TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * -->		% of Total
		(MBTU)	(MBTU/sqft)	
Electric	443 kWh	2	0.000	0.6 %
Natural Gas	1947 Therms	195	0.047	76.6 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		196	0.047	77.2 %

Non-HVAC Component				
Electric	0 kWh	0	0.000	0.0 %
Natural Gas	580 Therms	58	0.014	22.8 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		58	0.014	22.8 %

>>> GRAND TOTAL		254	0.061	100.0 %
=====				

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 4,178 sqft
 Conditioned floor area = 4,178 sqft

400 AREA (ROSSELL VILLAGE)

Fuel Conversion:

Description - Existing oil-fired boilers used for heating and oil-fired water heaters are proposed to be replaced by gas-fired boilers and water heaters respectively.

Energy Saved	= -325	MBTU/year
Cost	= \$181,839	(incl. SIOH)
SIR	= 0.69	

PORT BELVOIR ROSSELL HOUSING AREA

CONSTRUCTION COSTS AND ENERGY SAVINGS CONSOLIDATION

TYPICAL BLDG	No.	ENERGY SAVINGS, MBTU/BLDG			TOTAL ENERGY SAVINGS, MBTU		
		ELEC.	OIL	GAS	ELEC.	OIL	GAS
401	5	0	214	-224	0	1070	-1120
406	25	0	184	-195	0	4600	-4875
TOTAL	30				0	5670	-5995

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

Rossell Village - TYPICAL BUILDING

Proposed conversion

Estimated cost of gas burner in existing boiler	= \$ 3,538
Estimated cost of gas-fired water heater	= \$ 647
Cost of conversion	= \$ 4,185
Total Cost of Conversion	\$ 4,185 X 30= \$ 125,750

Replacement costs

Replace boiler, retain gas burner	\$ 2,821 X 30= \$ 84,630
Gas-fired water heaters	\$ 647 X 30= \$ 19,410
Oil-fired water heaters	\$ 2,247 X 30= \$ 67,410

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Typical Building
Rossell Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 2: Replace oil burner with gas burner
Gas water heaters

Gas burner in existing boiler:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas burner	1	EA	\$210	\$210	\$795	\$795	\$1,005
Remove oil tank	1	EA	\$1,000	\$1,000	\$15	\$15	\$1,015
Valves etc.		LS	----	\$75	----	\$500	\$575
SUB-TOTAL:				\$1,285		\$1,310	\$2,595
Labor Markup: 21%				\$270		---	\$270
Taxes: 4.5%				---		\$59	\$59
SUB-TOTAL:				\$1,555		\$1,369	\$2,924
Overhead: 10%				\$155		\$137	\$292
SUB-TOTAL:				\$1,710		\$1,506	\$3,216
Profit: 10%				\$171		\$151	\$322
TOTAL:				\$1,881		\$1,656	\$3,538

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Typical Building
Rossell Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 2: Replace oil burner with gas burner
Gas water heaters

Replace boiler, retain gas burner

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Replace boiler	1	each	\$1,050	\$1,050	\$1,015	\$1,015	\$2,065
SUB-TOTAL:				\$1,050		\$1,015	\$2,065
Labor Markup: 21%				\$221		---	\$221
Taxes: 4.5%				---		\$46	\$46
SUB-TOTAL:				\$1,271		\$1,061	\$2,331
Overhead: 10%				\$127		\$106	\$233
SUB-TOTAL:				\$1,398		\$1,167	\$2,564
Profit: 10%				\$140		\$117	\$256
TOTAL:				\$1,537		\$1,283	\$2,821

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Typical Building
Rossell Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 2: Replace oil burner with gas burner
Gas water heaters

Gas water heaters:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas water heater	1	each	\$265	\$265	\$205	\$205	\$470
SUB-TOTAL:				\$265		\$205	\$470
Labor Markup: 21%				\$56		---	\$56
Taxes: 4.5%				---		\$9	\$9
SUB-TOTAL:				\$321		\$214	\$535
Overhead: 10%				\$32		\$21	\$53
SUB-TOTAL:				\$353		\$236	\$588
Profit: 10%				\$35		\$24	\$59
TOTAL:				\$388		\$259	\$647

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Typical Building
Rossell Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 1: Oil boiler
Oil water heater

Replace oil water heater now:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Replace oil water heater	1	each	\$395	\$395	\$1,320	\$1,320	\$1,715
SUB-TOTAL:				\$395		\$1,320	\$1,715
Labor Markup: 21%				\$83		---	\$83
Taxes: 4.5%				---		\$59	\$59
SUB-TOTAL:				\$478		\$1,379	\$1,857
Overhead: 10%				\$48		\$138	\$186
SUB-TOTAL:				\$526		\$1,517	\$2,043
Profit: 10%				\$53		\$152	\$204
TOTAL:				\$578		\$1,669	\$2,247

CONSTRUCTION COST ESTIMATE				DATE PREPARED. <u>AUG '91</u>		SHEET <u>1</u> OF <u>1</u>		
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY					BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) <u>VP</u>			
LOCATION FT. BELVOIR, VIRGINIA								
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS								
DRAWING NO. ROSSELL VILLAGE (400 AREA)			ESTIMATOR REF		CHECKED BY			
<u>GAS to BLDGS.</u> SUMMARY		QUANTITY		LABOR		MATERIAL		TOTAL COST
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	
TRENCH & BACKFILL		1200	LF	1.01	1212	.74	888	2100
HAND EXCAVATING		200	CY	34.00	6800		—	6800
HAND BACKFILLING		200	CY	12.45	2490		—	2490
POLYETHYLENE PIPE - 1 1/4"		1800	LF	1.17	2106	.55	990	3096
BLACK STEEL PIPE - 3/4"		2400	LF	3.21	7704	.87	2088	9792
MAIN CONNECTION		60	EA	15.00	900	5.00	300	1200
STOP VALVES - 3/4"		60	EA	9.00	540	8.05	483	1023
PRESSURE REGULATORS		30	EA	10.00	300	50.00	1500	1800
SIDEWALK REPAIR		1000	SF	.94	940	1.26	1260	2200
HAULING		60	CY	2.21	133	4.33	260	392
DISPOSAL OF MATERIALS			LS		300		—	300
MATERIAL HANDL./STORAGE			LS		200		—	200
SEED/SOD			LS		300		—	300
GAS LINE TESTING		60	EA	10.00	600		—	600
GENERAL CLEAN-UP		60	EA	10.00	600		—	600
SUB-TOTAL					25,125		7,769	32,894
LABOR, INS. & TAXES 21%					5,276		—	5276
SALES TAX 4.5%					—		350	350
SUB-TOTAL					30,401		8,119	38,520
OVERHEAD 10%								3,852
SUB-TOTAL								42,372
PROFIT 10%								4,237
SUB-TOTAL								46,609
TOTAL								\$ 46,609

$$\text{PROPORTIONATE COST / UNIT} = \frac{46609}{30} = \text{APPRX } \$1555.$$

44

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

Rossell Village - SUMMARY OF COSTS

Typical Building (30 buildings) = \$125,750

Cost to Govt for curb to
buildings gas lines = \$ 46,609

TOTAL = \$172,359

Replacement costs

Replace boiler, retain gas burner \$2,821 X 30 = \$ 84,630

Gas-fired water heaters \$ 647 X 30 = \$ 19,410

Oil-fired water heaters \$2,247 X 30 = \$ 67,410

PORT BELVOIR ROSSELL HOUSING AREA

CONSOLIDATION OF OTHER COSTS

TYP.BLDG	No.	MAINT.COST PER BLDG	ONE TIME REPL COSTS		MAINT. COSTS	ONE TIME REPL COST	
			\$ OIL WH	\$ PER BLDG GAS WH		\$ OIL WH	\$ GAS WH
401	5	20	2247	-647	100	11235	-3235
406	25	20	2247	-647	500	56175	-16175
TOTAL	30				600	67410	-19410

LIFE CYCLE COST ANALYSIS SUMMARY
ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

LOCATION: FORT BELVOIR REGION NO. 3 PROJECT NUMBER DACA-31-89-C-0198
PROJECT TITLE: ENERGY SAVINGS OPPORTUNITY SURVEY FISCAL YR. 1991
DISCRETE PORTION NAME ROSSELL VILLAGE - OIL TO GAS CONVERSION
ANALYSIS DATE AUGUST 1991 ECONOMIC LIFE 20 YEARS PREPARED BY EAC

1. INVESTMENT
A. CONSTRUCTION COST \$ 172,359
B. SIOH \$ 9,480
C. DESIGN COST \$ 10,342
D. SALVAGE VALUE - \$
E. TOTAL INVESTMENT (1A + 1B + 1C - 1D) \$ 192,181

2. ENERGY SAVINGS (+) / COST (-)
ANALYSIS DATE ANNUAL SAVINGS, UNIT COST AND DISCOUNTED SAVINGS

FUEL	COST \$/MBTU/YR(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS (5)
A. ELEC	\$ <u> </u>	<u> </u>	\$ <u> </u>	<u> </u>	\$ <u> </u>
B. DIST	\$ <u>7.43</u>	<u>5,670</u>	\$ <u>42,128</u>	<u>18.26</u>	\$ <u>769,257</u>
C. RESID	\$ <u>6.62</u>	<u> </u>	\$ <u> </u>	<u> </u>	\$ <u> </u>
D. NG	\$ <u>5.33</u>	<u>-5,995</u>	\$ <u>-31,953</u>	<u>19.38</u>	\$ <u>-619,249</u>
E. COAL	\$ <u> </u>	<u> </u>	\$ <u> </u>	<u> </u>	\$ <u> </u>
F. TOTAL		<u>-325</u>	\$ <u>10,175</u>		\$ <u>150,008</u>

3. NONENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)
(1) DISCOUNT FACTOR (TABLE A) 12.97 \$ 600
(2) DISCOUNTED SAVING/COST (3A X 3A1) \$ 7,782

B. NONRECURRING SAVINGS (+) / COST (-)

ITEM	SAVINGS (+) COST (-)(1)	YEAR OF OCCUR.(2)	DISCOUNT FACTOR(3)	DISCOUNTED SAV- INGS(+) COST(-)(4)
REPL.				
(1) OIL WH	\$ <u>67,410</u>	<u>10</u>	<u>0.63</u>	\$ <u>42,468</u>
(2) GAS WH	\$ <u>-19,410</u>	<u>10</u>	<u>0.63</u>	\$ <u>-12,228</u>
(3) BOILER (INCL. SIOH)	\$ <u>-89,285</u>	<u>10</u>	<u>0.63</u>	\$ <u>-56,249</u>
(4) TOTAL	\$ <u>-41,285</u>			\$ <u>-26,009</u>

C. TOTAL NONENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ -18,227

D. PROJECT NONENERGY QUALIFICATION TEST
(1) 25% MAX NONENERGY CALC (2F5 x .33) \$ 49,503
a. IF 3D1 IS = OR > 3C GO TO ITEM 4
b. IF 3D1 IS < 3C CALC S1R = (2F5+3D1) - 1E =
c. IF 3D1 IS = > 1 GO TO ITEM 4
d. IF 3D1 IS < 1 PROJECT DOES NOT QUALIFY

4. FIRST YEAR DOLLAR SAVINGS 2F3 + 3A + (3B1d ÷ YEARS ECONOMIC LIFE) \$ 8,711

5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C) \$ 131,781

6. DISCOUNTED SAVINGS RATION (IF < 1 PROJECT DOES NOT QUALIFY) (S1R) = (5÷1E) = 0.69

SIMPLE PAYBACK PERIOD (YEARS) = 22.0


BUILDINGS 900 TO 944
DOGUE CREEK VILLAGE
(TYPICALS)

900 AREA (DOGUE CREEK)

Fuel Conversion:

Description - Existing oil-fired furnaces used for heating and electric water heaters are proposed to be replaced by gas-fired boilers and water heaters respectively.


Energy Saved	= -23	MBTU/year
Cost	= \$205,446	(incl. SIOH)
SIR	= 3.84	



DOGUE
CREEK

NCO FAMILY HOUSING

NORTH



Dogue Creek Village

Bldg No.	Location	Bed-rooms	Sq Ft	Year
900	A Barlow Road	2	1,137	56
	B Barlow Road	2	1,137	56
	C Barlow Road	2	1,137	56
	D Barlow Road	2	1,137	56
	E Barlow Road	3/B	1,264	56
901	A Barlow Road	3/B	1,264	56
	B Barlow Road	3	1,264	56
	C Barlow Road	3	1,264	56
	D Barlow Road	3	1,264	56
	E Barlow Road	3	1,264	56
	F Barlow Road	3/B	1,264	56
902	A Barlow Road	3/B	1,264	56
	B Barlow Road	2	1,137	56
	C Barlow Road	2	1,137	56
	D Barlow Road	2	1,137	56
	E Barlow Road	2	1,137	56
903	A Barlow Road	3/B	1,264	56
	B Barlow Road	3	1,264	56
	C Barlow Road	3	1,264	56
	D Barlow Road	3	1,264	56
	E Barlow Road	3	1,264	56
904	A Barlow Road	3/B	1,264	56
	B Barlow Road	3	1,264	56
	C Barlow Road	3	1,264	56
	D Barlow Road	3	1,264	56
	E Barlow Road	3	1,264	56
905	A Barlow Road	3/B	1,264	56
	B Barlow Road	3	1,264	56
	C Barlow Road	3	1,264	56
	D Barlow Road	3	1,264	56
	E Barlow Road	3	1,264	56
906	A Barlow Road	3/B	1,264	56
	B Barlow Road	3	1,264	56
	C Barlow Road	3	1,264	56
	D Barlow Road	3	1,264	56
	E Barlow Road	3	1,264	56
907	A Fenner Road	3/B	1,264	56
	B Barlow Road	2	1,137	56
	C Barlow Road	2	1,137	56
	D Barlow Road	2	1,137	56

Bldg No.	Location	Bed-rooms	Sq Ft	Year
907 E	Barlow Road	2	1,137	56
F	Barlow Road	3	1,264	56
G	Barlow Road	3	1,264	56
H	Barlow Road	3	1,264	56
I	Barlow Road	3	1,264	56
908 A	Barlow Road	3/B	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3	1,264	56
F	Barlow Road	3/B	1,264	56
909 A	Barlow Road	3/B	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3	1,264	56
910 A	Barlow Road	3/B	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3	1,264	56
911 A	Barlow Road	3	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3/B	1,264	56
912 A	Barlow Road	3	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	2/B	1,137	56
913 A	Barlow Road	3/B	1,264	56
B	Moyer Road	3	1,264	56
C	Moyer Road	3	1,264	56
D	Moyer Road	3	1,264	56
E	Moyer Road	3	1,264	56
914 A	Moyer Road	3	1,264	56
B	Moyer Road	3	1,264	56
C	Moyer Road	3	1,264	56
D	Moyer Road	3	1,264	56
E	Moyer Road	2	1,137	56
F	Moyer Road	2	1,137	56
G	Moyer Road	2	1,137	56
H	Moyer Road	2	1,137	56
I	Moyer Road	3	1,264	56
915 A	Maloney Road	2	1,137	56
B	Maloney Road	2	1,137	56
C	Maloney Road	2	1,137	56
D	Maloney Road	2	1,137	56
E	Maloney Road	2	1,137	56
916 A	Maloney Road	3/B	1,264	56
	Maloney Road	3/B	1,264	56

Bldg No.	Location	Bed-rooms	Sq Ft	Year
916 B	Maloney Road	3	1,264	56
916 C	Maloney Road	3	1,264	56
916 D	Maloney Road	3	1,264	56
916 E	Maloney Road	3	1,264	56
916 F	Maloney Road	3/B	1,264	56
917 A	Maloney Road	3/B	1,264	56
917 B	Maloney Road	2	1,137	56
917 C	Maloney Road	2	1,137	56
917 D	Maloney Road	2	1,137	56
917 E	Maloney Road	2	1,137	56
918 A	Maloney Road	2/B	1,264	56
918 B	Maloney Road	2	1,264	56
918 C	Maloney Road	2	1,264	56
918 D	Maloney Road	2	1,264	56
918 E	Maloney Road	3	1,264	56
919 A	Moyer Road	3/B	1,264	56
919 B	Maloney Road	2	1,137	56
919 C	Maloney Road	2	1,137	56
919 D	Maloney Road	2	1,137	56
919 E	Maloney Road	2	1,137	56
919 F	Maloney Road	3	1,264	56
919 G	Maloney Road	3	1,264	56
919 H	Maloney Road	3	1,264	56
919 I	Maloney Road	3	1,264	56
920 A	Maloney Road	3/B	1,264	56
920 B	Maloney Road	3	1,264	56
920 C	Maloney Road	3	1,264	56
920 D	Maloney Road	3	1,264	56
920 E	Maloney Road	3	1,264	56
920 F	Maloney Road	3/B	1,264	56
921 A	Maloney Road	3/B	1,264	56
921 B	Maloney Road	3	1,264	56
921 C	Maloney Road	3	1,264	56
921 D	Maloney Road	3	1,264	56
921 E	Maloney Road	3	1,264	56
922 A	Maloney Road	3	1,264	56
922 B	Maloney Road	3	1,264	56
922 C	Maloney Road	3	1,264	56
922 D	Maloney Road	3	1,264	56
922 E	Maloney Road	2	1,137	56
922 F	Maloney Road	2	1,137	56
922 G	Maloney Road	2	1,137	56
922 H	Maloney Road	2	1,137	56
923 A	Maloney Road	3	1,264	56
923 B	Maloney Road	3	1,264	56
923 C	Maloney Road	3	1,264	56
923 D	Maloney Road	3	1,264	56
923 E	Maloney Road	3/B	1,264	56
924 A	Maloney Road	2	1,137	56
924 B	Maloney Road	2	1,137	56
924 C	Maloney Road	2	1,137	56

Bldg No.	Location	Bed-rooms	Sq Ft	Year
924 D	Maloney Road	2	1,137	56
E	Maloney Road	3/B	1,264	56
925 A	Maloney Road	3	1,264	56
B	Maloney Road	3	1,264	56
C	Maloney Road	3	1,264	56
D	Maloney Road	3	1,264	56
E	Maloney Road	3/B	1,264	56
926 A	Maloney Road	3/B	1,264	56
B	Maloney Road	2	1,137	56
C	Maloney Road	2	1,137	56
D	Maloney Road	2	1,137	56
E	Maloney Road	2	1,137	56
F	Maloney Road	3/B	1,264	56
927 A	Maloney Road	3/B	1,264	56
B	Maloney Road	3	1,264	56
C	Maloney Road	3	1,264	56
D	Maloney Road	3	1,264	56
E	Maloney Road	3	1,264	56
928 A	Fenner Road	3	1,264	56
B	Fenner Road	3	1,264	56
C	Fenner Road	3	1,264	56
D	Fenner Road	3	1,264	56
E	Fenner Road	2	1,137	56
F	Maloney Road	2	1,137	56
G	Maloney Road	2	1,137	56
H	Maloney Road	2	1,137	56
929 A	Maloney Road	3/B	1,264	56
B	Fenner Road	3	1,264	56
C	Fenner Road	3	1,264	56
D	Fenner Road	3	1,264	56
E	Fenner Road	3	1,264	56
930 A	Fenner Road	3	1,264	56
B	Fenner Road	3	1,264	56
C	Fenner Road	3	1,264	56
D	Fenner Road	3	1,264	56
E	Fenner Road	3/B	1,264	56
931 A	Fenner Road	3	1,264	56
B	Fenner Road	3	1,264	56
C	Fenner Road	3	1,264	56
D	Fenner Road	3	1,264	56
E	Fenner Road	3/B	1,264	56
932 A	Fenner Road	3/B	1,264	56
B	Fenner Road	3	1,264	56
C	Fenner Road	3	1,264	56
D	Fenner Road	3	1,264	56
E	Fenner Road	3	1,264	56
933 A	Barlow Road	3	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	2	1,137	56

Bldg No.	Location	Bed-rooms	Sq Ft	Year
933 F	Barlow Road	2	1,137	56
G	Barlow Road	2	1,137	56
933 H	Barlow Road	2	1,137	56
I	Barlow Road	3/B	1,264	56
934 A	Barlow Road	3	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	2	1,137	56
F	Barlow Road	2	1,137	56
G	Barlow Road	2	1,137	56
H	Barlow Road	2	1,137	56
I	Barlow Road	3/B	1,264	56
935 A	Barlow Road	3/B	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3	1,264	56
F	Barlow Road	3/B	1,264	56
936 A	Barlow Road	3/B	1,264	56
B	Barlow Road	2	1,137	56
C	Barlow Road	2	1,137	56
D	Barlow Road	3	1,137	56
E	Barlow Road	2	1,137	56
F	Barlow Road	3	1,264	56
G	Barlow Road	3	1,264	56
H	Barlow Road	3	1,264	56
I	Barlow Road	3	1,264	56
937 A	Barlow Road	3	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3/B	1,264	56
938 A	Barlow Road	3	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	2	1,189	56
F	Barlow Road	2	1,189	56
G	Barlow Road	2	1,189	56
H	Barlow Road	2	1,189	56
I	Barlow Road	3/B	1,264	56
939 A	Barlow Road	3/B	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3	1,264	56
F	Barlow Road	3/B	1,264	56
940 A	Barlow Road	3/B	1,264	56
B	Barlow Road	2	1,137	56
C	Barlow Road	2	1,137	56

Bldg No.	Location	Bed- rooms	Sq Ft	Year
940 D	Barlow Road	2	1,137	56
E	Barlow Road	2	1,137	56
940 F	Barlow Road	3	1,264	56
G	Barlow Road	3	1,264	56
H	Barlow Road	3	1,264	56
I	Barlow Road	3	1,264	56
941 A	Barlow Road	3/B	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3	1,264	56
942 A	Barlow Road	3	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3/B	1,264	56
943 A	Barlow Road	3/B	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3	1,264	56
944 A	Barlow Road	3	1,264	56
B	Barlow Road	3	1,264	56
C	Barlow Road	3	1,264	56
D	Barlow Road	3	1,264	56
E	Barlow Road	3/B	1,264	56

900 AREA (DOGUE CREEK)

TABLE OF CONTENTS

Input Data	8
Output Data	49
ECIP Analysis	
Energy Savings	56
Cost Summary	57-70
LCC Analysis	72

DESIGN PARAMETERS, SHGs

Location : Fort Belvoir, Virginia 01-08-91
 Prepared By : E A C, PC BURKE, VA. 6100190202
 Carrier Hourly Analysis Program Page 1 of 1

DESIGN WEATHER PARAMETERS

City Name.....: Fort Belvoir
 Location.....: Virginia
 Latitude.....: 38.7 deg
 Elevation.....: 69.0 ft
 Summer Design Dry Bulb Temp.....: 90.0 F
 Summer Design Wet Bulb Temp.....: 75.0 F
 Daily Temperature Range.....: 23.0 F
 Winter Design Dry Bulb Temp.....: 12.0 F
 Atmospheric Clearness Number.....: 1.00

TABLE 1. MAXIMUM SOLAR HEAT GAINS - AVERAGE DAYS
 (BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	24.2	61.9	98.8	111.9	98.8	61.9	24.2	24.2	80.1
Feb	31.7	75.4	106.8	115.1	106.8	75.4	31.7	31.7	107.3
Mar	40.7	87.4	107.7	108.9	107.7	87.4	40.7	40.7	136.8
Apr	59.9	97.6	104.8	97.9	104.8	97.6	59.9	49.2	164.2
May	74.7	103.1	98.7	84.7	98.7	103.1	74.7	54.9	181.6
Jun	84.9	109.2	97.9	79.8	97.9	109.2	84.9	57.8	194.9
Jul	80.4	106.6	98.5	82.0	98.5	106.6	80.4	56.4	189.0
Aug	69.0	104.2	106.2	95.1	106.2	104.2	69.0	52.1	177.5
Sep	52.3	99.7	115.4	112.4	115.4	99.7	52.3	45.3	158.1
Oct	36.3	88.9	118.8	124.1	118.8	88.9	36.3	36.3	128.3
Nov	26.6	67.2	103.2	114.9	103.2	67.2	26.6	26.6	89.5
Dec	21.3	53.7	89.1	102.7	89.1	53.7	21.3	21.3	68.5

TABLE 2. MAXIMUM SOLAR HEAT GAINS - DESIGN DAYS
 (BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	20.2	157.9	243.4	253.9	243.4	157.9	20.2	20.2	140.3
Feb	52.5	188.6	246.3	238.2	246.3	188.6	52.5	24.6	186.3
Mar	95.5	219.4	234.8	201.8	234.8	219.4	95.5	29.3	227.8
Apr	141.3	224.3	200.7	148.1	200.7	224.3	141.3	34.1	255.2
May	165.9	220.1	171.5	106.1	171.5	220.1	165.9	37.3	267.4
Jun	173.0	215.4	157.5	89.2	157.5	215.4	173.0	47.4	269.3
Jul	163.5	215.7	167.2	102.9	167.2	215.7	163.5	38.2	264.2
Aug	136.2	216.5	193.7	143.1	193.7	216.5	136.2	35.7	250.5
Sep	89.8	206.8	224.9	195.9	224.9	206.8	89.8	30.4	220.2
Oct	51.4	182.2	238.2	231.2	238.2	182.2	51.4	25.4	183.0
Nov	20.6	155.1	239.4	250.0	239.4	155.1	20.6	20.6	139.7
Dec	18.3	140.7	235.7	254.0	235.7	140.7	18.3	18.3	120.5

ZONE DESCRIPTION

Zone Name : Dogue Creek typicals 05-01-91
 Prepared By : E A C 6100190202
 Carrier Hourly Analysis Program Page 1 of 2

1. ZONE NAME AND TYPE

Zone Name = Dogue Creek typicals
 Job Name = Fort Belvoir
 Zone Type = 1 (Normal Zone)

2. THERMOSTAT AND EQUIPMENT SCHEDULE

COOLING EQUIPMENT

Occupied cooling thermostat setpoint = 75.0 F
 Unoccupied cooling thermostat setpoint = 75.0 F
 Starting hour of occupied period = 0
 Number of hours in occupied period = 24

HEATING EQUIPMENT

Heating thermostat setpoint = 68.0 F

3. COOLING SYSTEM PARAMETERS

SUPPLY AIR

Type of input = 3 (Supply Temperature)
 Supply temperature = 55.0 F

VENTILATION AIR

Type of input = 3 (% of supply)
 Ventilation air = 0 %

SAFETY FACTOR

Cooling safety factor = 10 %

4. HEATING SYSTEM PARAMETERS

HEATING SOURCE

Type of system = 1 (Warm Air)
 Supply temperature = 110.0 F

VENTILATION AIR

Type of input = 3 (% of supply)
 Ventilation air = 0 %

SAFETY FACTOR

Heating safety factor = 10 %

5. OTHER SYSTEM PARAMETERS

SUPPLY FAN

Total static pressure = 0.35 in wg
 Total efficiency = 60 %
 Fan configuration = 1 (Draw-Thru)

EXHAUST AIR

Direct exhaust air flow rate = 0 % of vent. air

RETURN AIR

Is a return plenum used = N

COIL DATA

Cooling coil bypass factor = 0.050

U-VALUE CALCULATION FORM

FOR WALL/PARTITION

Project: DOGUE CREEK VILLAGE, FORT BELVOIR

EAC Project Number: 89034.01 Date: AUGUST 1990 By: TB

☒ Wall

☐ Partition

Material	Resistance (h-ft ² - F/Btu)	
	Summer	Winter
1. <u>Outside Air</u>	<u>0.25</u>	<u>0.17</u>
2. <u>Inside Still Air</u>	<u>0.68</u>	<u>0.68</u>
3. <u>4" FACE BRICK</u>		<u>0.44</u>
4. <u>4" CINDER BLOCK</u>		<u>1.11</u>
5. <u>PLASTER</u>		<u>0.45</u>
6. _____		
7. _____		
8. _____		
Total (R) =		<u>2.85</u>
U = 1/R =		<u>0.351</u>

(Btu/h-sq.ft. - F)

MATERIAL	R*	MATERIAL	R*
Air Space 3/4" (90 F)	0.84	Blanket/Batt Insul.	
Air Space 3/4" (0 F)	1.18	2-2 3/4 in.	7.00
Still Air	0.68	3-4 in.	11.00
Moving Air 7 1/2 MPH	0.25	3.5 in.	13.00
Moving Air 15 MPH	0.17	5.5-6.5 in.	19.00
Face Brick 4"	0.44	6-7.5 in.	22.00
Cinderblock 4"	1.11	9-10 in.	30.00
Cinderblock 8"	1.72	12-13 in.	38.00
Cinderblock 12"	1.89	Rigid Insul. 1"	2.78
Gypsum Bd 3/8"	0.32	Styrofoam 1"	4.00
Gypsum Bd 1/2"	0.45	Vermiculite 1"	2.27
Gypsum Plaster 1/2"	0.45	Vapor Barr.-felt	0.06
Sand Plaster 3/8"	0.08	Fir, Pine & Simil.	
Loose Fill Sandust 1"	2.22	Woods 3/4"	0.94
Perlite Expanded 1"	2.90		

*(h-sq.ft. - F/Btu)

U-VALUE CALCULATION FORM

FOR ROOF/FLOOR

Project: DOGUE CREEK VILLAGE, FORT BELVOIR

EAC Project Number: 89034.01 Date: AUGUST 1990 By: JB

☒ Roof

☐ Floor

Material	Resistance (h-sq. ft.-F/Btu)	
	Summer	Winter
1. <u>Top Surface (Moving Air)</u>	<u>0.25</u>	<u>0.61</u>
2. <u>Bottom Surface (Still Air)</u>		<u>0.61</u>
3. <u>INSULATION</u>		<u>30.00</u>
4. <u>PLASTER</u>		<u>0.45</u>
5. _____		
6. _____		
7. _____		
8. _____		
Total (R) =		<u>31.67</u>
U = 1/R =		<u>0.032</u>

(Btu/h-sq.ft. - F)

MATERIAL	DIRECTION OF HEAT FLOW	R*	MATERIAL	R*
Air Space 3/4" (0 F)	UP	0.93	Batt/Blanket	
Air Space 4"	UP	1.03	2-2 3/4 in.	7.00
Air Space 3/4" (90 F)	DN	0.85	3-4 in.	11.00
Air Space 4"	DN	1.00	3.5 in.	13.00
Still Air	UP	0.61	5.5-6.5 in.	19.00
Still Air	DN	0.92	6-7.5 in.	22.00
Moving Air 7 1/2 MPH	ANY	0.25	9-10 in.	30.00
Moving Air 15 MPH	ANY	0.17	12-13 in.	38.00
Acoustical Tile 1/2"		1.25	Rigid Insul. 1"	2.78
Acoustical Tile 3/4"		1.89	Stryofoam 1"	4.00
Sand Plaster 3/8"		0.08	Built-up Roof 3/8"	0.33
Gypsum Plaster 1/2"		0.45	Asphalt Shingles	0.44

*(h-sq.ft. - F/Btu)

ENGINEERING ANALYSIS

Sheet 1 of 1

By: TB

Calculations for Infiltration

DOGUE CREEK - Typical
~~Building~~

Project: ESOS, Fort Belvoir Date: August, 1990

Contract No: DACA-31-89-C-0189 EAC Project No.: 89034.01

Calculations based on ASHRAE 1989 Page F 23.14.

Building Leakage Area

	Effective Leakage Area, in ²	Building Component Parameter	Building Leakage Area D _L , in ²
	L	D _L	L
Sill foundation	0.19/ft. of perimeter	250 ft.	48
Joints, ceiling/wall	0.12/ft. of wall	250 ft.	30
Windows	0.063/ft ² . of window	830 ft ² .	52
Doors	0.215/ft ² . of doors	150 ft ² .	40
Wall - Window frames	0.15/ft ² . of window	830 ft ² .	125
- Door frames	0.072/ft ² . of door	190 ft ² .	14
Elec. outlet/switch	0.16/ fix fixture outlet	200 sq. ft.	32
Recessed lights	1.6/fixture	10 ft ²	16
Pipe penetration	0.15 sq. ft. in ² . of pipe	10 ft ²	2
Exhaust Fans	6.0/fan	10	60
Duct penetration	2.2/SF	10 SF	22
Furnace	5 sq. ft.	5	25
			<u>466</u>

$$\begin{aligned} \text{Infiltration } Q(\text{cfm}) &= L \times (A \Delta t + B v^2)^{1/2} \\ &= L(0.03/3 \times 51 + 0.057 \times 14^2)^{1/2} \\ &= L \times 2.2 = 466 \times 2.2 = 1025 \text{ CFM} \end{aligned}$$

$$\begin{aligned} \text{Infiltration through walls} &= 0.1 \times 4750 (\text{SF}) \\ &= 475 \text{ CFM} \end{aligned}$$

$$\text{Total Infiltration} = 1025 + 475 = 1500 \text{ CFM}$$

$$\begin{aligned} \text{Infiltration Rate} &= \frac{1500}{6800} = 0.22 = \underline{\underline{0.2}} \text{ CFM/SF} \end{aligned}$$


(ASHRAE 1989, p. 23.13)

MASTER SCHEDULE DISPLAY - 1. OCCUPANCY

Weekday				Saturday				Sunday				DESIGN			
Hr		Pct		Hr		Pct		Hr		Pct		Hr		Pct	
0)	100	12)	50	0)	100	12)	100	0)	100	12)	100	0)	100	12)	100
1)	100	13)	30	1)	100	13)	100	1)	100	13)	100	1)	100	13)	100
2)	100	14)	30	2)	100	14)	100	2)	100	14)	100	2)	100	14)	100
3)	100	15)	30	3)	100	15)	100	3)	100	15)	100	3)	100	15)	100
4)	100	16)	30	4)	100	16)	100	4)	100	16)	100	4)	100	16)	100
5)	100	17)	50	5)	100	17)	100	5)	100	17)	100	5)	100	17)	100
6)	100	18)	70	6)	100	18)	100	6)	100	18)	100	6)	100	18)	100
7)	50	19)	100	7)	100	19)	100	7)	100	19)	100	7)	100	19)	100
8)	30	20)	100	8)	100	20)	100	8)	100	20)	100	8)	100	20)	100
9)	30	21)	100	9)	100	21)	100	9)	100	21)	100	9)	100	21)	100
10)	30	22)	100	10)	100	22)	100	10)	100	22)	100	10)	100	22)	100
11)	30	23)	100	11)	100	23)	100	11)	100	23)	100	11)	100	23)	100

Press <ENTER> to continue.

MASTER SCHEDULE DISPLAY - 1. OCCUPANCY




Press <ENTER> to continue.

MASTER SCHEDULE DISPLAY - 2. HOT WATER

Weekday				Saturday				Sunday				DESIGN			
Hr Pct		Hr Pct		Hr Pct		Hr Pct		Hr Pct		Hr Pct		Hr Pct		Hr Pct	
0)	10	12)	60	0)	10	12)	60	0)	10	12)	60	0)	100	12)	100
1)	3	13)	55	1)	3	13)	55	1)	3	13)	55	1)	100	13)	100
2)	1	14)	50	2)	1	14)	50	2)	1	14)	50	2)	100	14)	100
3)	1	15)	45	3)	1	15)	45	3)	1	15)	45	3)	100	15)	100
4)	1	16)	40	4)	1	16)	40	4)	1	16)	40	4)	100	16)	100
5)	1	17)	45	5)	1	17)	45	5)	1	17)	45	5)	100	17)	100
6)	3	18)	50	6)	3	18)	50	6)	3	18)	50	6)	100	18)	100
7)	15	19)	60	7)	15	19)	60	7)	15	19)	60	7)	100	19)	100
8)	65	20)	75	8)	65	20)	75	8)	65	20)	75	8)	100	20)	100
9)	70	21)	70	9)	70	21)	70	9)	70	21)	70	9)	100	21)	100
10)	85	22)	65	10)	85	22)	65	10)	85	22)	65	10)	100	22)	100
11)	70	23)	60	11)	70	23)	60	11)	70	23)	60	11)	100	23)	100

Press <ENTER> to continue.

MASTER SCHEDULE DISPLAY - 2. HOT WATER



Press <ENTER> to continue.

The design hot water usage for the
New York, 54.12, for the family hot water
usage is 100%.

PROJECTED NAVFAC COST INDEX
MONTHLY
JULY 1989

YEAR	JAN.	FEB.	MAR.	APR.	MAY.	JUNE	JULY	AUG.	SEPT.	OCT.	NOV.	DEC.
1974	1156	1154	1155	1177	1177	1199	1233	1240	1238	1246	1239	1240
1975	1242	1265	1265	1269	1287	1307	1317	1330	1333	1351	1349	1354
1976	1362	1370	1378	1391	1398	1416	1425	1455	1467	1476	1479	1484
1977	1489	1499	1504	1506	1507	1521	1539	1554	1587	1617	1603	1606
1978	1609	1617	1620	1621	1652	1663	1696	1705	1720	1721	1732	1734
1979	1740	1740	1750	1749	1753	1809	1829	1849	1900	1899	1902	1909
1980	1895	1894	1915	1899	1888	1916	1950	1971	1976	1981	2000	2017
1981	2015	2016	2014	2064	2076	2083	2109	2118	2139	2156	2186	2184
1982	2184	2200	2195	2195	2220	2219	2233	2253	2249	2248	2260	2295
1983	2311	2348	2352	2347	2351	2388	2414	2428	2430	2416	2419	2406
1984	2402	2407	2412	2422	2419	2417	2418	2428	2430	2424	2421	2408
1985	2410	2414	2406	2405	2411	2429	2448	2442	2440	2441	2446	2439
1986	2440	2446	2447	2458	2479	2493	2499	2498	2504	2511	2511	2511
1987	2515	2510	2518	2523	2524	2525	2538	2557	2565	2569	2564	2589
1988	2574	2576	2586	2591	2592	2595	2598	2611	2612	2612	2616	2617
1989	2619	2613	2616	2620	2621	2626	2633	2640	2648	2655	2663	2670
1990	2677	2683	2690	2697	2704	2710	2717	2724	2731	2738	2744	2751
1991	2757	2763	2769	2776	2782	2788	2794	2800	2806	2812	2819	2825
1992	2830	2835	2840	2845	2850	2855	2861	2866	2871	2876	2881	2886
1993	2891	2896	2900	2905	2910	2914	2919	2924	2928	2933	2938	2942

ANNUAL MARK-UP FACTORS FOR ESCALATION
(BEYOND FY 93, USE 1.80% ESCALATION COMPOUNDED EACH YEAR)

FISCAL-YEAR	4-87	4-88	4-89	4-90	4-91	4-92	4-93	4-94	4-95
4-83	1.07	1.10	1.12	1.15	1.18	1.21	1.24	1.26	1.28
4-84	1.04	1.07	1.08	1.11	1.15	1.17	1.20	1.22	1.24
4-85	1.05	1.08	1.09	1.12	1.15	1.18	1.21	1.23	1.25
4-86	1.03	1.05	1.07	1.10	1.13	1.16	1.18	1.20	1.22
4-87	1.00	1.03	1.04	1.07	1.10	1.13	1.15	1.17	1.19
4-88	0.97	1.00	1.01	1.04	1.07	1.10	1.12	1.14	1.16
4-89	0.96	0.99	1.00	1.03	1.06	1.09	1.11	1.13	1.15
4-90	0.94	0.96	0.97	1.00	1.03	1.05	1.08	1.10	1.12
4-91	0.91	0.93	0.94	0.97	1.00	1.02	1.05	1.07	1.08
4-92	0.89	0.91	0.92	0.95	0.98	1.00	1.02	1.04	1.06
4-93	0.87	0.89	0.90	0.93	0.96	0.98	1.00	1.02	1.04

NOTE: Escalation rate change to be 1.80% after 1993.

Figure 9
Projected NAVFAC Cost Index

STUDY PARAMETER INPUT PRINTOUT

Prepared By : E A C
Advanced Engineering Economic Analysis Program

05-01-91
60901891.00
Page 1 of 1

STUDY CRITERIA

ECIP - FEMP/10CFR436A (Army TM 5-802-1, Para. 2-3&4)

Discount Rate	:	7.0 %
Investment Credit	:	10.0 %
Payment Time	:	1.0 (1 = end of year)

KEY STUDY DATES

ECIP Economic Life : 15 (years)

ENERGY RELATED STUDY PARAMETERS

State : VA
Prices of Electricity : 18.05
Distillate Oil : 7.43
Residual Oil : 6.62
Natural Gas : 5.33
Coal : 0.00

Prices are specified in \$ / Million BTU, FEMP Date (JUL 1988)

STUDY IDENTIFICATION BLOCK

Project Title : FORT BELVOIR E.S.O.S
Installation Name : DOGUE CREEK VILLAGE
Project Number : DACA-31-89-C-0198
Fiscal Year : 1991
Name of Analyst : E A C, P.C. Burke, Va.

ZONE DESCRIPTION

Zone Name : Dogue Creek Village 01-08-91
 Prepared By : E A C, PC BURKE, VA. 6100190202
 Carrier Hourly Analysis Program Page 2 of 2

***** 6. SPACES INCLUDED IN ZONE

Space Name	Qty.	Space Name	Qty.
1 DOGUE CREEK, type 1 ex 1 x 1		6 DOGUE CREEK, type 2 ex 2 x 1	
2 DOGUE CREEK, type 1 ex 2 x 1		7 DOGUE CREEK, bungalow 1 x 1	
3 DOGUE CREEK, type 1 int. x 1		8 DOGUE CREEK, bungalow 2 x 1	
4 DOGUE CREEK, type 2 ex1 x 1		9 DOGUE CREEK, bungalow 3 x 1	
5 DOGUE CREEK, type 2 int. x 1		10 DOGUE CREEK, type 4 int. x 1	

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, type 1 ex 1

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, type 1 ex 1

Exposure :	E	W	Floor Area :	1,137.0 sqft
Wall Area :	288.0	262.0	Roof Area :	568.0 sqft
Glass Area :	62.0	86.0	Current	
			Elements :	Ms,Wl,Gr,Gl,In

ADDITIONAL ELEMENT - Misc. Internal-----

Sensible Load	=	1,200 BTU/hr
Latent Load	=	0 BTU/hr
Schedule	=	1

ADDITIONAL ELEMENT - Wall-----

Weight	=	M (lb/sqft)	Exposure	=	S
Color	=	M	Net Area	=	300.0 sqft
U-Value	=	0.351 BTU/hr/sqft/F			

ADDITIONAL ELEMENT - Ground-----

Slab Floor Area	=	568.0 sqft
Perimeter	=	75.0 ft
Depth	=	0.0 ft

ADDITIONAL ELEMENT - Glass-----

U-Value	=	0.550 BTU/hr/sqft/F	Exposure	=	S
Glass Factor	=	0.90	Area	=	22.5 sqft
Internal Shades	?	N			

ADDITIONAL ELEMENT - Infiltration-----

Cooling	:	0.20 CFM/sqft	=	227 CFM
Heating	:	0.20 CFM/sqft	=	227 CFM
Typical	:	0.20 CFM/sqft	=	227 CFM

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, type 1 ex 2

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades ?	N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, type 1 ex 2

Exposure :	E	W	Floor Area :	1,137.0 sqft
Wall Area :	288.0	262.0	Roof Area :	568.0 sqft
Glass Area :	62.0	86.0	Current Elements :	Ms,Wl,Gr,Gl,In

ADDITIONAL ELEMENT - Misc. Internal

Sensible Load = 1,200 BTU/hr
 Latent Load = 0 BTU/hr
 Schedule = 1

ADDITIONAL ELEMENT - Wall

Weight =	M (lb/sqft)	Exposure =	S
Color =	M	Net Area =	380.0 sqft
U-Value =	0.351 BTU/hr/sqft/F		

ADDITIONAL ELEMENT - Ground

Slab Floor Area = 568.0 sqft
 Perimeter = 75.0 ft
 Depth = 0.0 ft

ADDITIONAL ELEMENT - Glass

U-Value =	0.550 BTU/hr/sqft/F	Exposure =	S
Glass Factor =	0.90	Area =	44.5 sqft
Internal Shades ?	N		

ADDITIONAL ELEMENT - Infiltration

Cooling : 0.20 CFM/sqft = 227 CFM
 Heating : 0.20 CFM/sqft = 227 CFM
 Typical : 0.20 CFM/sqft = 227 CFM

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, type 1 int.

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight	: M
Weight :	M	M		Glass Factor	: 0.90
Color :	M	M		Internal Shades	? N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, type 1 int.

Exposure :	E	W	Floor Area :	1,137.0 sqft
Wall Area :	288.0	262.0	Roof Area :	568.0 sqft
Glass Area :	62.0	86.0	Current	
			Elements :	Ms,Gr,In

ADDITIONAL ELEMENT - Misc. Internal-----

Sensible Load	=	1,200 BTU/hr
Latent Load	=	0 BTU/hr
Schedule	=	1

ADDITIONAL ELEMENT - Ground-----

Slab Floor Area	=	568.0 sqft
Perimeter	=	40.0 ft
Depth	=	0.0 ft

ADDITIONAL ELEMENT - Infiltration-----

Cooling	: 0.20 CFM/sqft =	227 CFM
Heating	: 0.20 CFM/sqft =	227 CFM
Typical	: 0.20 CFM/sqft =	227 CFM

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, type 2 ex1

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	? N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, type 2 ex1

Exposure :	E	W	Floor Area :	1,264.0 sqft
Wall Area :	330.0	304.0	Roof Area :	632.0 sqft
Glass Area :	62.0	86.0	Current Elements :	G1,W1,Ms,Gr,In

ADDITIONAL ELEMENT - Glass

U-Value	=	0.550 BTU/hr/sqft/F	Exposure	=	S
Glass Factor	=	0.90	Area	=	44.5 sqft
Internal Shades	?	N			

ADDITIONAL ELEMENT - Wall

Weight	=	M (lb/sqft)	Exposure	=	S
Color	=	M	Net Area	=	456.0 sqft
U-Value	=	0.351 BTU/hr/sqft/F			

ADDITIONAL ELEMENT - Misc. Internal

Sensible Load	=	1,200 BTU/hr
Latent Load	=	0 BTU/hr
Schedule	=	1

ADDITIONAL ELEMENT - Ground

Slab Floor Area	=	632.0 sqft
Perimeter	=	85.0 ft
Depth	=	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling	:	0.20 CFM/sqft	=	253 CFM
Heating	:	0.20 CFM/sqft	=	253 CFM
Typical	:	0.20 CFM/sqft	=	253 CFM

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, type 2 int.

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, type 2 int.

Exposure :	E	W	Floor Area :	1,264.0 sqft
Wall Area :	330.0	304.0	Roof Area :	632.0 sqft
Glass Area :	62.0	86.0	Current	
			Elements :	Ms,Gr,In

ADDITIONAL ELEMENT - Misc. Internal

Sensible Load = 1,200 BTU/hr
 Latent Load = 0 BTU/hr
 Schedule = 1

ADDITIONAL ELEMENT - Ground

Slab Floor Area = 632.0 sqft
 Perimeter = 48.0 ft
 Depth = 0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling : 0.20 CFM/sqft = 253 CFM
 Heating : 0.20 CFM/sqft = 253 CFM
 Typical : 0.20 CFM/sqft = 253 CFM

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, type 2 ex 2

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	? N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, type 2 ex 2

Exposure :	E	W	Floor Area :	1,264.0 sqft
Wall Area :	330.0	304.0	Roof Area :	632.0 sqft
Glass Area :	62.0	86.0	Current Elements :	Gl,Wl,Ms,Gr,In

ADDITIONAL ELEMENT - Glass

U-Value	=	0.550 BTU/hr/sqft/F	Exposure	=	S
Glass Factor	=	0.90	Area	=	22.2 sqft
Internal Shades	?	N			

ADDITIONAL ELEMENT - Wall

Weight	=	M (lb/sqft)	Exposure	=	S
Color	=	M	Net Area	=	380.0 sqft
U-Value	=	0.351 BTU/hr/sqft/F			

ADDITIONAL ELEMENT - Misc. Internal

Sensible Load	=	1,200 BTU/hr
Latent Load	=	0 BTU/hr
Schedule	=	1

ADDITIONAL ELEMENT - Ground

Slab Floor Area	=	632.0 sqft
Perimeter	=	85.0 ft
Depth	=	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling	:	0.20 CFM/sqft	=	253 CFM
Heating	:	0.20 CFM/sqft	=	253 CFM
Typical	:	0.20 CFM/sqft	=	253 CFM

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, bungalow 1

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight	: M
Weight :	M	M		Glass Factor	: 0.90
Color :	M	M		Internal Shades	? N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, bungalow 1

Exposure :	S	N	Floor Area :	1,264.0 sqft
Wall Area :	295.0	162.0	Roof Area :	1,264.0 sqft
Glass Area :	49.5	40.2	Current	
			Elements :	G1,W1,Ms,Gr,In

ADDITIONAL ELEMENT - Glass

U-Value	=	0.550 BTU/hr/sqft/F	Exposure	=	E
Glass Factor	=	0.90	Area	=	21.6 sqft
Internal Shades	?	N			

ADDITIONAL ELEMENT - Wall

Weight	=	M (lb/sqft)	Exposure	=	W
Color	=	M	Net Area	=	262.0 sqft
U-Value	=	0.351 BTU/hr/sqft/F			

ADDITIONAL ELEMENT - Misc. Internal

Sensible Load	=	1,200 BTU/hr
Latent Load	=	0 BTU/hr
Schedule	=	1

ADDITIONAL ELEMENT - Ground

Slab Floor Area	=	1,264.0 sqft
Perimeter	=	110.0 ft
Depth	=	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling	: 0.20 CFM/sqft =	253 CFM
Heating	: 0.20 CFM/sqft =	253 CFM
Typical	: 0.20 CFM/sqft =	253 CFM

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, bungalow 2

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	? N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, bungalow 2

			Floor Area :	1,264.0 sqft
Exposure :	S	N	Roof Area :	1,264.0 sqft
Wall Area :	295.0	104.0	Current	
Glass Area :	49.5	40.2	Elements :	G1,W1,Ms,Gr,In

ADDITIONAL ELEMENT - Glass

U-Value	=	0.550 BTU/hr/sqft/F	Exposure	=	E
Glass Factor	=	0.90	Area	=	43.2 sqft
Internal Shades	?	N			

ADDITIONAL ELEMENT - Wall

Weight	=	M (lb/sqft)	Exposure	=	E
Color	=	M	Net Area	=	400.0 sqft
U-Value	=	0.351 BTU/hr/sqft/F			

ADDITIONAL ELEMENT - Misc. Internal

Sensible Load	=	1,200 BTU/hr
Latent Load	=	0 BTU/hr
Schedule	=	1

ADDITIONAL ELEMENT - Ground

Slab Floor Area	=	1,264.0 sqft
Perimeter	=	120.0 ft
Depth	=	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling	:	0.20 CFM/sqft	=	253 CFM
Heating	:	0.20 CFM/sqft	=	253 CFM
Typical	:	0.20 CFM/sqft	=	253 CFM

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, bungalow 3

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	? N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, bungalow 3

Exposure :	S	N	Floor Area :	1,137.0 sqft
Wall Area :	250.0	262.0	Roof Area :	1,137.0 sqft
Glass Area :	49.5	40.2	Current	
			Elements :	G1,W1,Ms,Gr,In

ADDITIONAL ELEMENT - Glass

U-Value	=	0.550 BTU/hr/sqft/F	Exposure	=	E
Glass Factor	=	0.90	Area	=	21.6 sqft
Internal Shades	?	N			

ADDITIONAL ELEMENT - Wall

Weight	=	M (lb/sqft)	Exposure	=	W
Color	=	M	Net Area	=	262.0 sqft
U-Value	=	0.351 BTU/hr/sqft/F			

ADDITIONAL ELEMENT - Misc. Internal

Sensible Load	=	1,200 BTU/hr
Latent Load	=	0 BTU/hr
Schedule	=	1

ADDITIONAL ELEMENT - Ground

Slab Floor Area	=	1,137.0 sqft
Perimeter	=	100.0 ft
Depth	=	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling	:	0.20 CFM/sqft	=	227 CFM
Heating	:	0.20 CFM/sqft	=	227 CFM
Typical	:	0.20 CFM/sqft	=	227 CFM

SIMPLE SPACE DESCRIPTION

Space Name : DOGUE CREEK, type 4 int

02-05-91

Prepared By : E A C , PC BURKE, VA.

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.351	0.032	0.550	Building Weight	: M
Weight :	M	M		Glass Factor	: 0.90
Color :	M	M		Internal Shades	? N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = DOGUE CREEK, type 4 int

Exposure :	E	W	Floor Area :	1,189.0 sqft
Wall Area :	305.0	279.0	Roof Area :	643.0 sqft
Glass Area :	62.0	86.0	Current	
			Elements :	Ms,Gr,In

ADDITIONAL ELEMENT - Misc. Internal

Sensible Load = 1,200 BTU/hr
 Latent Load = 0 BTU/hr
 Schedule = 1

ADDITIONAL ELEMENT - Ground

Slab Floor Area = 644.0 sqft
 Perimeter = 45.0 ft
 Depth = 0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling : 0.20 CFM/sqft = 238 CFM
 Heating : 0.20 CFM/sqft = 238 CFM
 Typical : 0.20 CFM/sqft = 238 CFM

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek unit 1 ex 1 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
----------------	---------------

WALL TRANSMISSION	16,708
ROOF TRANSMISSION	1,018
GLASS TRANSMISSION	5,251
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	13,719
SLAB FLOOR	2,719
HEATING SAFETY BTU/hr	3,941

SUB-TOTAL	43,356
NET VENTILATION LOSS	0

TOTAL HEATING LOAD	43,356
--------------------	--------

HEATING SUPPLY CFM	958 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek unit 1 int 1 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	10,811
ROOF TRANSMISSION	1,018
GLASS TRANSMISSION	4,558
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	13,719
SLAB FLOOR	1,543
HEATING SAFETY BTU/hr	3,165
SUB-TOTAL	34,813
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	34,813
HEATING SUPPLY CFM	769 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek unit 1 ex2 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	18,280
ROOF TRANSMISSION	1,018
GLASS TRANSMISSION	5,929
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	13,719
SLAB FLOOR	2,719
HEATING SAFETY BTU/hr	4,166
SUB-TOTAL	45,831
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	45,831
HEATING SUPPLY CFM	1,013 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek unit 2 ex 1 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	21,425
ROOF TRANSMISSION	1,133
GLASS TRANSMISSION	5,929
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	15,251
SLAB FLOOR	3,077
HEATING SAFETY BTU/hr	4,681
SUB-TOTAL	51,496
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	51,496
HEATING SUPPLY CFM	1,138 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek unit 2 int Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	12,462
ROOF TRANSMISSION	1,133
GLASS TRANSMISSION	4,558
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	15,251
SLAB FLOOR	1,834
HEATING SAFETY BTU/hr	3,524
SUB-TOTAL	38,761
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	38,761
HEATING SUPPLY CFM	857 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek unit 2 ex 2 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	19,931
ROOF TRANSMISSION	1,133
GLASS TRANSMISSION	5,242
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	15,251
SLAB FLOOR	3,077
HEATING SAFETY BTU/hr	4,463
SUB-TOTAL	49,097
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	49,097
HEATING SUPPLY CFM	1,085 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek unit 4

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	11,479
ROOF TRANSMISSION	1,152
GLASS TRANSMISSION	4,558
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	14,346
SLAB FLOOR	1,737
HEATING SAFETY BTU/hr	3,327
SUB-TOTAL	36,600
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	36,600
HEATING SUPPLY CFM	809 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek bungalow 1 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	14,133
ROOF TRANSMISSION	2,265
GLASS TRANSMISSION	3,428
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	15,251
SLAB FLOOR	4,138
HEATING SAFETY BTU/hr	3,922
SUB-TOTAL	43,137
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	43,137
HEATING SUPPLY CFM	953 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek bungalow 2 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	15,705
ROOF TRANSMISSION	2,265
GLASS TRANSMISSION	4,093
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	15,251
SLAB FLOOR	4,474
HEATING SAFETY BTU/hr	4,179
SUB-TOTAL	45,968
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	45,968
HEATING SUPPLY CFM	1,016 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia
 Prepared By : E A C , PC BURKE, VA.
 Carrier Hourly Analysis Program

02-05-91
 6100190202
 Page 1 of 1

CALCULATION DATA:

Zone Name : Dogue Creek bungalow 3 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	15,214
ROOF TRANSMISSION	2,038
GLASS TRANSMISSION	3,428
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	13,719
SLAB FLOOR	3,758
HEATING SAFETY BTU/hr	3,816
SUB-TOTAL	41,971
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	41,971
HEATING SUPPLY CFM	928 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

AIR SYSTEM DESCRIPTION

Name : Dogue Creek typical sys.

01-08-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C, PC BURKE, VA.

Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = Dogue Creek typical sys.
 System Class = Constant Volume
 System Type = (SZCV) Single Zone Constant Volume
 Operation Type = 2 Heating Only
 Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	68.0 F	CLOSED
Unoccupied	75.0 F	68.0 F	CLOSED
Weekday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Sunday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Design Day	: Occupied Period Begins at 0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
 Heating supply temperature = 110.0 F
 Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
 Minimum ventilation flow rate = 0.00 % of supply air
 Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 CFM
 Zone exhaust fan power = 0.0 kW
 Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : Dogue Creek typical sys.

01-08-91

Carrier Hourly Analysis Program

6100190202

Prepared By : E A C, PC BURKE, VA.

Page 2 of 2

***** 5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved

Static = 0.35 in wg

Efficiency = 60 %

Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

***** 6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

***** 7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050

Type of supplemental heating = 1 Not Used

DESIGN SPACE HEATING LOADS

Location : Fort Belvoir, Virginia

04-03-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building 900

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 12.0 F

Space Name	Mult	Space Sensible (BTU/hr/space)	Supply Air (CFM/space)
DOGUE CREEK, type 1 ex 1 x	1	43,355.6	958.2
DOGUE CREEK, type 1 ex 2 x	1	45,830.7	1,012.9
DOGUE CREEK, type 1 int. x	2	34,813.2	769.4
DOGUE CREEK, bungalow 1 x	1	43,136.6	953.4

ZONE DESIGN HEATING LOAD SUMMARY

Location : Fort Belvoir, Virginia

04-03-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building 900

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 12.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	70,742
ROOF TRANSMISSION	6,337
GLASS TRANSMISSION	23,725
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	70,125
SLAB FLOOR	12,662
HEATING SAFETY BTU/hr	18,359
SUB-TOTAL	201,949
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	201,949
HEATING SUPPLY CFM	4,463 CFM
HEATING SUPPLY AIR TEMPERATURE	110.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

PLANT DESCRIPTIONS

Plant : Building 900 Oil
 Prepared By : E A C
 Carrier Hourly Analysis Program

04-03-91
 6100190202
 Page 1 of 1

1 PLANT NAME AND TYPES

Class = Individual Plants
 Name = Building 900 Oil
 Cooling Plant Type = User Defined
 Heating Plant Type = Combustion

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Dogue Creek unit 1 ex 1	1	Dogue Creek unit 1 int	2
Dogue Creek unit 1 ex 2	1	Dogue Creek bungalow 1	1

3a COOLING PLANT DATA (User Defined)

Estimated maximum cooling coil load = 0.00 Ton
 Nominal capacity = 0.00 Ton
 Nominal input power rate = 0.000 kW/Ton
 Type of cooling = DX
 Condenser type = Air Cooled

PART LOAD PERFORMANCE

% Load	% Power	% Load	% Power	% Load	% Power
90 -----	100	60 -----	100	30 -----	100
80 -----	100	50 -----	100	20 -----	100
70 -----	100	40 -----	100	10 -----	100

3b HEATING PLANT DATA (Combustion)

Estimated maximum heating coil load = 182.64 MBH
 Fuel type = Fuel Oil
 Rated plant output = 275.0 MBH
 Type of heating = Direct
 Is plant efficiency computer generated ? N
 Seasonal plant efficiency = 78 %

4 PUMP SYSTEM DATA

(No inputs required)

BUILDING DESCRIPTION

Building : Building 900 Oil

04-03-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = Building 900 Oil

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW

Power schedule = 4

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y

Maximum hourly hot water use = 35.0 gal

Hot water schedule = 2

Average entering water temperature = 57.0 F

Average hot water supply temperature = 140.0 F

Heating plant type = 1 : Electric

OTHER INPUTS

Additional building floor area = 0.0 sqft

Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
Building 900 Oil	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	2	Electric (Energy)	MBTU
Natural Gas	3	Natural Gas (Energy)	MBTU
Fuel Oil	4	Distillate Fuel Oil (Energy)	MBTU
Propane	5	Propane	MBTU
Remote Source Heating	9	Remote Source Heating (generic)	MBTU
Remote Source Cooling	10	Remote Source Cooling (generic)	MBTU

ANNUAL COMPONENT COSTS

Building : Building 900 Oil
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-26-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	1	0.000	0.3 %
Cooling Plants	0	0.000	0.0 %
Heating Plants	225	0.039	76.6 %
Pumps	0	0.000	0.0 %
<hr/>			
>>> HVAC Subtotal	226	0.039	76.9 %
<hr/>			
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	68	0.012	23.1 %
<hr/>			
>>> Non-HVAC Sub-total	68	0.012	23.1 %
<hr/>			
>>> GRAND TOTAL	294	0.051	100.0 %
<hr/>			

* Note: 1. Cost per unit floor area is based on the gross building floor area. For this building:

Gross floor area = 5,812 sqft
 Conditioned floor area = 5,812 sqft

ANNUAL ENERGY COSTS

Building : Building 900 Oil
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-26-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	267 kWh	1	0.000	0.3 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	1623 gallon	225	0.039	76.6 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		226	0.039	76.9 %
Non-HVAC Component				
Electric	19894 kWh	68	0.012	23.1 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		68	0.012	23.1 %

>>> GRAND TOTAL		294	0.051	100.0 %

* Note: 1. Cost per unit floor area is based on the gross building floor area. For this building:

Gross floor area = 5,812 sqft
 Conditioned floor area = 5,812 sqft

PLANT DESCRIPTIONS

Plant : Building 900 Gas 04-04-91
 Prepared By : E A C 6100190202
 Carrier Hourly Analysis Program Page 1 of 1

1 PLANT NAME AND TYPES

Class = Individual Plants
 Name = Building 900 Gas
 Cooling Plant Type = User Defined
 Heating Plant Type = Combustion

2 AIR SYSTEM SELECTION

-----		-----	
Air System Name	Mult	Air System Name	Mult

Dogue Creek unit 1 ex 1	1	Dogue Creek unit 1 int	2
Dogue Creek unit 1 ex 2	1	Dogue Creek bungalow 1	1

3a COOLING PLANT DATA (User Defined)

Estimated maximum cooling coil load = 0.00 Ton
 Nominal capacity = 0.00 Ton
 Nominal input power rate = 0.000 kW/Ton
 Type of cooling = DX
 Condenser type = Air Cooled

PART LOAD PERFORMANCE

% Load	% Power	% Load	% Power	% Load	% Power
90 -----	100	60 -----	100	30 -----	100
80 -----	100	50 -----	100	20 -----	100
70 -----	100	40 -----	100	10 -----	100

3b HEATING PLANT DATA (Combustion)

Estimated maximum heating coil load = 182.64 MBH
 Fuel type = Natural Gas
 Rated plant output = 265.0 MBH
 Type of heating = Direct
 Is plant efficiency computer generated ? N
 Seasonal plant efficiency = 84 %

4 PUMP SYSTEM DATA

(No inputs required)

BUILDING DESCRIPTION

Building : Building 900 Gas

04-04-91

Prepared By: E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1. BUILDING INPUTS

BUILDING NAME = Building 900 Gas

MISCELLANEOUS ELECTRIC

Maximum power = 0.0 kW
Power schedule = 4

DOMESTIC WATER HEATING

Is a domestic hot water system used ? Y
Maximum hourly hot water use = 35.0 gal
Hot water schedule = 2
Average entering water temperature = 57.0 F
Average hot water supply temperature = 140.0 F
Heating plant type = 2 : Combustion
Fuel type = 1 : Natural Gas
Plant capacity = 200.0 MBH
Is plant efficiency computer generated ? N
Annual plant efficiency = 80 %

OTHER INPUTS

Additional building floor area = 0.0 sqft
Electrical generating efficiency = 100.00 %

2. PLANT SELECTION

Plant Name	Mult	Plant Name	Mult
Building 900 Gas	1		

3. FUEL & ELECTRIC RATE SELECTION

Fuel or Energy	No.	Name of Rate Schedule	Currency
Electric	2	Electric (Energy)	MBTU
Natural Gas	3	Natural Gas (Energy)	MBTU
Fuel Oil	4	Distillate Fuel Oil (Energy)	MBTU
Propane	5	Propane	MBTU
Remote Source Heating	9	Remote Source Heating (generic)	MBTU
Remote Source Cooling	10	Remote Source Cooling (generic)	MBTU

ANNUAL ENERGY COSTS

Building : Building 900 Gas
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual (MBTU)	Costs * --> (MBTU/sqft)	% of Total
Electric	267 kWh	1	0.000	0.3 %
Natural Gas	2091 Therms	209	0.036	70.8 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %

>>> HVAC Subtotal		210	0.036	71.1 %

Non-HVAC Component

Electric	0 kWh	0	0.000	0.0 %
Natural Gas	854 Therms	85	0.015	28.9 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %

>>> Non-HVAC Subtotal		85	0.015	28.9 %

=====

>>> GRAND TOTAL		295	0.051	100.0 %
-----------------	--	-----	-------	---------

=====

* Note: 1. Cost per unit floor area is based on the gross building floor area. For this building:

Gross floor area	=	5,812 sqft
Conditioned floor area	=	5,812 sqft

ANNUAL COMPONENT COSTS

Building : Building 900 Gas
 Site : Fort Belvoir, Virginia
 Prepared By : E A C

04-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	1	0.000	0.3 %
Cooling Plants	0	0.000	0.0 %
Heating Plants	209	0.036	70.8 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	210	0.036	71.1 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	85	0.015	28.9 %
>>> Non-HVAC Sub-total	85	0.015	28.9 %
>>> GRAND TOTAL	295	0.051	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 5,812 sqft
 Conditioned floor area = 5,812 sqft

FUEL OIL COSTS

Building : #900 OIL - ENERGY (\$)

08-29-91

Site : Fort Belvoir, Virginia

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Fixed Charges	Taxes	Total Charges
Jan	470	0	0	470
Feb	349	0	0	349
Mar	194	0	0	194
Apr	34	0	0	34
May	0	0	0	0
June	0	0	0	0
July	0	0	0	0
Aug	0	0	0	0
Sept	0	0	0	0
Oct	26	0	0	26
Nov	189	0	0	189
Dec	411	0	0	411

Tot.	1,673	0	0	1,673
------	-------	---	---	-------

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (MBTU)	Effective Rate (\$/MBTU)
Jan	470	63	7.43000
Feb	349	47	7.43000
Mar	194	26	7.43000
Apr	34	5	7.43000
May	0	0	7.43000
June	0	0	7.43000
July	0	0	7.43000
Aug	0	0	7.43000
Sept	0	0	7.43000
Oct	26	3	7.43000
Nov	189	25	7.43000
Dec	411	55	7.43000
Tot.	1,673	225	7.43000

FUEL OIL COSTS

Building : #901 OIL - ENERGY (\$)

08-29-91

Site : Fort Belvoir, Virginia

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Fixed Charges	Taxes	Total Charges
Jan	618	0	0	618
Feb	465	0	0	465
Mar	268	0	0	268
Apr	51	0	0	51
May	0	0	0	0
June	0	0	0	0
July	0	0	0	0
Aug	0	0	0	0
Sept	0	0	0	0
Oct	37	0	0	37
Nov	254	0	0	254
Dec	541	0	0	541
Tot.	2,235	0	0	2,235

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (MBTU)	Effective Rate (\$/MBTU)
Jan	618	83	7.43000
Feb	465	63	7.43000
Mar	268	36	7.43000
Apr	51	7	7.43000
May	0	0	7.43000
June	0	0	7.43000
July	0	0	7.43000
Aug	0	0	7.43000
Sept	0	0	7.43000
Oct	37	5	7.43000
Nov	254	34	7.43000
Dec	541	73	7.43000
Tot.	2,235	301	7.43000

FUEL OIL COSTS

Building : #914 OIL - ENERGY (\$)

08-29-91

Site : Fort Belvoir, Virginia

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Fixed Charges	Taxes	Total Charges
Jan	898	0	0	898
Feb	666	0	0	666
Mar	368	0	0	368
Apr	64	0	0	64
May	0	0	0	0
June	0	0	0	0
July	0	0	0	0
Aug	0	0	0	0
Sept	0	0	0	0
Oct	49	0	0	49
Nov	364	0	0	364
Dec	786	0	0	786
Tot.	3,194	0	0	3,194

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (MBTU)	Effective Rate (\$/MBTU)
Jan	898	121	7.43000
Feb	666	90	7.43000
Mar	368	49	7.43000
Apr	64	9	7.43000
May	0	0	7.43000
June	0	0	7.43000
July	0	0	7.43000
Aug	0	0	7.43000
Sept	0	0	7.43000
Oct	49	7	7.43000
Nov	364	49	7.43000
Dec	786	106	7.43000
Tot.	3,194	430	7.43000

FUEL OIL COSTS

Building : #922 OIL - ENERGY (\$)

08-29-91

Site : Fort Belvoir, Virginia

6100190202

Prepared By : E A C, PC BURKE, VA.

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. MONTHLY COMPONENT CHARGES (Dollars)

Month	Energy Charges	Fixed Charges	Taxes	Total Charges
Jan	795	0	0	795
Feb	587	0	0	587
Mar	320	0	0	320
Apr	53	0	0	53
May	0	0	0	0
June	0	0	0	0
July	0	0	0	0
Aug	0	0	0	0
Sept	0	0	0	0
Oct	42	0	0	42
Nov	321	0	0	321
Dec	697	0	0	697
Tot.	2,815	0	0	2,815

TABLE 2. MONTHLY TOTALS

Month	Charges (\$)	Energy (MBTU)	Effective Rate (\$/MBTU)
Jan	795	107	7.43000
Feb	587	79	7.43000
Mar	320	43	7.43000
Apr	53	7	7.43000
May	0	0	7.43000
June	0	0	7.43000
July	0	0	7.43000
Aug	0	0	7.43000
Sept	0	0	7.43000
Oct	42	6	7.43000
Nov	321	43	7.43000
Dec	697	94	7.43000
Tot.	2,815	379	7.43000

900 AREA (DOGUE CREEK)

Fuel Conversion:

Description - Existing oil-fired furnaces used for heating and electric water heaters are proposed to be replaced by gas-fired boilers and water heaters respectively.

Energy Saved	= -23	MBTU/year
Cost	= \$205,446	(incl. SIOH)
SIR	= 3.84	

FORT BELVOIR DOGUE CREEK HOUSING AREA

CONSOLIDATION OF OTHER COSTS

TYP.BLDG	No.	MAINT. COST PER BLDG	ONE TIME REPLAC.COSTS \$ PER BUILDING		MAINT. COSTS \$	ONE TIME REPLAC. COSTS \$	
			ELEC. WH	GAS WH		ELEC. WH	GAS WH
900	28	50	2850	-3236	1400	79800	-90608
901	7	60	3420	-3883	420	23940	-27181
914	8	90	5130	-5825	720	41040	-46600
922	2	80	4560	-5178	160	9120	-10356
TOTAL	45				2700	153900	-174745

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

DOGUE CREEK VILLAGE - BUILDING 900 (28 buildings)

For evaluating conversion to gas, it is assumed that the project can be implemented in conjunction with the Norfolk District Corps of Engineers Project 24566, design for which is under way. As such, only incremental costs have been considered.

Proposed conversion

Estimated cost of gas-fired furnace	= \$ 5,556
Estimated cost of gas-fired water heater	= \$ 3,236
Total cost of conversion now	= \$ 8,792

Existing systems

Estimated cost of oil-fired furnace (under an on-going contract)	= \$ 4,820
Estimated cost of electric water heater	= \$ 2,850
Total cost of replacement now	= \$ 7,670

Incremental cost now	= \$ 8,792 - \$ 7,670	= \$ 1,122
----------------------	-----------------------	------------

Total incremental cost	= \$1,122 X 28 (bldg)	= \$31,416
------------------------	-----------------------	------------

Water heater replacement costs

Gas-fired waterheaters	= \$3,236 X 28	= \$90,608
Electric water heaters	= \$2,850 X 28	= \$79,800

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Building 900
Dogue Creek Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 1: Oil furnaces
Electric water heaters

Oil furnaces:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install oil furnaces	5	each	\$97	\$485	\$650	\$3,250	\$3,735
SUB-TOTAL:				\$485		\$3,250	\$3,735
Labor Markup: 21%				\$102		---	\$102
Taxes: 4.5%				---		\$146	\$146
SUB-TOTAL:				\$587		\$3,396	\$3,983
Overhead: 10%				\$59		\$340	\$398
SUB-TOTAL:				\$646		\$3,736	\$4,381
Profit: 10%				\$65		\$374	\$438
TOTAL:				\$710		\$4,109	\$4,820

Electric water heaters:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install electric water heater	5	each	\$195	\$975	\$225	\$1,125	\$2,100
SUB-TOTAL:				\$975		\$1,125	\$2,100
Labor Markup: 21%				\$205		---	\$205
Taxes: 4.5%				---		\$51	\$51
SUB-TOTAL:				\$1,180		\$1,176	\$2,355
Overhead: 10%				\$118		\$118	\$236
SUB-TOTAL:				\$1,298		\$1,293	\$2,591
Profit: 10%				\$130		\$129	\$259
TOTAL:				\$1,427		\$1,423	\$2,850

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Building 900
Dogue Creek Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 2: Gas furnaces
Gas water heaters

Gas furnaces:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas furnaces	5	each	\$90	\$450	\$540	\$2,700	\$3,150
Remove oil tanks	1	each	\$1,000	\$1,000	\$15	\$15	\$1,015
SUB-TOTAL:				\$1,450		\$2,715	\$4,165
Labor Markup: 21%				\$305		---	\$305
Taxes: 4.5%				---		\$122	\$122
SUB-TOTAL:				\$1,755		\$2,837	\$4,592
Overhead: 10%				\$175		\$284	\$459
SUB-TOTAL:				\$1,930		\$3,121	\$5,051
Profit: 10%				\$193		\$312	\$505
TOTAL:				\$2,123		\$3,433	\$5,556

Gas water heaters:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas water heaters	5	each	\$265	\$1,325	\$205	\$1,025	\$2,350
SUB-TOTAL:				\$1,325		\$1,025	\$2,350
Labor Markup: 21%				\$278		---	\$278
Taxes: 4.5%				---		\$46	\$46
SUB-TOTAL:				\$1,603		\$1,071	\$2,674
Overhead: 10%				\$160		\$107	\$267
SUB-TOTAL:				\$1,764		\$1,178	\$2,942
Profit: 10%				\$176		\$118	\$294
TOTAL:				\$1,940		\$1,296	\$3,236

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

DOGUE CREEK VILLAGE - BUILDING 901 (7 buildings)

For evaluating conversion to gas, it is assumed that the project can be implemented in conjunction with the Norfolk District Corps of Engineers Project 24566, design for which is under way. As such, only incremental costs have been considered.

Proposed conversion

Estimated cost of gas-fired furnace	= \$ 6,370
Estimated cost of gas-fired water heater	= \$ 3,883
Total cost of conversion now	= \$10,253

Existing systems

Estimated cost of oil-fired furnace (under an on-going contract)	= \$ 5,783
Estimated cost of electric water heater	= \$ 3,420
Total cost of replacement now	= \$ 9,203

Incremental cost now = \$10,253 - \$ 9,203 = \$ 1,050

Total incremental cost = \$1,050 X 7 (bldg) = \$7,350

Water heater replacement costs

Gas-fired waterheaters	= \$3,883 X 7	= \$27,181
Electric water heaters	= \$3,420 X 7	= \$23,940

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Building 901
Dogue Creek Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 1: Oil furnaces
Electric water heaters

Oil furnaces:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install oil furnaces	6	each	\$97	\$582	\$650	\$3,900	\$4,482
SUB-TOTAL:				\$582		\$3,900	\$4,482
Labor Markup: 21%				\$122		---	\$122
Taxes: 4.5%				---		\$176	\$176
JB-TOTAL:				\$704		\$4,076	\$4,780
Overhead: 10%				\$70		\$408	\$478
SUB-TOTAL:				\$775		\$4,483	\$5,258
Profit: 10%				\$77		\$448	\$526
TOTAL:				\$852		\$4,931	\$5,783

Electric water heaters:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install electric water heater	6	each	\$195	\$1,170	\$225	\$1,350	\$2,520
SUB-TOTAL:				\$1,170		\$1,350	\$2,520
Labor Markup: 21%				\$246		---	\$246
Taxes: 4.5%				---		\$61	\$61
SUB-TOTAL:				\$1,416		\$1,411	\$2,826
Overhead: 10%				\$142		\$141	\$283
SUB-TOTAL:				\$1,557		\$1,552	\$3,109
Profit: 10%				\$156		\$155	\$311
TOTAL:				\$1,713		\$1,707	\$3,420

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Building 901
Dogue Creek Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 2: Gas furnaces
Gas water heaters

Gas furnaces:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas furnaces	6	each	\$90	\$540	\$540	\$3,240	\$3,780
Remove oil tanks	1	each	\$1,000	\$1,000	\$15	\$15	\$1,015
SUB-TOTAL:				\$1,540		\$3,255	\$4,795
Labor Markup: 21%				\$323		---	\$323
Taxes: 4.5%				---		\$146	\$146
SUB-TOTAL:				\$1,863		\$3,401	\$5,265
Overhead: 10%				\$186		\$340	\$526
SUB-TOTAL:				\$2,050		\$3,742	\$5,791
Profit: 10%				\$205		\$374	\$579
TOTAL:				\$2,255		\$4,116	\$6,370

Gas water heaters:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas water heaters	6	each	\$265	\$1,590	\$205	\$1,230	\$2,820
SUB-TOTAL:				\$1,590		\$1,230	\$2,820
Labor Markup: 21%				\$334		---	\$334
Taxes: 4.5%				---		\$55	\$55
SUB-TOTAL:				\$1,924		\$1,285	\$3,209
Overhead: 10%				\$192		\$129	\$321
SUB-TOTAL:				\$2,116		\$1,414	\$3,530
Profit: 10%				\$212		\$141	\$353
TOTAL:				\$2,328		\$1,555	\$3,883

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

DOGUE CREEK VILLAGE - BUILDING 914 (8 buildings)

For evaluating conversion to gas, it is assumed that the project can be implemented in conjunction with the Norfolk District Corps of Engineers Project 24566, design for which is under way. As such, only incremental costs have been considered.

Proposed conversion

Estimated cost of gas-fired furnace	= \$ 8,814
Estimated cost of gas-fired water heater	= \$ 5,825
Total cost of conversion now	= \$14,639

Existing systems

Estimated cost of oil-fired furnace (under an on-going contract)	= \$ 8,675
Estimated cost of electric water heater	= \$ 5,130
Total cost of replacement now	= \$13,805

Incremental cost now = \$14,639 - \$13,805 = \$ 834

Total incremental cost = \$834 X 8 (bldg) = \$ 6,672

Water heater replacement costs

Gas-fired waterheaters	= \$5,825 X 8	= \$46,600
Electric water heaters	= \$5,130 X 8	= \$41,040

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Building 914
Dogue Creek Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 1: Oil furnaces
Electric water heaters

Oil furnaces:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install oil furnaces	9	each	\$97	\$873	\$650	\$5,850	\$6,723
SUB-TOTAL:				\$873		\$5,850	\$6,723
Labor Markup: 21%				\$183		---	\$183
Taxes: 4.5%				---		\$263	\$263
JB-TOTAL:				\$1,056		\$6,113	\$7,170
Overhead: 10%				\$106		\$611	\$717
SUB-TOTAL:				\$1,162		\$6,725	\$7,887
Profit: 10%				\$116		\$672	\$789
TOTAL:				\$1,278		\$7,397	\$8,675

Electric water heaters:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install electric water heater	9	each	\$195	\$1,755	\$225	\$2,025	\$3,780
SUB-TOTAL:				\$1,755		\$2,025	\$3,780
Labor Markup: 21%				\$369		---	\$369
Taxes: 4.5%				---		\$91	\$91
SUB-TOTAL:				\$2,124		\$2,116	\$4,240
Overhead: 10%				\$212		\$212	\$424
SUB-TOTAL:				\$2,336		\$2,328	\$4,664
Profit: 10%				\$234		\$233	\$466
TOTAL:				\$2,569		\$2,561	\$5,130

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Building 914
Dogue Creek Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 2: Gas furnaces
Gas water heaters

Gas furnaces:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas furnaces	9	each	\$90	\$810	\$540	\$4,860	\$5,670
Remove oil tanks	1	each	\$1,000	\$1,000	\$15	\$15	\$1,015
SUB-TOTAL:				\$1,810		\$4,875	\$6,685
Labor Markup: 21%				\$380		---	\$380
Taxes: 4.5%				---		\$219	\$219
SUB-TOTAL:				\$2,190		\$5,094	\$7,284
Overhead: 10%				\$219		\$509	\$728
SUB-TOTAL:				\$2,409		\$5,604	\$8,013
Profit: 10%				\$241		\$560	\$801
TOTAL:				\$2,650		\$6,164	\$8,814

Gas water heaters:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas water heaters	9	each	\$265	\$2,385	\$205	\$1,845	\$4,230
SUB-TOTAL:				\$2,385		\$1,845	\$4,230
Labor Markup: 21%				\$501		---	\$501
Taxes: 4.5%				---		\$83	\$83
SUB-TOTAL:				\$2,886		\$1,928	\$4,814
Overhead: 10%				\$289		\$193	\$481
SUB-TOTAL:				\$3,174		\$2,121	\$5,295
Profit: 10%				\$317		\$212	\$530
TOTAL:				\$3,492		\$2,333	\$5,825

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

DOGUE CREEK VILLAGE - BUILDING 922 (2 buildings)

For evaluating conversion to gas, it is assumed that the project can be implemented in conjunction with the Norfolk District Corps of Engineers Project 24566, design for which is under way. As such, only incremental costs have been considered.

Proposed conversion

Estimated cost of gas-fired furnace	= \$ 8,000
Estimated cost of gas-fired water heater	= \$ 5,178
Total cost of conversion now	= \$13,178

Existing systems

Estimated cost of oil-fired furnace (under an on-going contract)	= \$ 7,711
Estimated cost of electric water heater	= \$ 4,560
Total cost of replacement now	= \$12,271

Incremental cost now = \$13,178 - \$12,271 = \$ 907

Total incremental cost = \$907 X 2 (bldg) = \$ 1,814

Water heater replacement costs

Gas-fired waterheaters	= \$5,178 X 2	= \$10,356
Electric water heaters	= \$4,560 X 2	= \$ 9,120

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Building 922
Dogue Creek Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 1: Oil furnaces
Electric water heaters

Oil furnaces:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install oil furnaces	8	each	\$97	\$776	\$650	\$5,200	\$5,976
SUB-TOTAL:				\$776		\$5,200	\$5,976
Labor Markup: 21%				\$163		---	\$163
Taxes: 4.5%				---		\$234	\$234
SUB-TOTAL:				\$939		\$5,434	\$6,373
Overhead: 10%				\$94		\$543	\$637
SUB-TOTAL:				\$1,033		\$5,977	\$7,010
Profit: 10%				\$103		\$598	\$701
TOTAL:				\$1,136		\$6,575	\$7,711

Electric water heaters:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install electric water heater	8	each	\$195	\$1,560	\$225	\$1,800	\$3,360
SUB-TOTAL:				\$1,560		\$1,800	\$3,360
Labor Markup: 21%				\$328		---	\$328
Taxes: 4.5%				---		\$81	\$81
SUB-TOTAL:				\$1,888		\$1,881	\$3,769
Overhead: 10%				\$189		\$188	\$377
SUB-TOTAL:				\$2,076		\$2,069	\$4,145
Profit: 10%				\$208		\$207	\$415
TOTAL:				\$2,284		\$2,276	\$4,560

CONSTRUCTION COST ESTIMATE

Project: Energy Savings Opportunity Survey

Location: Building 922
Dogue Creek Village
Fort Belvoir, VA

By: Engineering Applications Consultants

Alternative 2: Gas furnaces
Gas water heaters

Gas furnaces:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas furnaces	8	each	\$90	\$720	\$540	\$4,320	\$5,040
Remove oil tanks	1	each	\$1,000	\$1,000	\$15	\$15	\$1,015
SUB-TOTAL:				\$1,720		\$4,335	\$6,055
Labor Markup: 21%				\$361		---	\$361
Taxes: 4.5%				---		\$195	\$195
SUB-TOTAL:				\$2,081		\$4,530	\$6,611
Overhead: 10%				\$208		\$453	\$661
SUB-TOTAL:				\$2,289		\$4,983	\$7,272
Profit: 10%				\$229		\$498	\$727
TOTAL:				\$2,518		\$5,481	\$8,000

Gas water heaters:

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install gas water heaters	8	each	\$265	\$2,120	\$205	\$1,640	\$3,760
SUB-TOTAL:				\$2,120		\$1,640	\$3,760
Labor Markup: 21%				\$445		---	\$445
Taxes: 4.5%				---		\$74	\$74
SUB-TOTAL:				\$2,565		\$1,714	\$4,279
Overhead: 10%				\$257		\$171	\$428
SUB-TOTAL:				\$2,822		\$1,885	\$4,707
Profit: 10%				\$282		\$189	\$471
TOTAL:				\$3,104		\$2,074	\$5,178

CONSTRUCTION COST ESTIMATE				DATE PREPARED JULY '91		SHEET 1 OF 1	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY					BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____		
LOCATION FT. BELVOIR, VIRGINIA							
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS							
DRAWING NO. DOGUE CREEK (900 AREA)				ESTIMATOR REF		CHECKED BY VF	
<u>GAS to BLDGS.</u> SUMMARY		QUANTITY		LABOR		MATERIAL	
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL
TRENCH & BACKFILL 10,000 LF 1.01 10,100. 74 7400. 17,500.							
HAND EXCAVATING 300 CY 34.00 10,200. — 10,200.							
HAND BACKFILLING 300 CY 12.45 3,735. — 3,735.							
POLYETHYLENE PIPE - 1/4" 11,000 LF 1.17 12,870 .55 6,050. 18,920.							
BLACK STEEL PIPE - 3/4" 5,400 LF 3.21 17,334. .87 4,693. 22,028.							
MAIN CONNECTION 160 EA 15.00 2,400. 5.00 800. 3,200.							
STOP VALVES - 3/4" 540 EL 9.00 4,860. 8.05 4,347. 9,207.							
PRESSURE REGULATOR 270 EA 10.00 2,700. 50.00 13,500. 16,200.							
HAULING 60 CY 2.21 133. 4.33 260. 393.							
DISPOSAL OF MATERIALS — LS — 500. — 500.							
MATERIAL HANDL./STORAGE — LS — 400. — 400.							
SEED/SOD — LS — 300. — 300.							
GAS LINE TESTING 160 EA 10.00 1,600. — 1,600.							
GENERAL CLEAN-UP 160 EA 10.00 1,600. — 1,600.							
SUB-TOTAL 63,732. 37,055. 105,787.							
LABOR, INS. & TAXES 21% 14,434. — 14,434.							
SALES TRX 4.5% — 1,667. 1,667.							
SUB-TOTAL 83,166. 38,722 121,888.							
OVERHEAD 10% 12,189.							
SUB-TOTAL 134,077							
PROFIT 10% 13,407							
SUB-TOTAL 147,484							
TOTAL 147,484.							

PROPORTIONATE COST/UNIT \bar{c}_9 $\frac{147484}{270}$

= \$ 546.

Engineering
Applications
Consultants

A Professional
Corporation

9004-B Crownwood Ct.
Burke, Virginia 22015-1630
(703) 978-0923

ENGINEERING ANALYSIS

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

DOGUE CREEK VILLAGE - SUMMARY OF INCREMENTAL COSTS

Typical Building 900 (28 buildings)	=	\$ 31,416
Typical building 901 (7 buildings)	=	\$ 7,350
Typical building 914 (8 buildings)	=	\$ 6,672
Typical building 922 (2 buildings)	=	\$ 1,814
Cost to Govt. for curb-to-building gas lines	=	\$147,484
Total - Cost of fuel conversion		\$194,736

Replacement costs of water heaters:

	<u>Gas-fired</u>	<u>Electric</u>
Typical Building 900	\$ 90,608	\$ 79,800
Typical building 901	\$ 27,181	\$ 23,940
Typical building 914	\$ 46,600	\$ 41,040
Typical building 922	\$ 10,356	\$ 9,120
TOTAL	\$174,745	\$153,900

PORT BELVOIR DOGUE CREEK HOUSING AREA

CONSTRUCTION COSTS AND ENERGY SAVINGS CONSOLIDATION

TYP. BLDG	No.	SAVINGS, PER BUILDING			TOTAL SAVINGS		
		ELEC.	OIL	GAS	ELEC.	OIL	GAS
		MBTU	MBTU	MBTU	MBTU	MBTU	MBTU
900	28	68	225	-294	1904	6300	-8232
901	7	82	301	-382	574	2107	-2674
914	8	123	430	-553	984	3440	-4424
922	2	109	379	-489	218	758	-978
TOTAL	45				3680	12605	-16308

LIFE CYCLE COST ANALYSIS SUMMARY
ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

LOCATION: FORT BELVOIR REGION NO. 3 PROJECT NUMBER DACA-31-89-C-0198
 PROJECT TITLE: ENERGY SAVINGS OPPORTUNITY SURVEY FISCAL YR. 199
 DISCRETE PORTION NAME DOQUE CREEK - OIL TO GAS CONVERSION
 ANALYSIS DATE August '91 ECONOMIC LIFE 15 YEARS PREPARED BY EAC

1. INVESTMENT

A. CONSTRUCTION COST	\$	<u>194,736</u>	
B. SIOH	\$	<u>10,710</u>	
C. DESIGN COST	\$	<u>11,684</u>	
D. SALVAGE VALUE	-	<u>\$</u>	
E. TOTAL INVESTMENT (1A + 1B + 1C - 1D)			\$ <u>217,130</u>

2. ENERGY SAVINGS (+) / COST (-)

ANALYSIS DATE ANNUAL SAVINGS, UNIT COST AND DISCOUNTED SAVINGS

FUEL	COST \$/MBTU/YR(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS (5)
A. ELEC	\$ <u>18.05</u>	<u>3680</u>	\$ <u>66424</u>	<u>11.11</u>	\$ <u>737,971</u>
B. DIST	\$ <u>7.43</u>	<u>12605</u>	\$ <u>93655</u>	<u>14.26</u>	\$ <u>1,335,520</u>
C. RESID	\$ <u>6.62</u>		\$		\$
D. NG	\$ <u>5.33</u>	<u>-16308</u>	\$ <u>-86922</u>	<u>14.45</u>	\$ <u>-1,256,023</u>
E. COAL	\$		\$		\$
F. TOTAL		<u>-23</u>	\$ <u>73,157</u>		\$ <u>817,468</u>

NONENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)		MAINT.	\$ <u>2,700</u>
(1) DISCOUNT FACTOR (TABLE A)		<u>10.59</u>	
(2) DISCOUNTED SAVING/COST (3A X 3A1)			\$ <u>28593</u>

B. NONRECURRING SAVINGS (+) / COST (-)

ITEM	SAVINGS (+) COST (-)(1)	YEAR OF OCCUR.(2)	DISCOUNT FACTOR(3)	DISCOUNTED SAV- INGS(+) COST(-)(4)
REPL.				
(1) ELEC WH	\$ <u>153,900</u>	<u>10</u>	<u>0.63</u>	\$ <u>96,957</u>
(2)	\$			\$ <u>-110,089</u>
(3) GAS WH	\$ <u>-174,745</u>	<u>10</u>	<u>0.63</u>	\$
(4) TOTAL	\$ <u>-20,845</u>			\$ <u>-13,132</u>

C. TOTAL NONENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 15,461

D. PROJECT NONENERGY QUALIFICATION TEST

(1) 25% MAX NONENERGY CALC (2F5 x .33)		\$ <u>269,764</u>	
a. IF 3D1 IS = OR > 3C GO TO ITEM 4			
b. IF 3D1 IS < 3C CALC S1R = (2F5+3D1) - 1E =			
c. IF 3D1 IS = > 1 GO TO ITEM 4			
d. IF 3D1 IS < 1 PROJECT DOES NOT QUALIFY			

4. FIRST YEAR DOLLAR SAVINGS 2F3 + 3A + (3B1d ÷ YEARS ECONOMIC LIFE) \$ 74,467

5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C) \$ 832,929

6. DISCOUNTED SAVINGS RATION (IF < 1 PROJECT DOES NOT QUALIFY) (S1R) = (5-1E) = 3.84

SIMPLE PAYBACK PERIOD = 2.9 years


BUILDINGS 2600 TO 2787
WOODLAWN VILLAGE
(TYPICALS)

2600 AREA (WOODLAWN VILLAGE)

Fuel Conversion:

Description - Existing heat pumps and electric water heaters are proposed to be replaced by gas-fired boilers and water heaters respectively.

Energy Saved	= -9,391	MBTU/year
Cost	= \$1,864,793	(incl. SIOH)
SIR	= 0.72	



DATE		BY		CHECKED	
10/1/50		J. H. HARRIS		J. H. HARRIS	
UNITED STATES ARMY DESIGN CENTER AND PORT WATSON DIRECTORATE OF FACILITIES ENGINEERING PORT BLUICK, VIRGINIA 22060					
WOODLAWN VILLAGE					
DESIGNED BY	ENGINEER	ARCHITECT	PAVING	LANDSCAPE	UTILITY
J. H. HARRIS	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
SCALE: 1" = 100' (AS SHOWN) SHEET NO. 2600-1A TOTAL SHEETS: 1					

2600-1A

2600 AREA (WOODLAWN VILLAGE)

TABLE OF CONTENTS

Input Data	2
Output Data	47
ECIP Analysis	
Energy Savings	68
Cost Summary	90-91
LCC Analysis	92

DESIGN PARAMETERS, SHGs

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

DESIGN WEATHER PARAMETERS

City Name.....: Washington
 Location.....: Dist. of Columbia
 Latitude.....: 38.9 deg
 Elevation.....: 14.0 ft
 Summer Design Dry Bulb Temp.....: 92.0 F
 Summer Design Wet Bulb Temp.....: 75.0 F
 Daily Temperature Range.....: 19.0 F
 Winter Design Dry Bulb Temp.....: 17.0 F
 Atmospheric Clearness Number.....: 1.00

TABLE 1. MAXIMUM SOLAR HEAT GAINS - AVERAGE DAYS
(BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	24.1	62.5	99.8	113.0	99.8	62.5	24.1	24.1	80.1
Feb	31.7	75.8	107.6	116.0	107.6	75.8	31.7	31.7	107.4
Mar	40.7	87.6	108.1	109.4	108.1	87.6	40.7	40.7	136.8
Apr	59.9	97.7	105.1	98.3	105.1	97.7	59.9	49.1	164.1
May	74.6	103.1	99.0	85.1	99.0	103.1	74.6	54.8	181.4
Jun	84.8	109.2	98.1	80.2	98.1	109.2	84.8	57.8	194.7
Jul	80.3	106.6	98.8	82.5	98.8	106.6	80.3	56.3	188.8
Aug	69.0	104.3	106.5	95.6	106.5	104.3	69.0	52.0	177.3
Sep	52.3	99.9	115.9	113.0	115.9	99.9	52.3	45.2	158.0
Oct	36.2	89.3	119.5	125.0	119.5	89.3	36.2	36.2	128.3
Nov	26.5	67.8	104.1	116.0	104.1	67.8	26.5	26.5	89.6
Dec	21.3	54.3	90.1	103.8	90.1	54.3	21.3	21.3	68.5

TABLE 2. MAXIMUM SOLAR HEAT GAINS - DESIGN DAYS
(BTU/hr/sqft)

Month	NE	E	SE	S	SW	W	NW	N	Hor
Jan	20.1	157.3	243.1	254.0	243.1	157.3	20.1	20.1	139.2
Feb	52.1	188.2	246.1	238.6	246.1	188.2	52.1	24.5	185.3
Mar	95.2	219.1	235.0	202.5	235.0	219.1	95.2	29.3	227.0
Apr	141.2	224.2	201.1	149.0	201.1	224.2	141.2	34.0	254.7
May	165.8	220.1	171.9	107.1	171.9	220.1	165.8	37.3	267.1
Jun	172.9	215.5	158.0	90.2	158.0	215.5	172.9	47.5	269.0
Jul	163.3	215.7	167.6	103.9	167.6	215.7	163.3	38.2	263.9
Aug	136.0	216.4	194.0	144.0	194.0	216.4	136.0	35.7	250.0
Sep	89.4	206.5	225.0	196.5	225.0	206.5	89.4	30.4	219.5
Oct	51.1	181.8	238.3	231.6	238.3	181.8	51.1	25.3	182.0
Nov	20.5	154.5	239.0	250.1	239.0	154.5	20.5	20.5	138.6
Dec	18.2	139.9	235.2	253.9	235.2	139.9	18.2	18.2	119.3

STATE	Station	WINTER DESIGN DATA HEATING				DEGREE DAYS	SUMMER DESIGN DATA AIR CONDITIONING										SUMMER CRITERIA D.A. AIR CONDITIONING					
		LOCATION					Dry Bulb				Wet Bulb				Dry Bulb				Wet Bulb			
		Lat	Long	Elev		99%	97.5%	Pvg	Mean	1% MCWB	2.5% MCWB	5% MCWB	Pvg	1% MCWB	2.5% MCWB	5% MCWB	≥ 93°F	≥ 93°F	≥ 73°F	≥ 73°F		
				feet	°F	°F	dir	knots	annual	°F	°F	°F	dir	°F	°F	°F	hrs	hrs	hrs	hrs		
UTAH (CONT)																						
	Ogden MAP	N 41 12	112 01	4455	1	5	S	6	6012	93 63	91 61	26	SW	88 61	66 65	64	37	727	0	19		
	Provo	40 13	111 43	4448	1	6	SE	5	5720	98 62	96 62	32	SW	94 61	66 65	64	185	989	0	26		
	Salt Lake City IAP	40 46	111 58	4220	3	8	SSE	6	5983	97 62	95 62	32	N	92 61	66 65	64	139	932	0	26		
	Tooele Army Depot	40 31	112 25	4700	4	7	SE	4	5941	93 61	91 61	24	N	88 60	65 64	63	41	704	0	5		
	Utah Army Depot	41 15	112 00	4270	2	6	S	6	6012	94 63	92 61	26	SW	89 61	66 65	64	59	849	0	19		
	Wendover AF Range	40 44	114 02	4237	8	12	ENE	4	5673	97 60	95 59	25	E	93 59	65 64	62	158	1144	0	4		
VERMONT																						
	Burlington IAP	N 44 28	73 09	332	-12	-7	E	7	7876	88 72	85 70	24	SSW	82 69	74 72	71	4	263	67	546		
	St Albans AFS	44 46	73 03	1310	-17	-11	E	9	8790	85 70	82 68	24	SSW	79 67	72 70	69	1	119	21	307		
VIRGINIA																						
	Arlington Hall	N 38 52	77 06	200	13	17	WNW	11	4211	94 75	91 74	21	S	89 74	78 77	76	55	815	580	1744		
	Bedford AFS	37 31	79 30	4220	-3	1	NW	9	7382	82 66	80 66	22	SW	77 65	69 68	67	0	87	0	216		
	Cameron Station	38 48	77 07	60	13	17	WNW	11	4211	94 75	91 74	21	S	89 74	78 77	76	55	815	580	1744		
	Camp A P Hill	38 08	77 21	230	10	14	NW	6	4398	96 77	93 76	21	S	90 75	80 78	77	90	897	710	1884		
	Camp Pickett/Blackstone AAF	37 05	77 57	390	15	19	NW	6	3841	95 77	92 76	22	SW	90 76	79 78	77	66	905	804	2086		
	Cape Charles AFS	37 08	75 57	13	20	23	N	11	3474	90 77	88 76	17	SW	86 75	79 78	77	0	596	856	2184		
	Charlottesville	38 02	78 31	870	14	18	NE	7	4162	94 74	91 74	23	SW	88 73	77 76	75	54	964	376	1544		
	Dahlgren NAVSURFWPNCEN	38 20	77 02	21	10	14	NW	6	4498	93 77	91 76	21	S	89 75	80 78	77	39	892	710	1884		
	Dam Neck	36 47	75 57	10	19	22	N	11	3639	91 77	89 76	17	SW	87 75	79 78	77	12	708	856	2184		
	Dulles IAP	38 57	77 27	313	7	11	NW	9	5010	93 74	90 73	23	S	88 73	77 76	75	28	749	386	1417		
	Fort Belvoir/Davison AAF	38 43	77 11	69	8	12	NW	9	4891	92 76	90 75	23	S	88 74	78 77	76	23	781	551	1668		
	Fort Eustis/Felker AAF	37 08	76 37	145	17	20	N	10	3752	92 77	90 76	17	SSW	88 75	80 78	77	26	875	807	2065		
	Fort Lee	37 14	77 21	145	14	17	N	6	3939	95 76	92 76	22	SW	90 75	79 78	77	70	932	765	1973		
	Fort Lee AFS	37 14	77 20	15	17	20	NW	9	3623	92 78	90 77	17	SW	87 76	79 78	77	70	932	765	1973		
	Fort Monroe	37 00	76 19	15	17	20	NW	9	3623	92 78	90 77	17	SW	87 76	79 78	77	21	809	1010	2290		
	Fort Myer	38 53	77 05	220	14	17	WNW	11	4211	93 75	91 74	19	S	89 74	78 77	76	41	910	580	1744		
	Fort Story	36 56	76 00	13	19	22	N	11	3639	91 77	89 76	17	SW	87 75	79 78	77	12	708	856	2184		
	Langley AFB/Hampton	37 05	76 21	10	17	20	NW	9	3623	92 78	90 77	17	SW	87 76	79 78	77	21	809	1010	2290		
	Little Creek NAVPHIBASE	36 54	76 09	15	20	22	NW	10	3488	93 77	91 76	19	SW	89 76	79 78	77	41	874	961	2238		
	Lynchburg MAP	37 20	79 12	916	12	16	NE	7	4233	93 74	90 74	23	SW	88 73	77 76	75	31	696	376	1544		
	Manassas/Davis Field	38 43	77 31	186	10	14	NW	6	4398	96 76	93 75	22	S	90 74	78 77	76	90	897	548	1650		
	Newport News/Patrick Henry	37 08	76 30	41	17	20	NW	9	3549	92 78	90 77	17	SW	87 76	79 78	77	21	809	1010	2290		
	Norfolk	36 54	76 12	22	20	22	NW	10	3488	93 77	91 76	19	SW	89 76	79 78	77	41	874	961	2238		

STUDY PARAMETER INPUT PRINTOUT

Prepared By : E A C
Advanced Engineering Economic Analysis Program

05-01-91
60901891.00
Page 1 of 1

STUDY CRITERIA

ECIP - FEMP/10CFR436A (Army TM 5-802-1, Para. 2-3&4)

Discount Rate : 7.0 %
Investment Credit : 10.0 %
Payment Time : 1.0 (1 = end of year)

KEY STUDY DATES

ECIP Economic Life : 15 (years)

ENERGY RELATED STUDY PARAMETERS

State : VA
Prices of Electricity : 18.05
Distillate Oil : 7.43
Residual Oil : 6.62
Natural Gas : 5.33
Coal : 0.00

Prices are specified in \$ / Million BTU, FEMP Date (JUL 1988)

STUDY IDENTIFICATION BLOCK

Project Title : FORT BELVOIR E.S.O.S
Installation Name : WOODLAWN VILLAGE
Project Number : DACA-31-89-C-0198
Fiscal Year : 1991
Name of Analyst : E A C, P.C. Burke, Va.

PROJECTED NAVFAC COST INDEX
MONTHLY
JULY 1989

YEAR	JAN.	FEB.	MAR.	APR.	MAY.	JUNE	JULY	AUG.	SEPT.	OCT.	NOV.	DEC.
1974	1156	1154	1155	1177	1177	1199	1233	1240	1238	1246	1239	1240
1975	1242	1265	1265	1269	1287	1307	1317	1330	1333	1351	1349	1354
1976	1362	1370	1378	1391	1398	1416	1425	1455	1467	1476	1479	1484
1977	1489	1499	1504	1506	1507	1521	1539	1554	1587	1617	1603	1606
1978	1609	1617	1620	1621	1652	1663	1696	1705	1720	1721	1732	1734
1979	1740	1740	1750	1749	1753	1809	1829	1849	1900	1899	1902	1909
1980	1895	1894	1915	1899	1888	1916	1950	1971	1976	1981	2000	2017
1981	2015	2016	2014	2064	2076	2083	2109	2118	2139	2156	2186	2184
1982	2184	2200	2195	2195	2220	2219	2233	2253	2249	2248	2260	2295
1983	2311	2348	2352	2347	2351	2388	2414	2428	2430	2416	2419	2406
1984	2402	2407	2412	2422	2419	2417	2418	2428	2430	2424	2421	2408
1985	2410	2414	2406	2405	2411	2429	2448	2442	2440	2441	2446	2439
1986	2440	2446	2447	2458	2479	2493	2499	2498	2504	2511	2511	2511
1987	2515	2510	2518	2523	2524	2525	2538	2557	2565	2569	2564	2589
1988	2574	2576	2586	2591	2592	2595	2598	2611	2612	2612	2616	2617
1989	2619	2613	2616	2620	2621	2626	2633	2640	2648	2655	2663	2670
1990	2677	2683	2690	2697	2704	2710	2717	2724	2731	2738	2744	2751
1991	2757	2763	2769	2776	2782	2788	2794	2800	2806	2812	2819	2825
1992	2830	2835	2840	2845	2850	2855	2861	2866	2871	2876	2881	2886
1993	2891	2896	2900	2905	2910	2914	2919	2924	2928	2933	2938	2942

ANNUAL MARK-UP FACTORS FOR ESCALATION
(BEYOND FY 93, USE 1.80% ESCALATION COMPOUNDED EACH YEAR)

FISCAL-YEAR	4-87	4-88	4-89	4-90	4-91	4-92	4-93	4-94	4-95
4-83	1.07	1.10	1.12	1.15	1.18	1.21	1.24	1.26	1.28
4-84	1.04	1.07	1.08	1.11	1.15	1.17	1.20	1.22	1.24
4-85	1.05	1.08	1.09	1.12	1.15	1.18	1.21	1.23	1.25
4-86	1.03	1.05	1.07	1.10	1.13	1.16	1.18	1.20	1.22
4-87	1.00	1.03	1.04	1.07	1.10	1.13	1.15	1.17	1.19
4-88	0.97	1.00	1.01	1.04	1.07	1.10	1.12	1.14	1.16
4-89	0.96	0.99	1.00	1.03	1.06	1.09	1.11	1.13	1.15
4-90	0.94	0.96	0.97	1.00	1.03	1.05	1.08	1.10	1.12
4-91	0.91	0.93	0.94	0.97	1.00	1.02	1.05	1.07	1.08
4-92	0.89	0.91	0.92	0.95	0.98	1.00	1.02	1.04	1.06
4-93	0.87	0.89	0.90	0.93	0.96	0.98	1.00	1.02	1.04

NOTE: Escalation rate change to be 1.80% after 1993.

Figure 9
Projected NAVFAC Cost Index

ENGINEERING ANALYSIS

Sheet 1 of 1

By: JR

Calculations for Infiltration

WOODBRIDGE MILITARY TOWER
Building

Project: ESOS, Fort 12-1-100 Date: August, 1990

Contract No: DACA-31-89-C-0189 EAC Project No.: 89034.0

Calculations based on ASHRAE 1989 Page F 23.14.

Building Leakage Area

	Effective Leakage Area, in ²	Building Component Parameter	Building Leakage Area D _L , in ²
	L ₁	D ₁	L
Sill foundation	0.04 0.197/ft. of perimeter	334 ft.	14
Joints, ceiling/walls	0.07 0.12/ft. of wall	334 ft.	23
Windows	0.043 0.062/ft ² of window	380 ft ² .	16
Doors	0.114 0.215/ft ² of doors	80 ft ² .	9
Wall - Window frames	0.014 0.15/ft ² of window	380 ft ² .	2
- Door frames	0.004 0.072/ft ² of door	80 ft ² .	1
Elec. outlet/switch	0.076 0.16/fixture	100 ft.	8
Recessed lights	1.6/fixture	12	20
Pipe penetration	0.155 1.55/in ² of pipe	8	1
Exhaust Fans	6.0/fan	10 8	60 48
Duct penetration	2.2/SF	10SF	22
			<u>164</u>

$$\begin{aligned} \text{Infiltration } Q(\text{cfm}) &= L \times (A \Delta t + B v^2)^{1/2} \\ &= L(0.0313 \times 51 + 0.0086 \times 14^2)^{1/2} \\ &= L \times 1.81 = 164 \times 1.81 = 297 \text{ CFM} \end{aligned}$$

$$\begin{aligned} \text{Infiltration through walls} &= 0.1 \times 5600(\text{SF}) \\ &= 560 \text{ CFM} \end{aligned}$$

⁹²
(ASHRAE 1989, p. 23.13)

$$\text{Total Infiltration} = 297 + 560 = 857 \text{ CFM}$$

$$\text{Infiltration Rate} = \frac{857}{7200} = 0.119 = 0.12 \text{ CFM/SF}$$

(through typical units)

SIMPLE SPACE DESCRIPTION

Space Name : Woodlawn type 1 upstairs

04-26-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.069	0.049	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	N

People : sqft/person = 500.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = Woodlawn type 1 upstairs

		Floor Area :	1,452.0 sqft
Exposure :	E	W Roof Area :	1,452.0 sqft
Wall Area :	278.0	Current	
Glass Area :	0.0	44.0 Elements :	Wl,Gl,In

ADDITIONAL ELEMENT - Wall

Weight =	M (lb/sqft)	Exposure =	S
Color =	M	Net Area =	423.0 sqft
U-Value =	0.069 BTU/hr/sqft/F		

ADDITIONAL ELEMENT - Glass

U-Value =	0.550 BTU/hr/sqft/F	Exposure =	S
Glass Factor =	0.90	Area =	65.0 sqft
Internal Shades ?	N		

ADDITIONAL ELEMENT - Infiltration

Cooling :	0.12 CFM/sqft =	174 CFM
Heating :	0.12 CFM/sqft =	174 CFM
Typical :	0.12 CFM/sqft =	174 CFM

SIMPLE SPACE DESCRIPTION

Space Name : Woodlawn type 1 down.

04-26-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.069	0.049	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	N

People : sqft/person = 500.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = Woodlawn type 1 down.

		Floor Area :	1,452.0 sqft
Exposure :	E	W Roof Area :	0.0 sqft
Wall Area :	278.0	234.0	Current
Glass Area :	0.0	44.0	Elements : Wl,Gl,Gr,In

ADDITIONAL ELEMENT - Wall

Weight =	M (lb/sqft)	Exposure =	S
Color =	M	Net Area =	423.0 sqft
U-Value =	0.069 BTU/hr/sqft/F		

ADDITIONAL ELEMENT - Glass

U-Value =	0.550 BTU/hr/sqft/F	Exposure =	S
Glass Factor =	0.90	Area =	65.0 sqft
Internal Shades ?	N		

ADDITIONAL ELEMENT - Ground

Slab Floor Area =	1,452.0 sqft
Perimeter =	110.0 ft
Depth =	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling :	0.12 CFM/sqft =	174 CFM
Heating :	0.12 CFM/sqft =	174 CFM
Typical :	0.12 CFM/sqft =	174 CFM

SIMPLE SPACE DESCRIPTION

Space Name : Woodlawn type 2 exterior

04-26-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.069	0.049	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades ?	N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = Woodlawn type 2 exterior

		Floor Area :	1,852.0 sqft
Exposure :	E	W Roof Area :	981.0 sqft
Wall Area :	545.0	556.0	Current
Glass Area :	40.0	49.0	Elements : Wl,Gl,Gr,In

ADDITIONAL ELEMENT - Wall

Weight =	M (lb/sqft)	Exposure =	S
Color =	M	Net Area =	403.0 sqft
U-Value =	0.069 BTU/hr/sqft/F		

ADDITIONAL ELEMENT - Glass

U-Value =	0.550 BTU/hr/sqft/F	Exposure =	S
Glass Factor =	0.90	Area =	12.0 sqft
Internal Shades ?	N		

ADDITIONAL ELEMENT - Ground

Slab Floor Area =	871.0 sqft
Perimeter =	95.0 ft
Depth =	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling :	0.12 CFM/sqft =	222 CFM
Heating :	0.12 CFM/sqft =	222 CFM
Typical :	0.12 CFM/sqft =	222 CFM

SIMPLE SPACE DESCRIPTION

Space Name : Woodlawn type 2 interior

04-26-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.069	0.049	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	N

People : sqft/person = 500.0 Schedule = 1 Activity Level = 1
Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
: Fixture Type = 3 Free-hanging

SPACE NAME = Woodlawn type 2 interior

Exposure :	E	W	Floor Area :	1,852.0 sqft
Wall Area :	545.0	556.0	Roof Area :	981.0 sqft
Glass Area :	40.0	49.0	Current Elements :	Gr,In

ADDITIONAL ELEMENT - Ground

Slab Floor Area = 871.0 sqft
Perimeter = 72.0 ft
Depth = 0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling : 0.12 CFM/sqft = 222 CFM
Heating : 0.12 CFM/sqft = 222 CFM
Typical : 0.12 CFM/sqft = 222 CFM

SIMPLE SPACE DESCRIPTION

Space Name : Woodlawn type 3

04-26-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

	Walls	Roof	Glass		
U-Value :	0.069	0.049	0.550	Building Weight :	M
Weight :	M	M		Glass Factor :	0.90
Color :	M	M		Internal Shades :	N

People : sqft/person = 400.0 Schedule = 1 Activity Level = 1
 Lights : W/sqft = 0.00 Schedule = 2 Wattage Mult. = 1.00
 : Fixture Type = 3 Free-hanging

SPACE NAME = Woodlawn type 3

		Floor Area :	2,073.0 sqft
Exposure :	E	W Roof Area :	1,036.0 sqft
Wall Area :	555.0	470.0	Current
Glass Area :	30.0	135.0	Elements : Gl,Wl,Wl,Gr,In

ADDITIONAL ELEMENT - Glass

U-Value	=	0.550 BTU/hr/sqft/F	Exposure	=	S
Glass Factor	=	0.90	Area	=	10.0 sqft
Internal Shades	?	N			

ADDITIONAL ELEMENT - Wall

Weight	=	M (lb/sqft)	Exposure	=	S
Color	=	M	Net Area	=	485.0 sqft
U-Value	=	0.069 BTU/hr/sqft/F			

ADDITIONAL ELEMENT - Wall

Weight	=	M (lb/sqft)	Exposure	=	N
Color	=	M	Net Area	=	495.0 sqft
U-Value	=	0.069 BTU/hr/sqft/F			

ADDITIONAL ELEMENT - Ground

Slab Floor Area	=	1,036.0 sqft
Perimeter	=	130.0 ft
Depth	=	0.0 ft

ADDITIONAL ELEMENT - Infiltration

Cooling	:	0.12 CFM/sqft	=	249 CFM
Heating	:	0.12 CFM/sqft	=	249 CFM
Typical	:	0.12 CFM/sqft	=	249 CFM

DESIGN SPACE COOLING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1

CALCULATION DATA:

Zone Name : Building type 1

Calc Time: Aug 1600h

Job Name : Fort Belvoir

Amb db/wb: 91.4/ 74.9 F

Space Name	Mult	Space Sensible (tons /space)	Supply Air (CFM/space)
Woodlawn type 1 upstairs x 2		1.37	759.7
Woodlawn type 1 down. x 2		1.17	648.0

DESIGN SPACE HEATING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 1

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 17.0 F

Space Name	Mult	Space Sensible (BTU/hr/space)	Supply Air (CFM/space)
Woodlawn type 1 upstairs x	2	21,525.7	906.4
Woodlawn type 1 down. x	2	21,596.3	909.4

ZONE DESIGN COOLING LOAD SUMMARY

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

CALCULATION DATA:

Zone Name : Building type 1

Calc Time: Aug 1600h

Job Name : Fort Belvoir

Amb db/wb: 91.4/ 74.9 F

LOAD INFORMATION

LOAD COMPONENT	SENSIBLE (BTU/hr)	LATENT (BTU/hr)
SOLAR LOAD	26,204	0
GLASS TRANSMISSION	3,233	0
WALL TRANSMISSION	6,427	0
ROOF TRANSMISSION	4,387	0
PARTITION TRANSMISSION	0	0
LIGHTING (0 W TOTAL)	0	0
OTHER ELEC. (0 W TOTAL)	0	0
PEOPLE (11.62 PEOPLE TOTAL)	2,668	1,394
MISCELLANEOUS LOADS	0	0
COOLING INFILTRATION	12,339	14,938
PULLDOWN/WARM-UP	0	0
COOLING SAFETY LOAD	5,526	1,633
SUB-TOTALS	60,783	17,965
NET VENTILATION LOAD (0 CFM)	0	0
SUPPLY FAN LOAD (BHP= 0.2)	563	0
WALL LOAD TO PLENUM	0	0
ROOF LOAD TO PLENUM	0	0
LIGHTING LOAD TO PLENUM	0	0
TOTAL COOLING LOADS	61,346	17,965

COIL SELECTION PARAMETERS:

COIL ENTERING AIR TEMP. (DB/WB)	=	75.0/ 64.1 deg F
COIL LEAVING AIR TEMP. (DB/WB)	=	54.8/ 54.3 deg F
COIL SENSIBLE LOAD	=	61,346 BTU/hr
COIL TOTAL LOAD	=	79,311 BTU/hr
COOLING SUPPLY AIR TEMPERATURE	=	55.0 deg F
TOTAL COOLING CFM (actual)	=	2,815 CFM
TOTAL COOLING CFM (std. air)	=	2,814 CFM
RESULTING ROOM REL. HUMIDITY	=	54.7 %
COIL BYPASS FACTOR	=	0.050
COIL APPARATUS DEWPOINT	=	53.8 deg F
REHEAT REQUIRED	=	0 BTU/hr

GENERAL INFORMATION:

TOTAL COOLING LOAD	=	6.61 Tons
	=	878.77 sqft/Tons
TOTAL FLOOR AREA	=	5,808.00 sqft
OVERALL U-FACTOR	=	0.090 BTU/hr/sqft/F
COOLING CFM/sqft	=	0.48 CFM/sqft

ZONE DESIGN HEATING LOAD SUMMARY

Location : Washington, Dist. of Columbia 05-01-91
 Prepared By : E A C 6100190202
 Carrier Hourly Analysis Program Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 1 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 17.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	13,161
ROOF TRANSMISSION	7,257
GLASS TRANSMISSION	12,230
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	38,370
SLAB FLOOR	7,385
HEATING SAFETY BTU/hr	7,840
SUB-TOTAL	86,244
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	86,244
HEATING SUPPLY CFM	3,632 CFM
HEATING SUPPLY AIR TEMPERATURE	90.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

DESIGN SPACE COOLING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1

CALCULATION DATA:

Zone Name : Building type 2

Calc Time: Jul 1700h

Job Name : Fort Belvoir

Amb db/wb: 90.1/ 74.5 F

Space Name	Mult	Space Sensible (tons /space)	Supply Air (CFM/space)
Woodlawn type 2 exterior x 2		1.48	820.4

DESIGN SPACE HEATING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 2

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 17.0 F

Space Name	Mult	Space Sensible (BTU/hr/space)	Supply Air (CFM/space)
Woodlawn type 2 exterior x	2	28,506.8	1,200.4

ZONE DESIGN COOLING LOAD SUMMARY

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

CALCULATION DATA:

Zone Name : Building type 2

Calc Time: Jul 1700h

Job Name : Fort Belvoir

Amb db/wb: 90.1/ 74.5 F

LOAD INFORMATION

LOAD COMPONENT	SENSIBLE (BTU/hr)	LATENT (BTU/hr)
SOLAR LOAD	12,749	0
GLASS TRANSMISSION	1,419	0
WALL TRANSMISSION	5,236	0
ROOF TRANSMISSION	3,428	0
PARTITION TRANSMISSION	0	0
LIGHTING (0 W TOTAL)	0	0
OTHER ELEC. (0 W TOTAL)	0	0
PEOPLE (9.26 PEOPLE TOTAL)	2,127	1,111
MISCELLANEOUS LOADS	0	0
COOLING INFILTRATION	7,245	9,192
PULLDOWN/WARM-UP	0	0
COOLING SAFETY LOAD	3,220	1,030
SUB-TOTALS	35,424	11,334
NET VENTILATION LOAD (0 CFM)	0	0
SUPPLY FAN LOAD (BHP= 0.1)	328	0
WALL LOAD TO PLENUM	0	0
ROOF LOAD TO PLENUM	0	0
LIGHTING LOAD TO PLENUM	0	0
TOTAL COOLING LOADS	35,752	11,334

COIL SELECTION PARAMETERS:

COIL ENTERING AIR TEMP. (DB/WB)	=	75.0/ 64.2 deg F
COIL LEAVING AIR TEMP. (DB/WB)	=	54.8/ 54.3 deg F
COIL SENSIBLE LOAD	=	35,752 BTU/hr
COIL TOTAL LOAD	=	47,086 BTU/hr
COOLING SUPPLY AIR TEMPERATURE	=	55.0 deg F
TOTAL COOLING CFM (actual)	=	1,641 CFM
TOTAL COOLING CFM (std. air)	=	1,640 CFM
RESULTING ROOM REL. HUMIDITY	=	55.3 %
COIL BYPASS FACTOR	=	0.050
COIL APPARATUS DEWPOINT	=	53.8 deg F
REHEAT REQUIRED	=	0 BTU/hr

GENERAL INFORMATION:

TOTAL COOLING LOAD	=	3.92 Tons
	=	943.97 sqft/Tons
TOTAL FLOOR AREA	=	3,704.00 sqft
OVERALL U-FACTOR	=	0.080 BTU/hr/sqft/F
COOLING CFM/sqft	=	0.44 CFM/sqft

ZONE DESIGN HEATING LOAD SUMMARY

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 2

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 17.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	10,585
ROOF TRANSMISSION	4,903
GLASS TRANSMISSION	5,666
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	24,470
SLAB FLOOR	6,206
HEATING SAFETY BTU/hr	5,183
SUB-TOTAL	57,014
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	57,014
HEATING SUPPLY CFM	2,401 CFM
HEATING SUPPLY AIR TEMPERATURE	90.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

DESIGN SPACE COOLING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1

CALCULATION DATA:

Zone Name : Building type 3

Calc Time: Jul 1700h

Job Name : Fort Belvoir

Amb db/wb: 90.1/ 74.5 F

Space Name	Mult	Space Sensible (tons /space)	Supply Air (CFM/space)
Woodlawn type 2 exterior x 2		1.48	820.4
Woodlawn type 2 interior x 2		1.35	750.9

DESIGN SPACE HEATING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 3

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 17.0 F

Space Name	Mult	Space Sensible (BTU/hr/space)	Supply Air (CFM/space)
Woodlawn type 2 exterior x	2	28,506.8	1,200.4
Woodlawn type 2 interior x	2	25,802.4	1,086.5

ZONE DESIGN COOLING LOAD SUMMARY

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

CALCULATION DATA:

Zone Name : Building type 3

Calc Time: Jul 1700h

Job Name : Fort Belvoir

Amb db/wb: 90.1/ 74.5 F

LOAD INFORMATION

LOAD COMPONENT	SENSIBLE (BTU/hr)	LATENT (BTU/hr)
SOLAR LOAD	24,710	0
GLASS TRANSMISSION	2,669	0
WALL TRANSMISSION	9,126	0
ROOF TRANSMISSION	6,855	0
PARTITION TRANSMISSION	0	0
LIGHTING (0 W TOTAL)	0	0
OTHER ELEC. (0 W TOTAL)	0	0
PEOPLE (16.67 PEOPLE TOTAL)	3,829	2,000
MISCELLANEOUS LOADS	0	0
COOLING INFILTRATION	14,490	18,224
PULLDOWN/WARM-UP	0	0
COOLING SAFETY LOAD	6,168	2,022
SUB-TOTALS	67,847	22,247
NET VENTILATION LOAD (0 CFM)	0	0
SUPPLY FAN LOAD (BHP= 0.2)	629	0
WALL LOAD TO PLENUM	0	0
ROOF LOAD TO PLENUM	0	0
LIGHTING LOAD TO PLENUM	0	0
TOTAL COOLING LOADS	68,476	22,247

COIL SELECTION PARAMETERS:

COIL ENTERING AIR TEMP. (DB/WB)	=	75.0/ 64.3 deg F
COIL LEAVING AIR TEMP. (DB/WB)	=	54.8/ 54.3 deg F
COIL SENSIBLE LOAD	=	68,476 BTU/hr
COIL TOTAL LOAD	=	90,722 BTU/hr
COOLING SUPPLY AIR TEMPERATURE	=	55.0 deg F
TOTAL COOLING CFM (actual)	=	3,143 CFM
TOTAL COOLING CFM (std. air)	=	3,141 CFM
RESULTING ROOM REL. HUMIDITY	=	55.5 %
COIL BYPASS FACTOR	=	0.050
COIL APPARATUS DEWPOINT	=	53.8 deg F
REHEAT REQUIRED	=	0 BTU/hr

GENERAL INFORMATION:

TOTAL COOLING LOAD	=	7.56 Tons
	=	979.87 sqft/Tons
TOTAL FLOOR AREA	=	7,408.00 sqft
OVERALL U-FACTOR	=	0.080 BTU/hr/sqft/F
COOLING CFM/sqft	=	0.42 CFM/sqft

ZONE DESIGN HEATING LOAD SUMMARY

Location : Washington, Dist. of Columbia 05-01-91
 Prepared By : E A C 6100190202
 Carrier Hourly Analysis Program Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 3 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 17.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	18,334
ROOF TRANSMISSION	9,806
GLASS TRANSMISSION	10,659
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	48,941
SLAB FLOOR	11,004
HEATING SAFETY BTU/hr	9,874
SUB-TOTAL	108,618
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	108,618
HEATING SUPPLY CFM	4,574 CFM
HEATING SUPPLY AIR TEMPERATURE	90.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

DESIGN SPACE COOLING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1

CALCULATION DATA:

Zone Name : Building type 4

Calc Time: Jul 1700h

Job Name : Fort Belvoir

Amb db/wb: 90.1/ 74.5 F

Space Name	Mult	Space Sensible (tons /space)	Supply Air (CFM/space)
Woodlawn type 3	x 2	2.24	1,247.3

DESIGN SPACE HEATING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 4

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 17.0 F

Space Name	Mult	Space Sensible (BTU/hr/space)	Supply Air (CFM/space)
Woodlawn type 3	x 2	35,705.5	1,503.5

ZONE DESIGN COOLING LOAD SUMMARY

Location : Washington, Dist. of Columbia 05-01-91
 Prepared By : E A C 6100190202
 Carrier Hourly Analysis Program Page 1 of 2

CALCULATION DATA:

Zone Name : Building type 4 Calc Time: Jul 1700h
 Job Name : Fort Belvoir Amb db/wb: 90.1/ 74.5 F

LOAD INFORMATION

LOAD COMPONENT	SENSIBLE (BTU/hr)	LATENT (BTU/hr)
SOLAR LOAD	26,107	0
GLASS TRANSMISSION	2,458	0
WALL TRANSMISSION	6,287	0
ROOF TRANSMISSION	3,620	0
PARTITION TRANSMISSION	0	0
LIGHTING (0 W TOTAL)	0	0
OTHER ELEC. (0 W TOTAL)	0	0
PEOPLE (10.36 PEOPLE TOTAL)	2,381	1,244
MISCELLANEOUS LOADS	0	0
COOLING INFILTRATION	8,110	11,065
PULLDOWN/WARM-UP	0	0
COOLING SAFETY LOAD	4,896	1,231
SUB-TOTALS	53,859	13,539
NET VENTILATION LOAD (0 CFM)	0	0
SUPPLY FAN LOAD (BHP= 0.2)	499	0
WALL LOAD TO PLENUM	0	0
ROOF LOAD TO PLENUM	0	0
LIGHTING LOAD TO PLENUM	0	0
TOTAL COOLING LOADS	54,358	13,539

COIL SELECTION PARAMETERS:

COIL ENTERING AIR TEMP. (DB/WB) = 75.0/ 63.7 deg F
 COIL LEAVING AIR TEMP. (DB/WB) = 54.8/ 54.3 deg F
 COIL SENSIBLE LOAD = 54,358 BTU/hr
 COIL TOTAL LOAD = 67,898 BTU/hr
 COOLING SUPPLY AIR TEMPERATURE = 55.0 deg F
 TOTAL COOLING CFM (actual) = 2,495 CFM
 TOTAL COOLING CFM (std. air) = 2,493 CFM
 RESULTING ROOM REL. HUMIDITY = 53.5 %
 COIL BYPASS FACTOR = 0.050
 COIL APPARATUS DEWPOINT = 53.8 deg F
 REHEAT REQUIRED = 0 BTU/hr

GENERAL INFORMATION:

TOTAL COOLING LOAD = 5.66 Tons
 = 732.75 sqft/Tons
 TOTAL FLOOR AREA = 4,146.00 sqft
 OVERALL U-FACTOR = 0.089 BTU/hr/sqft/F
 COOLING CFM/sqft = 0.60 CFM/sqft

ZONE DESIGN HEATING LOAD SUMMARY

Location : Washington, Dist. of Columbia 05-01-91
 Prepared By : E A C 6100190202
 Carrier Hourly Analysis Program Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 4 Calc Time: Winter design
 Job Name : Fort Belvoir Amb db : 17.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	14,111
ROOF TRANSMISSION	5,178
GLASS TRANSMISSION	9,818
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	27,390
SLAB FLOOR	8,422
HEATING SAFETY BTU/hr	6,492
SUB-TOTAL	71,411
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	71,411
HEATING SUPPLY CFM	3,007 CFM
HEATING SUPPLY AIR TEMPERATURE	90.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

DESIGN SPACE COOLING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1

CALCULATION DATA:

Zone Name : Building type 5

Calc Time: Jul 1700h

Job Name : Fort Belvoir

Amb db/wb: 90.1/ 74.5 F

Space Name	Mult	Space Sensible (tons /space)	Supply Air (CFM/space)
Woodlawn type 2 exterior x 2		1.48	820.4
Woodlawn type 2 interior x 1		1.35	750.9

DESIGN SPACE HEATING LOADS

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 5

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 17.0 F

Space Name	Mult	Space Sensible (BTU/hr/space)	Supply Air (CFM/space)
Woodlawn type 2 exterior x	2	28,506.8	1,200.4
Woodlawn type 2 interior x	1	25,802.4	1,086.5

ZONE DESIGN COOLING LOAD SUMMARY

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 2

CALCULATION DATA:

Zone Name : Building type 5

Calc Time: Jul 1700h

Job Name : Fort Belvoir

Amb db/wb: 90.1/ 74.5 F

LOAD INFORMATION

LOAD COMPONENT	SENSIBLE (BTU/hr)	LATENT (BTU/hr)
SOLAR LOAD	18,729	0
GLASS TRANSMISSION	2,044	0
WALL TRANSMISSION	7,181	0
ROOF TRANSMISSION	5,141	0
PARTITION TRANSMISSION	0	0
LIGHTING (0 W TOTAL)	0	0
OTHER ELEC. (0 W TOTAL)	0	0
PEOPLE (12.96 PEOPLE TOTAL)	2,978	1,556
MISCELLANEOUS LOADS	0	0
COOLING INFILTRATION	10,868	13,709
PULLDOWN/WARM-UP	0	0
COOLING SAFETY LOAD	4,694	1,526
SUB-TOTALS	51,635	16,791
NET VENTILATION LOAD (0 CFM)	0	0
SUPPLY FAN LOAD (BHP= 0.2)	479	0
WALL LOAD TO PLENUM	0	0
ROOF LOAD TO PLENUM	0	0
LIGHTING LOAD TO PLENUM	0	0

TOTAL COOLING LOADS 52,114 16,791

COIL SELECTION PARAMETERS:

COIL ENTERING AIR TEMP. (DB/WB) = 75.0/ 64.3 deg F
 COIL LEAVING AIR TEMP. (DB/WB) = 54.8/ 54.3 deg F
 COIL SENSIBLE LOAD = 52,114 BTU/hr
 COIL TOTAL LOAD = 68,905 BTU/hr
 COOLING SUPPLY AIR TEMPERATURE = 55.0 deg F
 TOTAL COOLING CFM (actual) = 2,392 CFM
 TOTAL COOLING CFM (std. air) = 2,391 CFM
 RESULTING ROOM REL. HUMIDITY = 55.4 %
 COIL BYPASS FACTOR = 0.050
 COIL APPARATUS DEWPOINT = 53.8 deg F
 REHEAT REQUIRED = 0 BTU/hr

GENERAL INFORMATION:

TOTAL COOLING LOAD = 5.74 Tons
 = 967.59 sqft/Tons
 TOTAL FLOOR AREA = 5,556.00 sqft
 OVERALL U-FACTOR = 0.080 BTU/hr/sqft/F
 COOLING CFM/sqft = 0.43 CFM/sqft

ZONE DESIGN HEATING LOAD SUMMARY

Location : Washington, Dist. of Columbia

05-01-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

CALCULATION DATA:

Zone Name : Building type 5

Calc Time: Winter design

Job Name : Fort Belvoir

Amb db : 17.0 F

LOAD COMPONENT	LOAD (BTU/hr)
WALL TRANSMISSION	14,460
ROOF TRANSMISSION	7,355
GLASS TRANSMISSION	8,163
TRANSMISSION LOSS TO UNCOND. SPACES	0
INFILTRATION LOSS	36,705
SLAB FLOOR	8,605
HEATING SAFETY BTU/hr	7,529
SUB-TOTAL	82,816
NET VENTILATION LOSS	0
TOTAL HEATING LOAD	82,816
HEATING SUPPLY CFM	3,487 CFM
HEATING SUPPLY AIR TEMPERATURE	90.0 deg F
HEATING VENTILATION AIR CFM	0 CFM
HEATING THERMOSTAT SETPOINT TEMP	68.0 deg F

AIR SYSTEM DESCRIPTION

Name : Typical building 1
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = Typical building 1
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	68.0 F	CLOSED
Unoccupied	75.0 F	68.0 F	CLOSED
Weekday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Sunday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Design Day	: Occupied Period Begins at 0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
Heating supply temperature = 95.0 F
Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 % of vent. air
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : Typical building 1
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.60 in wg
Efficiency = 60 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050

Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : Typical building 2
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = Typical building 2
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	68.0 F	CLOSED
Unoccupied	75.0 F	68.0 F	CLOSED
Weekday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Sunday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Design Day	: Occupied Period Begins at 0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
Heating supply temperature = 95.0 F
Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 % of vent. air
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : Typical building 2
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.60 in wg
Efficiency = 60 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : Typical building 3
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = Typical building 3
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	68.0 F	CLOSED
Unoccupied	75.0 F	68.0 F	CLOSED
Weekday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Sunday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Design Day	: Occupied Period Begins at 0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
Heating supply temperature = 95.0 F
Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 % of vent. air
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : Typical building 3
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.60 in wg
Efficiency = 60 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : Typical building 4
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = Typical building 4
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	68.0 F	CLOSED
Unoccupied	75.0 F	68.0 F	CLOSED

Weekday : Occupied Period Begins at 0 ; Duration = 24 hrs
Saturday : Occupied Period Begins at 0 ; Duration = 24 hrs
Sunday : Occupied Period Begins at 0 ; Duration = 24 hrs
Design Day : Occupied Period Begins at 0 ; Duration = 24 hrs

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
Heating supply temperature = 95.0 F
Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 % of vent. air
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : Typical building 4
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.60 in wg
Efficiency = 60 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 1 Not Used

AIR SYSTEM DESCRIPTION

Name : Typical building 5
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 1 of 2

1. SYSTEM NAME AND TYPE

System Name = Typical building 5
System Class = Constant Volume
System Type = (SZCV) Single Zone Constant Volume
Operation Type = 2 Heating Only
Type of Heating = 1 Central Heating

2. SPACE SELECTION (see separate printout)

3. THERMOSTAT & EQUIPMENT SCHEDULING DATA

Operation Period	Thermostat Setpoints		Ventilation Dampers
	Cooling	Heating	
Occupied	75.0 F	68.0 F	CLOSED
Unoccupied	75.0 F	68.0 F	CLOSED
Weekday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Saturday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Sunday	: Occupied Period Begins at 0 ; Duration = 24 hrs		
Design Day	: Occupied Period Begins at 0 ; Duration = 24 hrs		

4. SUPPLY, VENTILATION, RETURN AIR DATA

SUPPLY AIR

Supply air temperature = 55.0 F
Heating supply temperature = 95.0 F
Fan operation for heating = 2 Cycled

VENTILATION AIR

Nominal ventilation flow rate = 0.00 % of supply air
Minimum ventilation flow rate = 0.00 % of supply air
Damper leak rate = 0 % of vent air

RETURN AIR

Zone exhaust air flow rate = 0.00 % of vent. air
Zone exhaust fan power = 0.0 kW
Is a return plenum used ? N

AIR SYSTEM DESCRIPTION

Name : Typical building 5
Carrier Hourly Analysis Program
Prepared By : E A C

05-01-91
6100190202
Page 2 of 2

5. FAN DATA

SUPPLY FAN

Type = 2:Forward curved
Static = 0.60 in wg
Efficiency = 60 %
Configuration = 1 Draw-thru

RETURN FAN

Type = 1:(Fan does not exist)

6. ACCESSORY DEVICES AND SYSTEMS

PREHEAT COIL

(Not used)

OUTDOOR AIR ECONOMIZER CONTROL

(Not used)

VENTILATION AIR RECLAIM

(Not used)

HUMIDITY CONTROL

(Not used)

7. MISCELLANEOUS SYSTEM DATA

Cooling coil bypass factor = 0.050
Type of supplemental heating = 1 Not Used

PLANT DESCRIPTIONS

Plant : Typical building 1,elect

05-02-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Heat Pumps
Name = Typical building 1,elect
Heat Pump Type = Air Source Heat Pump
Auxiliary Plant Type = Electrical Resistance

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Typical building 1	1		

3 PLANT CHARACTERISTICS (Air Source Heat Pump)

COOLING DATA

Estimated maximum cooling coil load = 6.04 Ton
Capacity at 95.0 F outdoor air = 8.00 Ton
Input power rate at 95.0 F outdoor air = 1.200 kW/Ton

HEATING DATA

Estimated maximum heating coil load = 76.56 MBH
Capacity at 47.0 F outdoor air = 96.0 MBH
Compressor, evaporator fan kW at 47.0 F outdoor air = 10.0 kW
Outdoor air temperature for cutoff = 15.0 F

AUXILIARY PLANT DATA

Plant type = Electrical
Estimated maximum heating coil load = 76.56 MBH
Type of heating = Direct

4 PUMP SYSTEM DATA

(No inputs required)

PLANT DESCRIPTIONS

Plant : Typical building 2,elect

05-02-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Heat Pumps
Name = Typical building 2,elect
Heat Pump Type = Air Source Heat Pump
Auxiliary Plant Type = Electrical Resistance

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Typical building 2	1		

3 PLANT CHARACTERISTICS (Air Source Heat Pump)

COOLING DATA

Estimated maximum cooling coil load = 3.60 Ton
Capacity at 95.0 F outdoor air = 4.00 Ton
Input power rate at 95.0 F outdoor air = 1.200 kW/Ton

HEATING DATA

Estimated maximum heating coil load = 48.25 MBH
Capacity at 47.0 F outdoor air = 24.0 MBH
Compressor, evaporator fan kW at 47.0 F outdoor air = 5.0 kW
Outdoor air temperature for cutoff = 15.0 F

AUXILIARY PLANT DATA

Plant type = Electrical
Estimated maximum heating coil load = 48.25 MBH
Type of heating = Direct

4 PUMP SYSTEM DATA

(No inputs required)

PLANT DESCRIPTIONS

Plant : Typical building 3,elect

05-02-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Heat Pumps
Name = Typical building 3,elect
Heat Pump Type = Air Source Heat Pump
Auxiliary Plant Type = Electrical Resistance

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Typical building 3	1		

3 PLANT CHARACTERISTICS (Air Source Heat Pump)

COOLING DATA

Estimated maximum cooling coil load = 6.94 Ton
Capacity at 95.0 F outdoor air = 8.00 Ton
Input power rate at 95.0 F outdoor air = 1.200 kW/Ton

HEATING DATA

Estimated maximum heating coil load = 92.06 MBH
Capacity at 47.0 F outdoor air = 96.0 MBH
Compressor, evaporator fan kW at 47.0 F outdoor air = 10.0 kW
Outdoor air temperature for cutoff = 15.0 F

AUXILIARY PLANT DATA

Plant type = Electrical
Estimated maximum heating coil load = 92.06 MBH
Type of heating = Direct

4 PUMP SYSTEM DATA

(No inputs required)

PLANT DESCRIPTIONS

Plant : Typical building 4,elect

05-02-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Heat Pumps
Name = Typical building 4,elect
Heat Pump Type = Air Source Heat Pump
Auxiliary Plant Type = Electrical Resistance

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Typical building 4	1		

3 PLANT CHARACTERISTICS (Air Source Heat Pump)

COOLING DATA

Estimated maximum cooling coil load = 5.19 Ton
Capacity at 95.0 F outdoor air = 5.00 Ton
Input power rate at 95.0 F outdoor air = 1.200 kW/Ton

HEATING DATA

Estimated maximum heating coil load = 64.03 MBH
Capacity at 47.0 F outdoor air = 62.0 MBH
Compressor, evaporator fan kW at 47.0 F outdoor air = 5.0 kW
Outdoor air temperature for cutoff = 15.0 F

AUXILIARY PLANT DATA

Plant type = Electrical
Estimated maximum heating coil load = 64.03 MBH
Type of heating = Direct

4 PUMP SYSTEM DATA

(No inputs required)

PLANT DESCRIPTIONS

Plant : Typical building 5,elect

05-02-91

Prepared By : E A C

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

1 PLANT NAME AND TYPES

Class = Heat Pumps
Name = Typical building 5,elect
Heat Pump Type = Air Source Heat Pump
Auxiliary Plant Type = Electrical Resistance

2 AIR SYSTEM SELECTION

Air System Name	Mult	Air System Name	Mult
Typical building 5	1		

3 PLANT CHARACTERISTICS (Air Source Heat Pump)

COOLING DATA

Estimated maximum cooling coil load = 5.27 Ton
Capacity at 95.0 F outdoor air = 6.00 Ton
Input power rate at 95.0 F outdoor air = 1.200 kW/Ton

HEATING DATA

Estimated maximum heating coil load = 70.15 MBH
Capacity at 47.0 F outdoor air = 72.0 MBH
Compressor, evaporator fan kW at 47.0 F outdoor air = 7.5 kW
Outdoor air temperature for cutoff = 15.0 F

AUXILIARY PLANT DATA

Plant type = Electrical
Estimated maximum heating coil load = 70.15 MBH
Type of heating = Direct

4 PUMP SYSTEM DATA

(No inputs required)

ANNUAL ENERGY COSTS

Building : Typical building 1,elect
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-02-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

 TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	18951 kWh	65	0.011	47.4 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		65	0.011	47.4 %
Non-HVAC Component				
Electric	21068 kWh	72	0.012	52.6 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		72	0.012	52.6 %
>>> GRAND TOTAL		137	0.024	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 5,808 sqft
 Conditioned floor area = 5,808 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 1,elect

05-02-91

Site : Washington, Dist. of Columbia

6100190202

Prepared By : E A C

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	5	0.001	3.8 %
Cooling Plants	24	0.004	17.6 %
Heating Plants	35	0.006	26.0 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	65	0.011	47.4 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	72	0.012	52.6 %
>>> Non-HVAC Sub-total	72	0.012	52.6 %
>>> GRAND TOTAL	137	0.024	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
building floor area. For this building:

Gross floor area = 5,808 sqft

Conditioned floor area = 5,808 sqft

ANNUAL ENERGY COSTS

Building : Typical building 2,elect
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-02-91
 6100190202

Page 1 of 1

Carrier Hourly Analysis Program

 TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	20184 kWh	69	0.019	65.7 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		69	0.019	65.7 %
Non-HVAC Component				
Electric	10534 kWh	36	0.010	34.3 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		36	0.010	34.3 %
=====				
>>> GRAND TOTAL		105	0.028	100.0 %
=====				

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 3,704 sqft
 Conditioned floor area = 3,704 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 2,elect
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-02-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	3	0.001	2.9 %
Cooling Plants	14	0.004	13.3 %
Heating Plants	52	0.014	49.5 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	69	0.019	65.7 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	36	0.010	34.3 %
>>> Non-HVAC Sub-total	36	0.010	34.3 %
>>> GRAND TOTAL	105	0.028	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 3,704 sqft
 Conditioned floor area = 3,704 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 3,elect
 Site : Washington, Dist. of Columbia
 Prepared By : E A C
 Carrier Hourly Analysis Program

05-02-91
 6100190202

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	6	0.001	3.7 %
Cooling Plants	26	0.004	16.9 %
Heating Plants	52	0.007	33.1 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	84	0.011	53.7 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	72	0.010	46.3 %
>>> Non-HVAC Sub-total	72	0.010	46.3 %
>>> GRAND TOTAL	155	0.021	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 7,408 sqft

Conditioned floor area = 7,408 sqft

ANNUAL ENERGY COSTS

Building : Typical building 3,elect
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-02-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	24482 kWh	84	0.011	53.7 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		84	0.011	53.7 %
Non-HVAC Component				
Electric	21068 kWh	72	0.010	46.3 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		72	0.010	46.3 %

>>> GRAND TOTAL		155	0.021	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 7,408 sqft
 Conditioned floor area = 7,408 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 4,elect
 Site : Washington, Dist. of Columbia
 Prepared By : E A C
 Carrier Hourly Analysis Program

05-02-91
 6100190202

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	4	0.001	5.3 %
Cooling Plants	21	0.005	24.3 %
Heating Plants	23	0.006	27.8 %
Pumps	0	0.000	0.0 %

>>> HVAC Subtotal	48	0.012	57.4 %

Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	36	0.009	42.6 %

>>> Non-HVAC Sub-total	36	0.009	42.6 %
=====			
>>> GRAND TOTAL	84	0.020	100.0 %
=====			

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 4,146 sqft

Conditioned floor area = 4,146 sqft

ANNUAL ENERGY COSTS

Building : Typical building 4,elect
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-02-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

 TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	14202 kWh	48	0.012	57.4 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		48	0.012	57.4 %
Non-HVAC Component				
Electric	10534 kWh	36	0.009	42.6 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		36	0.009	42.6 %
>>> GRAND TOTAL		84	0.020	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 4,146 sqft
 Conditioned floor area = 4,146 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 5,elect
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-02-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	4	0.001	3.8 %
Cooling Plants	20	0.004	17.2 %
Heating Plants	39	0.007	33.0 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	63	0.011	53.9 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	54	0.010	46.1 %
>>> Non-HVAC Sub-total	54	0.010	46.1 %
>>> GRAND TOTAL	117	0.021	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 5,556 sqft
 Conditioned floor area = 5,556 sqft

ANNUAL ENERGY COSTS

Building : Typical building 5,elect
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-02-91

6100190202

Page 1 of 1

Carrier Hourly Analysis Program

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	18506 kWh	63	0.011	53.9 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		63	0.011	53.9 %
Non-HVAC Component				
Electric	15801 kWh	54	0.010	46.1 %
Natural Gas	0 Therms	0	0.000	0.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		54	0.010	46.1 %

>>> GRAND TOTAL		117	0.021	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:
 Gross floor area = 5,556 sqft
 Conditioned floor area = 5,556 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 1, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	5	0.001	2.4 %
Cooling Plants	16	0.003	7.4 %
Heating Plants	100	0.017	47.5 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	121	0.021	57.4 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	90	0.015	42.6 %
>>> Non-HVAC Sub-total	90	0.015	42.6 %
>>> GRAND TOTAL	211	0.036	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 5,808 sqft
 Conditioned floor area = 5,808 sqft

ANNUAL ENERGY COSTS

Building : Typical building 1, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * -->		% of Total
		(MBTU)	(MBTU/sqft)	
Electric	6066 kWh	21	0.004	9.8 %
Natural Gas	1002 Therms	100	0.017	47.5 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		121	0.021	57.4 %

Non-HVAC Component

Electric	0 kWh	0	0.000	0.0 %
Natural Gas	899 Therms	90	0.015	42.6 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		90	0.015	42.6 %

=====
 >>> GRAND TOTAL 211 0.036 100.0 %
 =====

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 5,808 sqft
 Conditioned floor area = 5,808 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 2, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	3	0.001	2.3 %
Cooling Plants	9	0.003	7.1 %
Heating Plants	74	0.020	56.3 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	86	0.023	65.7 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	45	0.012	34.3 %
>>> Non-HVAC Sub-total	45	0.012	34.3 %
>>> GRAND TOTAL	131	0.035	100.0 %

* Note: 1. Cost per unit floor area is based on the gross building floor area. For this building:

Gross floor area = 3,704 sqft

Conditioned floor area = 3,704 sqft

ANNUAL ENERGY COSTS

Building : Typical building 2, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	3626 kWh	12	0.003	9.4 %
Natural Gas	738 Therms	74	0.020	56.3 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		86	0.023	65.7 %

Non-HVAC Component

Electric	0 kWh	0	0.000	0.0 %
Natural Gas	449 Therms	45	0.012	34.3 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		45	0.012	34.3 %

=====
 >>> GRAND TOTAL 131 0.035 100.0 %
 =====

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 3,704 sqft
 Conditioned floor area = 3,704 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 3, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91

6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	6	0.001	2.2 %
Cooling Plants	17	0.002	6.7 %
Heating Plants	148	0.020	56.7 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	171	0.023	65.6 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	90	0.012	34.4 %
>>> Non-HVAC Sub-total	90	0.012	34.4 %
>>> GRAND TOTAL	261	0.035	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 7,408 sqft

Conditioned floor area = 7,408 sqft

ANNUAL ENERGY COSTS

Building : Typical building 3, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	6795 kWh	23	0.003	8.9 %
Natural Gas	1479 Therms	148	0.020	56.7 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		171	0.023	65.6 %

Non-HVAC Component				
Electric	0 kWh	0	0.000	0.0 %
Natural Gas	899 Therms	90	0.012	34.4 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		90	0.012	34.4 %

=====				
>>> GRAND TOTAL		261	0.035	100.0 %
=====				

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 7,408 sqft

Conditioned floor area = 7,408 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 4, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	4	0.001	3.0 %
Cooling Plants	14	0.003	9.3 %
Heating Plants	86	0.021	57.7 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	105	0.025	70.0 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	45	0.011	30.0 %
>>> Non-HVAC Sub-total	45	0.011	30.0 %
>>> GRAND TOTAL	150	0.036	100.0 %

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 4,146 sqft
 Conditioned floor area = 4,146 sqft

ANNUAL ENERGY COSTS

Building : Typical building 4, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * -->		% of Total
		(MBTU)	(MBTU/sqft)	
Electric	5388 kWh	18	0.004	12.3 %
Natural Gas	863 Therms	86	0.021	57.7 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %

>>> HVAC Subtotal		105	0.025	70.0 %

Non-HVAC Component

Electric	0 kWh	0	0.000	0.0 %
Natural Gas	449 Therms	45	0.011	30.0 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %

>>> Non-HVAC Subtotal		45	0.011	30.0 %

=====
 >>> GRAND TOTAL 150 0.036 100.0 %
 =====

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 4,146 sqft

Conditioned floor area = 4,146 sqft

ANNUAL COMPONENT COSTS

Building : Typical building 5, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91
 6100190202

Carrier Hourly Analysis Program

Page 1 of 1

TABLE 1. COSTS BY COMPONENT

Component	<---- Annual Costs * ---->		% of Total
	(MBTU)	(MBTU/sqft)	
Air System Fans	4	0.001	2.2 %
Cooling Plants	13	0.002	6.8 %
Heating Plants	111	0.020	56.6 %
Pumps	0	0.000	0.0 %
>>> HVAC Subtotal	129	0.023	65.6 %
Lights	0	0.000	0.0 %
Other Electric	0	0.000	0.0 %
Miscellaneous Electric	0	0.000	0.0 %
Domestic Hot Water	67	0.012	34.4 %
>>> Non-HVAC Sub-total	67	0.012	34.4 %
>>> GRAND TOTAL	196	0.035	100.0 %

* Note: 1. Cost per unit floor area is based on the gross building floor area. For this building:

Gross floor area = 5,556 sqft

Conditioned floor area = 5,556 sqft

ANNUAL ENERGY COSTS

Building : Typical building 5, gas
 Site : Washington, Dist. of Columbia
 Prepared By : E A C

05-03-91
 6100190202

Page 1 of 1

Carrier Hourly Analysis Program

 TABLE 1. COSTS BY ENERGY CATEGORY

HVAC Component	Annual Energy	<---- Annual Costs * --> (MBTU) (MBTU/sqft)		% of Total
Electric	5204 kWh	18	0.003	9.1 %
Natural Gas	1109 Therms	111	0.020	56.6 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
Remote Cooling	0 Therms	0	0.000	0.0 %
>>> HVAC Subtotal		129	0.023	65.6 %

Non-HVAC Component				
Electric	0 kWh	0	0.000	0.0 %
Natural Gas	674 Therms	67	0.012	34.4 %
Fuel Oil	0 gallon	0	0.000	0.0 %
Propane	0 Therms	0	0.000	0.0 %
Remote Heating	0 Therms	0	0.000	0.0 %
>>> Non-HVAC Subtotal		67	0.012	34.4 %

>>> GRAND TOTAL		196	0.035	100.0 %
=====				

* Note: 1. Cost per unit floor area is based on the gross
 building floor area. For this building:

Gross floor area = 5,556 sqft
 Conditioned floor area = 5,556 sqft

2600 AREA (WOODLAWN VILLAGE)

Fuel Conversion:

Description - Existing heat pumps and electric water heaters are proposed to be replaced by gas-fired boilers and water heaters respectively.

Energy Saved	= -9,391	MBTU/year
Cost	= \$1,864,793	(incl. SIOH)
SIR	= 0.72	

PORT BELVOIR WOODLAWN HOUSING AREA

CONSTRUCTION COSTS AND ENERGY SAVINGS CONSOLIDATION

TYPE	No.	ENERGY SAVINGS, MBTU/BLDG			TOTAL ENERGY SAVINGS, MBTU		
		ELEC.	OIL	GAS	ELEC.	OIL	GAS
1	50	137	0	-211	6850	0	-10550
2	34	105	0	-131	3570	0	-4454
3	16	155	0	-261	2480	0	-4176
4	22	84	0	-150	1848	0	-3300
5	21	117	0	-196	2457	0	-4116
TOTAL	143				17205	0	-26596

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

WOODLAWN VILLAGE - TYPE 1 (50 buildings)

Proposed conversion

Estimated cost of gas-fired furnace		= \$ 11,058
Estimated cost of gas-fired water heater		= \$ 2,335
Cost of conversion now		= \$ 13,393
Total Cost of Conversion	\$13,393 X 50	= \$669,650

Water heater replacement costs

Gas-fired water heaters	= \$2,335 X 50	= \$116,750
Electric water heaters	= \$2,078 X 50	= \$103,900

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 1
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace heat pumps with new gas furnaces

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Remove heat pump	4	each	\$200	\$800	---	---	\$800
Install gas furnace							
Gas furnaces w/ controls	4	each	\$88	\$352	\$390	\$1,560	\$1,912
Pres. reg., valves, etc.	4	each	\$85	\$340	\$160	\$640	\$980
Gas piping	120	l.f.	\$3.21	\$385	\$0.87	\$104	\$490
Holes thru walls	8	each	\$54	\$432	---	---	\$432
Install gas vent chimney							
Gas double wall, galv., 6"	96	v.l.f.	\$3.96	\$380	\$5.85	\$562	\$942
Elbow 90, 6"	4	each	\$16.45	\$66	\$11.70	\$47	\$113
Roof flashing	4	each	\$8.55	\$34	\$11.70	\$47	\$81
Tee, 6"	4	each	\$17.40	\$70	\$14.60	\$58	\$128
Tee cap, 6"	4	each	\$1.75	\$7	\$9.50	\$38	\$45
Top cap, 6"	4	each	\$9.85	\$39	\$8.75	\$35	\$74
Architectual modification							
Core drill floor/ceil./roof	4	each	\$51.30	\$205	---	---	\$205
2x4 wood framing @ 16"	384	s.f.	\$1.08	\$415	\$0.42	\$161	\$576
5/3" type x gypsum wallbd.	384	s.f.	\$1.08	\$415	\$0.28	\$108	\$522
Painting	800	s.f.	\$0.60	\$480	\$0.16	\$128	\$608
Patch roofing	4	each	\$24.70	\$99	\$6.35	\$25	\$124
SUB-TOTAL:				\$4,519		\$3,513	\$8,032
Labor Markup: 21%				\$949		---	\$949
Taxes: 4.5%				---		\$158	\$158
SUB-TOTAL:				\$5,468		\$3,671	\$9,139
Overhead: 10%				\$547		\$367	\$914
SUB-TOTAL:				\$6,015		\$4,038	\$10,053
Profit: 10%				\$601		\$404	\$1,005
TOTAL:				\$6,616		\$4,442	\$11,058

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 1
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing water heaters with gas water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	4	each	\$110	\$440	\$230	\$920	\$1,360
Remove water heater	4	each	\$90	\$360	---	---	\$360
as double wall, galv., 4"	40	v.l.f.	\$5.15	\$206	\$2.86	\$114	\$320
Elbow 90, 4"	4	each	\$16.45	\$66	\$11.70	\$47	\$113
Tee, 6"	4	each	\$17.40	\$70	\$14.60	\$58	\$128
Tee cap, 6"	4	each	\$1.75	\$7	\$9.50	\$38	\$45
SUB-TOTAL:				\$800		\$920	\$1,720
Labor Markup: 21%				\$168		---	\$168
Taxes: 4.5%				---		\$41	\$41
SUB-TOTAL:				\$968		\$961	\$1,929
Overhead: 10%				\$97		\$96	\$193
SUB-TOTAL:				\$1,065		\$1,058	\$2,122
Profit: 10%				\$106		\$106	\$212
TOTAL:				\$1,171		\$1,163	\$2,335

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 1
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing electric water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	4	each	\$99	\$396	\$192	\$768	\$1,164
Remove water heater	4	each	\$90	\$360	---	---	\$360
SUB-TOTAL:				\$756		\$768	\$1,524
labor Markup: 21%				\$159		---	\$159
Taxes: 4.5%				---		\$35	\$35
SUB-TOTAL:				\$915		\$803	\$1,717
Overhead: 10%				\$91		\$80	\$172
SUB-TOTAL:				\$1,006		\$883	\$1,889
Profit: 10%				\$101		\$88	\$189
TOTAL:				\$1,107		\$971	\$2,078

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

WOODLAWN VILLAGE - TYPE 2 (34 buildings)

Proposed conversion

Estimated cost of gas-fired furnace	= \$	5,529
Estimated cost of gas-fired water heater	= \$	1,686
Cost of conversion now	= \$	7,215
Total Cost of Conversion	\$7,215 X 34	= \$245,310

Water heater replacement costs

Gas-fired water heaters	= \$1,686 X 34	= \$ 57,324
Electric water heaters	= \$1,393 X 34	= \$ 47,362

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 2
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace heat pumps with new gas furnaces

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Remove heat pump	2	each	\$200	\$400	---	---	\$400
Install gas furnace							
Gas furnaces w/ controls	2	each	\$88	\$176	\$390	\$780	\$956
Pres. reg., valves, etc.	2	each	\$85	\$170	\$160	\$320	\$490
Gas piping	60	l.f.	\$3.21	\$193	\$0.87	\$52	\$245
Holes thru walls	4	each	\$54	\$216	---	---	\$216
Install gas vent chimney							
Gas double wall, galv., 6"	48	v.l.f.	\$3.96	\$190	\$5.85	\$281	\$471
Elbow 90, 6"	2	each	\$16.45	\$33	\$11.70	\$23	\$56
Roof flashing	2	each	\$8.55	\$17	\$11.70	\$23	\$41
Tee, 6"	2	each	\$17.40	\$35	\$14.60	\$29	\$64
Tee cap, 6"	2	each	\$1.75	\$4	\$9.50	\$19	\$23
Top cap, 6"	2	each	\$9.85	\$20	\$8.75	\$18	\$37
Architectual modification							
Core drill floor/ceil./roof	2	each	\$51.30	\$103	---	---	\$103
2x4 wood framing @ 16"	192	s.f.	\$1.08	\$207	\$0.42	\$81	\$288
5/3" type x gypsum wallbd.	192	s.f.	\$1.08	\$207	\$0.28	\$54	\$261
Painting	400	s.f.	\$0.60	\$240	\$0.16	\$64	\$304
Patch roofing	2	each	\$24.70	\$49	\$6.35	\$13	\$62
SUB-TOTAL:				\$2,259		\$1,757	\$4,016
Labor Markup: 21%				\$474		---	\$474
Taxes: 4.5%				---		\$79	\$79
SUB-TOTAL:				\$2,734		\$1,836	\$4,570
Overhead: 10%				\$273		\$184	\$457
SUB-TOTAL:				\$3,007		\$2,019	\$5,026
Profit: 10%				\$301		\$202	\$503
TOTAL:				\$3,308		\$2,221	\$5,529

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 2
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing water heaters with gas water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	2	each	\$130	\$260	\$412	\$824	\$1,084
Remove water heater	2	each	\$90	\$180	---	---	\$180
as double wall, galv., 4"	20	v.l.f.	\$5.15	\$103	\$2.86	\$57	\$160
Elbow 90, 4"	2	each	\$16.45	\$33	\$11.70	\$23	\$56
Tee, 6"	2	each	\$17.40	\$35	\$14.60	\$29	\$64
Tee cap, 6"	2	each	\$1.75	\$4	\$9.50	\$19	\$23
SUB-TOTAL:				\$440		\$824	\$1,264
Labor Markup: 21%				\$92		---	\$92
Taxes: 4.5%				---		\$37	\$37
SUB-TOTAL:				\$532		\$861	\$1,393
Overhead: 10%				\$53		\$86	\$139
SUB-TOTAL:				\$586		\$947	\$1,533
Profit: 10%				\$59		\$95	\$153
TOTAL:				\$644		\$1,042	\$1,686

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 2
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing electric water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	2	each	\$125	\$250	\$302	\$604	\$854
Remove water heater	2	each	\$90	\$180	---	---	\$180
SUB-TOTAL:				\$430		\$604	\$1,034
Labor Markup: 21%				\$90		---	\$90
Taxes: 4.5%				---		\$27	\$27
SUB-TOTAL:				\$520		\$631	\$1,151
Overhead: 10%				\$52		\$63	\$115
SUB-TOTAL:				\$572		\$694	\$1,267
Profit: 10%				\$57		\$69	\$127
TOTAL:				\$630		\$764	\$1,393

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

WOODLAWN VILLAGE - TYPE 3 (16 buildings)

Proposed conversion

Estimated cost of gas-fired furnace		= \$ 11,058
Estimated cost of gas-fired water heater		= \$ 3,372
Cost of conversion now		= \$ 14,430
Total Cost of Conversion	\$14,430 X 16	= \$230,880

Water heater replacement costs

Gas-fired water heaters	= \$3,372 X 16	= \$ 53,952
Electric water heaters	= \$2,787 X 16	= \$ 44,592

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 3
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace heat pumps with new gas furnaces

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Remove heat pump	4	each	\$200	\$800	---	---	\$800
Install gas furnace							
Gas furnaces w/ controls	4	each	\$88	\$352	\$390	\$1,560	\$1,912
Pres. reg., valves, etc.	4	each	\$85	\$340	\$160	\$640	\$980
Gas piping	120	l.f.	\$3.21	\$385	\$0.87	\$104	\$490
Holes thru walls	8	each	\$54	\$432	---	---	\$432
Install gas vent chimney							
Gas double wall, galv., 6"	96	v.l.f.	\$3.96	\$380	\$5.85	\$562	\$942
Elbow 90, 6"	4	each	\$16.45	\$66	\$11.70	\$47	\$113
Roof flashing	4	each	\$8.55	\$34	\$11.70	\$47	\$81
Tee, 6"	4	each	\$17.40	\$70	\$14.60	\$58	\$128
Tee cap, 6"	4	each	\$1.75	\$7	\$9.50	\$38	\$45
Top cap, 6"	4	each	\$9.85	\$39	\$8.75	\$35	\$74
Architectual modification							
Core drill floor/ceil./roof	4	each	\$51.30	\$205	---	---	\$205
2x4 wood framing @ 16"	384	s.f.	\$1.08	\$415	\$0.42	\$161	\$576
5/3" type x gypsum wallbd.	384	s.f.	\$1.08	\$415	\$0.28	\$108	\$522
Painting	800	s.f.	\$0.60	\$480	\$0.16	\$128	\$608
Patch roofing	4	each	\$24.70	\$99	\$6.35	\$25	\$124
SUB-TOTAL:				\$4,519		\$3,513	\$8,032
Labor Markup: 21%				\$949		---	\$949
Taxes: 4.5%				---		\$158	\$158
SUB-TOTAL:				\$5,468		\$3,671	\$9,139
Overhead: 10%				\$547		\$367	\$914
SUB-TOTAL:				\$6,015		\$4,038	\$10,053
Profit: 10%				\$601		\$404	\$1,005
TOTAL:				\$6,616		\$4,442	\$11,058

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 3
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing water heaters with gas water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	4	each	\$130	\$520	\$412	\$1,648	\$2,168
Remove water heater	4	each	\$90	\$360	---	---	\$360
as double wall, galv., 4"	40	v.l.f.	\$5.15	\$206	\$2.86	\$114	\$320
Elbow 90, 4"	4	each	\$16.45	\$66	\$11.70	\$47	\$113
Tee, 6"	4	each	\$17.40	\$70	\$14.60	\$58	\$128
Tee cap, 6"	4	each	\$1.75	\$7	\$9.50	\$38	\$45
SUB-TOTAL:				\$880		\$1,648	\$2,528
Labor Markup: 21%				\$185		---	\$185
Taxes: 4.5%				---		\$74	\$74
SUB-TOTAL:				\$1,065		\$1,722	\$2,787
Overhead: 10%				\$106		\$172	\$279
SUB-TOTAL:				\$1,171		\$1,894	\$3,066
Profit: 10%				\$117		\$189	\$307
TOTAL:				\$1,288		\$2,084	\$3,372

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 3
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing electric water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	4	each	\$125	\$500	\$302	\$1,208	\$1,708
Remove water heater	4	each	\$90	\$360	---	---	\$360
SUB-TOTAL:				\$860		\$1,208	\$2,068
Labor Markup: 21%				\$181		---	\$181
Taxes: 4.5%				---		\$54	\$54
SUB-TOTAL:				\$1,041		\$1,262	\$2,303
Overhead: 10%				\$104		\$126	\$230
SUB-TOTAL:				\$1,145		\$1,389	\$2,533
Profit: 10%				\$114		\$139	\$253
TOTAL:				\$1,259		\$1,527	\$2,787

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

WOODLAWN VILLAGE - TYPE 4 (22 buildings)

Proposed conversion

Estimated cost of gas-fired furnace	= \$	5,529
Estimated cost of gas-fired water heater	= \$	1,686
Cost of conversion now	= \$	7,215
Total Cost of Conversion	\$7,215 X 22	= \$158,730

Water heater replacement costs

Gas-fired water heaters	= \$1,686 X 22	= \$ 37,092
Electric water heaters	= \$1,393 X 22	= \$ 30,646

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 4
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace heat pumps with new gas furnaces

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Remove heat pump	2	each	\$200	\$400	---	---	\$400
Install gas furnace							
Gas furnaces w/ controls	2	each	\$88	\$176	\$390	\$780	\$956
Pres. reg., valves, etc.	2	each	\$85	\$170	\$160	\$320	\$490
Gas piping	60	l.f.	\$3.21	\$193	\$0.87	\$52	\$245
Holes thru walls	4	each	\$54	\$216	---	---	\$216
Install gas vent chimney							
Gas double wall, galv., 6"	48	v.l.f.	\$3.96	\$190	\$5.85	\$281	\$471
Elbow 90, 6"	2	each	\$16.45	\$33	\$11.70	\$23	\$56
Roof flashing	2	each	\$8.55	\$17	\$11.70	\$23	\$41
Tee, 6"	2	each	\$17.40	\$35	\$14.60	\$29	\$64
Tee cap, 6"	2	each	\$1.75	\$4	\$9.50	\$19	\$23
Top cap, 6"	2	each	\$9.85	\$20	\$8.75	\$18	\$37
Architectual modification							
Core drill floor/ceil./roof	2	each	\$51.30	\$103	---	---	\$103
2x4 wood framing @ 16"	192	s.f.	\$1.08	\$207	\$0.42	\$81	\$288
5/3" type x gypsum wallbd.	192	s.f.	\$1.08	\$207	\$0.28	\$54	\$261
Painting	400	s.f.	\$0.60	\$240	\$0.16	\$64	\$304
Patch roofing	2	each	\$24.70	\$49	\$6.35	\$13	\$62
SUB-TOTAL:				\$2,259		\$1,757	\$4,016
Labor Markup: 21%				\$474		---	\$474
Taxes: 4.5%				---		\$79	\$79
SUB-TOTAL:				\$2,734		\$1,836	\$4,570
Overhead: 10%				\$273		\$184	\$457
SUB-TOTAL:				\$3,007		\$2,019	\$5,026
Profit: 10%				\$301		\$202	\$503
TOTAL:				\$3,308		\$2,221	\$5,529

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 4
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing water heaters with gas water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	2	each	\$130	\$260	\$412	\$824	\$1,084
Remove water heater	2	each	\$90	\$180	---	---	\$180
as double wall, galv., 4"	20	v.l.f.	\$5.15	\$103	\$2.86	\$57	\$160
Elbow 90, 4"	2	each	\$16.45	\$33	\$11.70	\$23	\$56
Tee, 6"	2	each	\$17.40	\$35	\$14.60	\$29	\$64
Tee cap, 6"	2	each	\$1.75	\$4	\$9.50	\$19	\$23
SUB-TOTAL:				\$440		\$824	\$1,264
Labor Markup: 21%				\$92		---	\$92
Taxes: 4.5%				---		\$37	\$37
SUB-TOTAL:				\$532		\$861	\$1,393
Overhead: 10%				\$53		\$86	\$139
SUB-TOTAL:				\$586		\$947	\$1,533
Profit: 10%				\$59		\$95	\$153
TOTAL:				\$644		\$1,042	\$1,686

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 4
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing electric water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	2	each	\$125	\$250	\$302	\$604	\$854
Remove water heater	2	each	\$90	\$180	---	---	\$180
SUB-TOTAL:				\$430		\$604	\$1,034
Labor Markup: 21%				\$90		---	\$90
Taxes: 4.5%				---		\$27	\$27
SUB-TOTAL:				\$520		\$631	\$1,151
Overhead: 10%				\$52		\$63	\$115
SUB-TOTAL:				\$572		\$694	\$1,267
Profit: 10%				\$57		\$69	\$127
TOTAL:				\$630		\$764	\$1,393

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

WOODLAWN VILLAGE - TYPE 5 (21 buildings)

Proposed conversion

Estimated cost of gas-fired furnace	= \$	8,294
Estimated cost of gas-fired water heater	= \$	2,529
Cost of conversion now	= \$	10,823
Total Cost of Conversion	\$10,823 X 21	= \$227,283

Water heater replacement costs

Gas-fired water heaters	= \$2,529 X 21	= \$ 53,109
Electric water heaters	= \$2,090 X 21	= \$ 43,890

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 5
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace heat pumps with new gas furnaces

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Remove heat pump	3	each	\$200	\$600	---	---	\$600
Install gas furnace							
Gas furnaces w/ controls	3	each	\$88	\$264	\$390	\$1,170	\$1,434
Pres. reg., valves, etc.	3	each	\$85	\$255	\$160	\$480	\$735
Gas piping	90	l.f.	\$3.21	\$289	\$0.87	\$78	\$367
Holes thru walls	6	each	\$54	\$324	---	---	\$324
Install gas vent chimney							
Gas double wall, galv., 6"	72	v.l.f.	\$3.96	\$285	\$5.85	\$421	\$706
Elbow 90, 6"	3	each	\$16.45	\$49	\$11.70	\$35	\$84
Roof flashing	3	each	\$8.55	\$26	\$11.70	\$35	\$61
Tee, 6"	3	each	\$17.40	\$52	\$14.60	\$44	\$96
Tee cap, 6"	3	each	\$1.75	\$5	\$9.50	\$29	\$34
Top cap, 6"	3	each	\$9.85	\$30	\$8.75	\$26	\$56
Architectual modification							
Core drill floor/ceil./roof	3	each	\$51.30	\$154	---	---	\$154
2x4 wood framing @ 16"	288	s.f.	\$1.08	\$311	\$0.42	\$121	\$432
5/3" type x gypsum wallbd.	288	s.f.	\$1.08	\$311	\$0.28	\$81	\$392
Painting	600	s.f.	\$0.60	\$360	\$0.16	\$96	\$456
Patch roofing	3	each	\$24.70	\$74	\$6.35	\$19	\$93
SUB-TOTAL:				\$3,389		\$2,635	\$6,024
Labor Markup: 21%				\$712		---	\$712
Taxes: 4.5%				---		\$119	\$119
SUB-TOTAL:				\$4,101		\$2,753	\$6,854
Overhead: 10%				\$410		\$275	\$685
SUB-TOTAL:				\$4,511		\$3,029	\$7,540
Profit: 10%				\$451		\$303	\$754
TOTAL:				\$4,962		\$3,332	\$8,294

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 5
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing water heaters with gas water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	3	each	\$130	\$390	\$412	\$1,236	\$1,626
Remove water heater	3	each	\$90	\$270	---	---	\$270
as double wall, galv., 4"	30	v.l.f.	\$5.15	\$155	\$2.86	\$86	\$240
Elbow 90, 4"	3	each	\$16.45	\$49	\$11.70	\$35	\$84
Tee, 6"	3	each	\$17.40	\$52	\$14.60	\$44	\$96
Tee cap, 6"	3	each	\$1.75	\$5	\$9.50	\$29	\$34
SUB-TOTAL:				\$660		\$1,236	\$1,896
Labor Markup: 21%				\$139		---	\$139
Taxes: 4.5%				---		\$56	\$56
SUB-TOTAL:				\$799		\$1,292	\$2,090
Overhead: 10%				\$80		\$129	\$209
SUB-TOTAL:				\$878		\$1,421	\$2,299
Profit: 10%				\$88		\$142	\$230
TOTAL:				\$966		\$1,563	\$2,529

CONSTRUCTION COST ESTIMATE

PROJECT: ENERGY SAVINGS OPPORTUNITY SURVEY

LOCATION: Typical building 5
Woodlawn Village
Fort Belvoir, VA

BY: Engineering Applications Consultants

Replace existing electric water heaters

ITEM	QUANTITY		LABOR		MATERIAL		TOTAL COST
	Number	Unit	Per unit	Total	Per unit	Total	
Install water heater	3	each	\$125	\$375	\$302	\$906	\$1,281
Remove water heater	3	each	\$90	\$270	---	---	\$270
SUB-TOTAL:				\$645		\$906	\$1,551
Labor Markup: 21%				\$135		---	\$135
Taxes: 4.5%				---		\$41	\$41
SUB-TOTAL:				\$780		\$947	\$1,727
Overhead: 10%				\$78		\$95	\$173
SUB-TOTAL:				\$858		\$1,041	\$1,900
Profit: 10%				\$86		\$104	\$190
TOTAL:				\$944		\$1,146	\$2,090

CONSTRUCTION COST ESTIMATE				DATE PREPARED		AUG '91		SHEET 1 OF 1	
PROJECT ENERGY SAVINGS OPPORTUNITY SURVEY						BASIS FOR ESTIMATE <input type="checkbox"/> CODE A (No design completed) <input type="checkbox"/> CODE B (Preliminary design) <input type="checkbox"/> CODE C (Final design) <input type="checkbox"/> OTHER (Specify) _____			
LOCATION FT. BELVOIR, VIRGINIA									
ARCHITECT ENGINEER ENGINEERING APPLICATIONS CONSULTANTS									
DRAWING NO. WOODLAWN VILLAGE				ESTIMATOR REF		CHECKED BY VP			
<u>GAS to BLDGS</u> SUMMARY		QUANTITY		LABOR		MATERIAL		TOTAL COST	
		NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL		
TRENCH & BACKFILL									
	11,000	LF	1.01	11,110	.74	8,140	19,250		
HAND EXCAVATING									
	1400	CY	34.00	47,600		-	47,600		
HAND BACKFILLING									
	1400	CY	12.45	17,430		-	17,430		
POLYETHYLENE PIPE - 1 1/4"									
	11,000	LF	1.17	12,870	.55	6050	18,920		
BLACK STEEL PIPE - 3/4"									
	1000	LF	3.21	3,210	.87	870	4,080		
MAIN CONNECTIONS									
	444	EA	15.00	6,660	5.00	2220	8,880		
STOP VALVES - 3/4"									
	444	EA	9.00	3,996	8.05	3574	7,570		
PRESSURE REGULATORS									
	444	EA	10.00	4,440	50.00	22,200	26,640		
SIDEWALK REPAIR									
	2000	SF	.94	1,880	1.26	2,520	4,400		
PAVEMENT REMOVAL									
	200	SY	1.84	368	2.56	512	880		
DISPOSAL OF MATERIALS									
		LS		1,000		-	1,000		
MATERIAL HANDL./STORAGE									
		LS		1,000		-	1,000		
SEED & SOD									
		LS		750		-	750		
GAS LINE TESTING									
	444	EA	10.00	4,444		-	4,444		
GENERAL CLEAN-UP									
	444	EA	10.00	4,444		-	4,444		
SUB-TOTAL									
				121,202		46,086	167,288		
LABOR, INS. & TAXES 21%									
				25,452		-	25,452		
SALES TRX 45%									
				-		2,074	2,074		
SUB-TOTAL									
				146,654		48,160	194,814		
OVERHEAD 10%									
							19,481		
SUB-TOTAL									
							214,294		
PROFIT 10%									
							21,429		
SUB-TOTAL									
							235,723		
TOTAL									
							235,723		

PROPORTIONATE COST / UNIT = $\frac{89 \times 235,723}{444} = \$531.$

ENGINEERING ANALYSIS

Sheet _____ of _____

By _____

Project: ESOS, FORT BELVOIR, VIRGINIA Date: August 29, 1991

Contract No: DACA 31-89-C-0198 EAC Project No. 89034.01

FUEL CONVERSION COST ANALYSIS

WOODLAWN VILLAGE - SUMMARY OF COSTS

Type 1 (50 buildings)	\$ 669,650
Type 2 (34 buildings)	\$ 245,310
Type 3 (16 buildings)	\$ 230,880
Type 4 (22 buildings)	\$ 158,730
Type 5 (21 buildings)	\$ 227,283
Cost to Govt for curb to building gas lines	\$ 235,723
TOTAL	\$1,767,576

Replacement costs of water heaters:

	<u>Gas-fired</u>	<u>Electric</u>
Type 1 (50 buildings)	\$116,750	\$103,900
Type 2 (34 buildings)	\$ 57,324	\$ 47,362
Type 3 (16 buildings)	\$ 53,952	\$ 44,592
Type 4 (22 buildings)	\$ 37,092	\$ 30,646
Type 5 (21 buildings)	\$ 53,109	\$ 43,890
Total	\$318,227	\$270,390

FORT BELVOIR WOODLAWN HOUSING AREA

CONSOLIDATION OF OTHER COSTS

TYPE	No.	MAINT. COST PER BLDG	ONE TIME REPL COSTS		MAINT. COSTS	ONE TIME REPL COST	
			\$ PER ELEC. WH	BLDG GAS WH		\$ ELEC. WH	GAS WH
1	50	40	2078	-2335	2000	103900	-116750
2	34	20	1393	-1686	680	47362	-57324
3	16	40	2787	-3372	640	44592	-53952
4	22	20	1393	-1686	440	30646	-37092
5	21	30	2090	-2529	630	43890	-53109
TOTAL	143				4390	270390	-318227

**LIFE CYCLE COST ANALYSIS SUMMARY
ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)**

LOCATION: FORT BELVOIR REGION NO. 3 PROJECT NUMBER DACA-31-89-C-0198

PROJECT TITLE: ENERGY SAVINGS OPPORTUNITY SURVEY FISCAL YR. 199

DISCRETE PORTION NAME WOODLAWN VILLAGE - ELECTRIC TO GAS CONVERSION

ANALYSIS DATE August '91 ECONOMIC LIFE 15 YEARS PREPARED BY EAC

1. INVESTMENT

A. CONSTRUCTION COST	\$ 1,767,576
B. SIOH	\$ 97,217
C. DESIGN COST	\$ 106,055
D. SALVAGE VALUE	-
E. TOTAL INVESTMENT (1A + 1B + 1C - 1D)	<u>\$ 1,970,848</u>

2. ENERGY SAVINGS (+) / COST (-)
ANALYSIS DATE ANNUAL SAVINGS, UNIT COST AND DISCOUNTED SAVINGS

	COST \$/MBTU/YR(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS (5)
A. ELEC	\$ 18.05	17,205	\$ 310,550	11.11	\$ 3,450,213
B. DIST	\$ 7.43				
C. RESID	\$ 6.62				
D. NG	\$ 5.33	- 26,596	\$ -141,757	14.45	\$ -2,048,384
E. COAL					
F. TOTAL		- 9,391	\$ 168,793		<u>\$ 1,401,829</u>

NONENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)

(1) DISCOUNT FACTOR (TABLE A)	MAINT. \$ 4,390
(2) DISCOUNTED SAVING/COST (3A X 3A1)	10.59 <u>\$ 46,490</u>

B. NONRECURRING SAVINGS (+) / COST (-)

ITEM	SAVINGS (+) COST (-)(1)	YEAR OF OCCUR.(2)	DISCOUNT FACTOR(3)	DISCOUNTED SAV- INGS(+)-COST(-)(4)
REPL.				
(1) ELEC WH	\$ 270,390	10	0.63	\$ 170,346
(2) GAS WH	\$ -318,227	10	0.63	\$ -200,483
(3)				
(4) TOTAL	<u>\$ -47,837</u>			<u>\$ -30,137</u>

C. TOTAL NONENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 16,353

D. PROJECT NONENERGY QUALIFICATION TEST

(1) 25% MAX NONENERGY CALC (2F5 x .33)	\$ 462,604
a. IF 3D1 IS = OR > 3C GO TO ITEM 4	
b. IF 3D1 IS < 3C CALC SIR = (2F5+3D1) - 1E =	
c. IF 3D1 IS = > 1 GO TO ITEM 4	
d. IF 3D1 IS < 1 PROJECT DOES NOT QUALIFY	

4. FIRST YEAR DOLLAR SAVINGS 2F3 + 3A + (3B1d ÷ YEARS ECONOMIC LIFE) \$ 169,994

5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C) \$ 1,418,182

6. DISCOUNTED SAVINGS RATION (IF < 1 PROJECT DOES NOT QUALIFY) (S1R) = (5 ÷ 1E) = 0.72

SIMPLE PAY BACK PERIOD = 11.6 years